

NOTICE OF VIOLATION

Florida Power & Light Company
St. Lucie 1

Docket Nos. 50-335
License Nos. DPR-67

During the Nuclear Regulatory Commission (NRC) inspection conducted on May 14 through June 11, 1990, a violation of NRC requirements was identified. The violation involved failure to follow a surveillance procedure. In accordance with the "General Statement of Policy and Procedures for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1990), the violation is listed below:

Unit 1 Technical Specification (TS) 6.8.1.a requires that written procedures shall be established, implemented and maintained covering the activities recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978. Appendix A, paragraph 1.d., includes procedures addressing procedure adherence and temporary change method.

Procedure QI 5-PR/PSL-1, Rev 37, Preparation, Revision, Review/Approval of Procedures, section 5.5, implemented TS 6.8.1 and required that procedures be strictly adhered to. It also provided the method to obtain approved temporary procedure changes and, if appropriate, subsequent permanent changes.

Procedure OP 1-0120051, Rev 10, RCS Flow Determination by Calorimetric Procedure, steps 8.3 through 8.6, directed certain action sequences involving coordination with the Reactor Control Operator at the control board, control board loop temperature meter function selection using switches, and confirmation that measurements were being made only on channels that had the meter switched out and isolated.

Contrary to the above, on May 14, 1990, During the performance of procedure OP 1-0120051, the licensee's staff did not follow instruction steps 8.3 through 8.6. The test persons instead utilized an unapproved method to isolate all the meters to simultaneously isolate the involved loop temperature meters and complete the data collection without the described coordination.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, the Florida Power & Light Company is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, St. Lucie, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) admission or denial of the alleged violation, (2) the reason for the violation if admitted, (3) the

9007260083 900710
PDR ADOCK 05000335
Q PDC


Florida Power & Light Company
St. Lucie 1

2

Docket Nos. 50-335
License Nos. DPR-67

corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION



Marvin V. Sinkule, Chief
Reactor Projects Branch 3
Division of Reactor Projects

Dated at Atlanta Georgia
this 15th day of July 1990