

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9009040033 DOC. DATE: 90/08/27 NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 BOHLKE, W.H. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-67 & NPF-16, changing Tech Specs re moderator temp coefficient SRs.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR ENCL SIZE: 3+2
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL
	PD2-2 LA	1		1	PD2-2 PD	1		1
	NORRIS, J	2		2				
INTERNAL:	ACRS	6		6	NRR/DET/ECMB 9H	1		1
	NRR/DOEA/OTSB11	1		1	NRR/DST 8E2	1		1
	NRR/DST/SELB 8D	1		1	NRR/DST/SICB 7E	1		1
	NRR/DST/SRXB 8E	1		1	NUDOCS-ABSTRACT	1		1
	OC/LEMB	1		0	OGC/HDS2	1		0
	<u>REG FILE</u> 01	1		1	RES/DSIR/EIB	1		1
EXTERNAL:	NRC PDR	1		1	NSIC	1		1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 23 ENCL 21

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

AUGUST 27 1990

L-90-312
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Moderator Temperature Coefficient
Surveillance Requirements
(TAC Nos. 66854 and 66855)

By letter L-87-525 dated December 22, 1987, Florida Power & Light Company (FPL) submitted a request to amend Facility Operating Licenses DPR-67 and NPF-16. The proposed amendments involved changes to the St. Lucie Units 1 and 2 Technical Specifications with respect to the requirements to perform a Moderator Temperature Coefficient (MTC) Test near the end of each cycle. These tests would not be required if tests conducted earlier in the cycle agree with design MTC calculations and if core reactivity characteristics predict that satisfactory MTC behavior will be obtained for the remainder of the cycle.

On October 26, 1989 and January 9, 1990 conference calls were held between FPL and the NRC to discuss questions the NRC had pertaining to the proposed amendments. By letter L-90-69 dated February 26, 1990, FPL responded to the questions. Also, on June 26, 1990, a conference call was held between FPL and the NRC to discuss FPL's L-90-69 submittal. During this call, the NRC proposed additional wording to the St. Lucie Units 1 and 2 Technical Specifications Surveillance Requirement 4.1.1.4.2.c.

The purpose of this submittal is to provide a revision to FPL's original amendment application of December 22, 1987, addressing the NRC's proposed wording change to Technical Specifications Surveillance Requirement 4.1.1.4.2.c. Marked up copies of the Technical Specifications pages affected by this revision are attached. FPL has reviewed the original FPL Safety Evaluation and No Significant Hazards Consideration determination of December 22, 1987, and determined that changes are not necessary.

9009040033 900827
PDR . ADOCK 05000335
P PDC

00301

Accol
11

U. S. Nuclear Regulatory Commission
L-90-312
Page Two

The proposed amendments revisions have been reviewed by the St. Lucie Facility Review Group and the Florida Power and Light Company Nuclear Review Board.

Please contact us if you have any questions concerning this revision.

Very truly yours,



W. H. Bohlke
Vice President
Nuclear Engineering and Licensing

WHB/lef

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, USNRC, Region II
Senior Resident Inspector, USNRC St. Lucie Plant
Mr. Jacob Nash, Florida Department of Health and
Rehabilitative Services

Attachment