

INSERT FOR ST. LUCIE UNIT 1

p. 3/4 1-6

At any THERMAL POWER, within 7 EFPD after reaching a RATED THERMAL POWER equilibrium boron concentration of 300 ppm. The MTC determination of this paragraph is not required if the results of Surveillance Requirements 4.1.1.4.2a. and 4.1.1.4.2b. are within a tolerance of ± 2.0 pcm/ $^{\circ}$ F from corresponding design values and plant conditions at RATED THERMAL POWER and at an equilibrium boron concentration of 300 ppm are in accordance with Surveillance Requirement 4.1.1.1.2.

EJW4/052/4

9009040034 900827
PDR ADOCK 05000335
P FDC

At any THERMAL POWER, within 7 EFPD after reaching a RATED THERMAL POWER equilibrium boron concentration of 300 ppm. The MTC determination of this paragraph is not required if the results of the tests required in Surveillance requirements 4.1.1.4.2a. and 4.1.1.4.2b. are within a tolerance of ± 2.0 pcm/ $^{\circ}$ F from corresponding design values and plant conditions at RATED THERMAL POWER and at an equilibrium boron concentration of 300 ppm are in accordance with Surveillance Requirement 4.1.1.1.2.



10-10-10

10-10-10