

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9101280251 DOC. DATE: 91/01/26 NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 GOLDBERG, J.H. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Clarifies 900413 response to violations noted in Insp Repts
 50-335/90-02 & 50-389/90-02. Corrective actions: nuclear job
 planning sys changed to include speed governor oil changes
 consistent w/vendor recommendations.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-2 PD		1	1		NORRIS, J		1	1
INTERNAL:	ACRS		2	2		AEOD		1	1
	AEOD/DEIIB		1	1		AEOD/TPAB		1	1
	DEDRO		1	1		NRR MORISSEAU, D		1	1
	NRR SHANKMAN, S		1	1		NRR/DLPQ/LPEB10		1	1
	NRR/DOEA/OEAB		1	1		NRR/DREP/PEPB9D		1	1
	NRR/DRIS/DIR		1	1		NRR/DST/DIR 8E2		1	1
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1
	OE DIR		1	1		OGC/HDS2		1	1
	REG FILE 02		1	1		RGN2 FILE 01		1	1
EXTERNAL:	EG&G/BRYCE, J.H.		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL ~~24~~ 0

R
I
D
S
/
A
D
D
S





FPL

JANUARY 24 1991

L-91-26

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit 1 and 2
Docket Nos. 50-335 and 50-389
Response to Notice of Violation Clarification
Inspection Report 90-02

Reference A: St. Lucie Unit 1 and 2
Docket Nos. 50-335 and 50-389
Response to Notice of Violation
Inspection Report 90-02
L-90-138, dated April 13, 1990

On January 10, 1991, a discussion between NRC Region II personnel and the St. Lucie Plant staff resulted in a request by the NRC for clarification of the "specific procedures" mentioned in Finding B, Response 3, in Reference A. In Reference A, Florida Power & Light Company (FPL) stated:

3. The specific vendor recommendation regarding the speed governor oil change was completed. The specific procedures were changed to reflect the oil changes at a frequency consistent with the vendor's recommendation.

FPL submits the following clarification:

The Nuclear Job Planning System (NJPS) was changed to include the speed governor oil changes at a frequency consistent with the vendor's recommendation on February 2, 1990. The NJPS is a system designed to ensure preventative maintenance is scheduled within the desired time frames and tracked to completion.

A detailed set of written work instructions was developed using the guidance in the vendor technical manual to perform the required preventative maintenance. This detailed set of written work instructions was in the form of an attachment which was issued with the maintenance work order. When this maintenance was subsequently performed, it was done using the developed set of detailed

9101280251 910124
PDR ADOCK 05000335
Q PDR

IE01
110

L-91-26
Page 2

instructions. In addition, this maintenance was performed under the supervision of the Instrument and Control supervisor and the System Engineer.

FPL regrets any confusion caused by our response of April 13, 1990. A detailed written procedure was issued on January 11, 1991, replacing the written instructions discussed above.

Very truly yours,



J. H. Goldberg
President - Nuclear Division

JHG/JWH

cc: Stewart D. Ebnetter, Regional Administrator, USNRC Region II
Senior Resident Inspector, USNRC, St. Lucie Plant