

May 28, 1991

Docket Nos. 50-335
and 50-389

LICENSEE: Florida Power and Light Company (FPL)

FACILITY: St. Lucie Units 1 and 2

SUBJECT: SUMMARY OF THE MEETING TO DISCUSS IMPLEMENTATION OF THE STATION
BLACKOUT RULE AT ST. LUCIE 1 AND 2

On May 21, 1991, the NRC staff met with Florida Power and Light Company (FPL) to discuss implementation of the Station Blackout Rule, 10 CFR 50.63 (SBO) at the St. Lucie Plant. Enclosure 1 lists the attendees. Enclosure 2 contains the slides FPL used during the presentation.

After the introduction, FPL reviewed the chronology of SBO at the St. Lucie Plant and outlined the electrical design of the station, including the proposed crosstie between the units. Then the operational and technical considerations of the required modifications were discussed. Finally, FPL presented a list of proposed revisions to the staff's draft SER issued on November 21, 1990. The staff agreed to review the proposed changes.

Original signed by

Jan A. Norris, Sr. Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures:
See next page

Distribution
See next page

memo-4

OFC	:LA:PDII-2	:PM:PDII-2	:D:PDII-2	:	:
NAME	:DMA:Wen	:JNorris:kdj	:HBerkey	:	:
DATE	:5/24/91	:5/24/91	:5/28/91	:	:

OFFICIAL RECORD COPY
Document Name: SUMMARY ST. LUCIE

NRC FILE CENTER COPY

Defol 111

9106060175	910528
PDR ADOCK	05000335
PDR	PDR



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and cannot be transcribed accurately.]

Florida Power & Light Company

St. Lucie Plant

cc:

Jack Shreve, Public Counsel
Office of the Public Counsel
c/o The Florida Legislature
111 West Madison Avenue, Room 812
Tallahassee, Florida 32399-1400

Senior Resident Inspector
St. Lucie Plant
U.S. Nuclear Regulatory Commission
7585 S. Hwy A1A
Jensen Beach, Florida 33457

State Planning & Development
Clearinghouse
Office of Planning & Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Harold F. Reis, Esq.
Newman & Holtzinger
1615 L Street, N.W.
Washington, DC 20036

John T. Butler, Esq.
Steel, Hector and Davis
4000 Southeast Financial Center
Miami, Florida 33131-2398

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Mr. James V. Chisholm, County
Administrator
St. Lucie County
2300 Virginia Avenue
Fort Pierce, Florida 34982

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Jacob Daniel Nash
Office of Radiation Control
Department of Health and
Rehabilitative Services
1317 Winewood Blvd.
Tallahassee, Florida 32399-0700

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Mr. R. E. Grazio
Director, Nuclear Licensing
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

Mr. J. H. Goldberg
President - Nuclear Division
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Meeting Summary dated May 28, 1991

Distribution

Docket File

NRC & Local PDRs

T. Murley

F. Miraglia

J. Partlow

S. Varga

G. Lainas

PDII-2 RF

D. Miller

J. Norris

H. Berkow

OGC

E. Jordan, MNBB 3701

F. Rosa

R. Auluck

J. Knight

M. El-Zeftawy

T. Ross

D. Dorman

D. Shum

J. Raval

P. Gill

K. Jabbour

S. Elrod, RII

R. Lo

C. Y. Liang

A. Thadani

G. Hubbard

ACRS (10)

J. Wechselberger, 17-G-21

M. Sinkule, RII



1997

1998

1999

2000

2001

2002

2003

2004

2005

2006

2007

2008

2009

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025

2026

2027

2028

2029

2030

2031

2032

2033

2034

2035

2036

2037

2038

2039

2040

2041

2042

2043

2044

2045

2046


2047

2048


MEETING BETWEEN FLORIDA POWER AND LIGHT COMPANY
AND NRC STAFF - ST. LUCIE PLANT

ATTENDANCE RECORD

<u>NAME</u>	<u>AFFILIATION</u>
Jan Norris	NRC/NRR/PDII-2
Herbert Berkow	NRC/NRR/PDII-2
Faust Rosa	NRC/NRR/SELB
Rajender Auluck	NRC/NRR/PDII-2
Jim Knight	NRC/NRR/DST/SELB
Bob Grazio	FPL/Dir. Nucl. Lic.
Tedd Dillard	FPL St. Lucie
Vittorio Pareto	Devonrute
Med El-Zeftawy	NRC/ACRS
Roger Kulavich	FPL St. Lucie Tech. Staff
Thierry Ross	NRC/NRR/PDII-4
Ron Pennenga	FPL/St. Lucie/Operations
J. Laduca	FPL/Nuclear Engineering
R. C. Munter	FPL/Nuclear Engineering
Dan Dorman	NRC/NRR/PDII-2
Mike Schoppman	FPL/Nucl. Licensing
David Shum	NRC/NRR/SPLB
Lamar McLaughlin	FPL/Plant Licensing
J. H. Raval	NRR/SPLB
Paul Gill	NRR/SELB
Gabe Salamon	FPL/Turkey Point Licensing
Thomas E. Roberts	FPL/Engr. Proj. Mgr.
Kahtan N. Jabbour	HRC/HRR (Hatch PM)
Stephen Elrod	NRR/Region II
Ronnie Lo	NRR/PDII-I
Chu-Yu Liang	NRR/DST/SRXB
Ashok Thadani	NRR/DST
Ed Weinkam	FPL
George Hubbard	NRR/SPLB



St. Lucie Nuclear Plant



STATION BLACKOUT

MAY 21, 1991

**FPL/NRC MEETING
STATION BLACKOUT
ST. LUCIE NUCLEAR PLANT
MAY 21, 1991**

AGENDA

INTRODUCTION/OBJECTIVES	McLAUGHLIN
LICENSING BACKGROUND	WEINKAM
ELECTRICAL DESIGN	MUNTER
OPERATIONAL CONSIDERATIONS	PENNENGA
TECHNICAL CONSIDERATIONS	MUNTER
SUMMARY	McLAUGHLIN

MEETING OBJECTIVES

- PRESENT FPL PLANS
- OBTAIN A CONSISTENT UNDERSTANDING BETWEEN FPL AND NRC OF SBO REQUIREMENTS
- CONFIRM FPL'S PLANS MEET 10CFR50.63 AND LICENSING BASIS REQUIREMENTS
- DOCUMENT CONCLUSIONS FROM MEETING
- WORK TOWARD CLOSURE OF STATION BLACKOUT FOR ST. LUCIE

CHRONOLOGY OF 10 CFR 50.63 AT ST. LUCIE PLANT

- **JUNE 21, 1988**

**NRC PUBLISHES SBO RULE IN FEDERAL REGISTER,
EFFECTIVE JULY 22, 1988**

- **APRIL 17, 1989**

**FPL RESPONDS TO SBO RULE FOR UNIT 1 AND UNIT 2 (L-89-145)
FPL'S LICENSING ASSUMPTIONS FOR SBO MODIFICATION DESIGN
BASES ARE:**

- 10 Minute clock defined

- 1. Starts at identification of SBO**
- 2. Ends at powering of SBO unit bus**

- 4 Hour SBO Duration

- 0.95 Emergency Diesel Generator (EDG) Reliability

- Hot Standby For 4 Hours

**- FPL committed to complete the modifications by December 31,
1991**

- **OCTOBER 17-19, 1989**

NRC AND SAIC CONDUCT SBO AUDIT IN JUNO BEACH

- **MARCH 7, 1990**

**FPL PROVIDES RESPONSE TO NRC COMMENTS/QUESTIONS FROM
SBO AUDIT (L-90-58)**

- **NOVEMBER 21, 1990**

**NRC FORWARDS DRAFT SAFETY EVALUATION ON SBO AT UNIT 1;
UNIT 2 EXEMPTED BY REGULATIONS**

- **DECEMBER 21, 1990**

**FPL FORWARDS COMMENT TO NRC ON DRAFT SBO SAFETY
EVALUATION (L-90-452)**

2500

1000



Handwritten notes and symbols in the top right corner, including a cluster of small dots and some faint lines.

STATION BLACKOUT CHRONOLOGY AT ST. LUCIE UNIT 2

- ON JULY 30, 1980, THE NRC'S ATOMIC SAFETY AND LICENSING APPEAL BOARD, IN ALAB 603:

Determines that the design of the circuits connecting St. Lucie Unit 2 to the offsite grid is in compliance with NRC regulations

Concludes that the probability of a complete loss of electric power (other than onsite battery power) at the facility should be designated a "design basis event"

Directs FPL to include in its FSAR an analysis demonstrating the ability of St. Lucie Unit 2 to withstand such a total loss of power

- IN DECEMBER 1981, ST. LUCIE UNIT 2 OPERATING LICENSE REVIEW (NUREG-0843) SECTION 15.10.8 (SSER #1)

Section 15.10.8 NRC Staff states that the event is a licensing basis event for St. Lucie Unit 2


NRC Staff finds "...that the plant system response is acceptable for total station blackout"

- ON NOVEMBER 21, 1990 THE NRC STAFF SAFETY EVALUATION ACKNOWLEDGES THE ST. LUCIE UNIT 2 EXEMPTION FROM 10 CFR 50.63

ELECTRICAL SYSTEM DESIGN ST. LUCIE PLANT

- **ST. LUCIE IS A TWO UNIT SITE WITH TWO COMBUSTION ENGINEERING PRESSURIZED WATER REACTORS**
- **THE TWO MAIN GENERATORS ARE WESTINGHOUSE 1000 MVA GENERATORS THAT PRODUCE APPROXIMATELY 900 MWe AT 22 KV**
- **THE FOUR BAY 240 KV SWITCHYARD PROVIDES SWITCHING CAPABILITY FOR EACH UNIT'S MAIN GENERATOR AND TWO STARTUP TRANSFORMERS AND THREE OUTGOING TRANSMISSION LINES**
- **THE ELECTRICAL SYSTEM FOR EACH UNIT IS AN A/B TRAIN DESIGN WITH A SAFETY RELATED SWING BUS (AB)**
THE SWING BUS CAN BE MANUALLY ALIGNED TO EITHER TRAIN
- **EACH TRAIN HAS A SAFETY AND NON-SAFETY RELATED PORTION WITH EACH SAFETY RELATED TRAIN HAVING ITS OWN EMERGENCY DIESEL GENERATOR**

ST. LUCIE PLANT SIMPLIFIED ONE LINE DIAGRAM



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300

301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400

401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500

501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600

601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700

701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800

801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900

901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000

1001
1002
1003
1004
1005
1006
1007
1008
1009
1010
1011
1012
1013
1014
1015
1016
1017
1018
1019
1020
1021
1022
1023
1024
1025
1026
1027
1028
1029
1030
1031
1032
1033
1034
1035
1036
1037
1038
1039
1040
1041
1042
1043
1044
1045
1046
1047
1048
1049
1050
1051
1052
1053
1054
1055
1056
1057
1058
1059
1060
1061
1062
1063
1064
1065
1066
1067
1068
1069
1070
1071
1072
1073
1074
1075
1076
1077
1078
1079
1080
1081
1082
1083
1084
1085
1086
1087
1088
1089
1090
1091
1092
1093
1094
1095
1096
1097
1098
1099
1100


1101
1102
1103
1104
1105
1106
1107
1108
1109
1110
1111
1112
1113
1114
1115
1116
1117
1118
1119
1120
1121
1122
1123
1124
1125
1126
1127
1128
1129
1130
1131
1132
1133
1134
1135
1136
1137
1138
1139
1140
1141
1142
1143
1144
1145
1146
1147
1148
1149
1150
1151
1152
1153
1154
1155
1156
1157
1158
1159
1160
1161
1162
1163
1164
1165
1166
1167
1168
1169
1170
1171
1172
1173
1174
1175
1176
1177
1178
1179
1180
1181
1182
1183
1184
1185
1186
1187
1188
1189
1190
1191
1192
1193
1194
1195
1196
1197
1198
1199
1200

1201
1202
1203
1204
1205
1206
1207
1208
1209
1210
1211
1212
1213
1214
1215
1216
1217
1218
1219
1220
1221
1222
1223
1224
1225
1226
1227
1228
1229
1230
1231
1232
1233
1234
1235
1236
1237
1238
1239
1240
1241
1242
1243
1244
1245
1246
1247
1248
1249
1250
1251
1252
1253
1254
1255
1256
1257
1258
1259
1260
1261
1262
1263
1264
1265
1266
1267
1268
1269
1270
1271
1272
1273
1274
1275
1276
1277
1278
1279
1280
1281
1282
1283
1284
1285
1286
1287
1288
1289
1290
1291
1292
1293
1294
1295
1296
1297
1298
1299
1300

10 CFR 50.63 MODIFICATION ST. LUCIE UNITS 1 AND 2


- **INSTALL AN INTER-UNIT CABLE CROSS TIE CAPABLE OF TRANSFERRING POWER FROM ANY EDG TO ANY SAFETY-RELATED 4.16 KV SWITCHGEAR THROUGH THE SAFETY RELATED SWING BUS (6-1/c 350MCM POWER CABLES)**
- **THE STATION BLACKOUT CROSSTIE HAS BEEN DESIGNED TO CARRY MORE THAN TWICE THE ANTICIPATED STATION BLACKOUT LOADS**
- **ADD APPROPRIATE CONTROL AND INDICATION EQUIPMENT IN THE CONTROL ROOMS OF BOTH UNITS SUCH THAT THE CROSS-TIE CAN BE ACCOMPLISHED FROM THE CONTROL ROOMS**
- **THIS MODIFICATION SATISFIES THE OBJECTIVES TO:**
 - **Increase flexibility of the plant's electrical distribution to cope with emergency events**
 - **Increase the capability of the operators to accomplish this from inside the Control Room**
 - **Significantly decrease the amount of time and effort currently required to accomplish this task**

10 CFR 50.63 MODIFICATION ST. LUCIE UNITS 1 AND 2



**NOTE: SIMPLIFIED ONE LINE DIAGRAM OF
THE 4.16KV SAFETY RELATED
SWITCHGEAR**

**10 CFR 50.63 MODIFICATION
CONTROL ROOM CONTROLS AND INDICATION
ST. LUCIE UNITS 1 AND 2**



**NOTE: UNIT 2 CONTROL ROOM MODIFICATIONS ARE SHOWN.
UNIT 1 MODIFICATIONS ARE SIMILAR.**




.....
.....


14
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

OPERATIONS DEPARTMENT SBO GOALS

- **MAINTAIN CONTROL OF ALL SAFETY FUNCTIONS ON BOTH UNITS**
- **MAINTAIN HOT STANDBY (MODE 3) CONDITIONS**
 - **Minimum amount of safety equipment requiring emergency AC Power**
 - **Core Heat Removal readily accomplished by Natural Circulation**
 - **Reduced stress compared to the actions required by performing an RCS cooldown**
 - **Reduced RCS make-up demand**
- **TO QUICKLY CROSS CONNECT TO THE OTHER UNIT'S AC POWER SUPPLY, PROVIDING POWER TO EQUIPMENT NECESSARY TO MAINTAIN HOT STANDBY WITH THE MINIMUM AMOUNT OF OPERATOR ACTION**
- **TO PROVIDE UNIFORM AND DETAILED PROCEDURAL GUIDANCE TO OPERATIONS STAFF FOR HANDLING SBO CONDITIONS**
 - **Provide directions and precautions**
 - **Reference point for both control rooms for event strategy**
 - **Uniform EOPs designed to enhance operator familiarity no matter which unit he is on**


STATION BLACKOUT STRATEGY CHART






SAFETY FUNCTIONS (EOP-01)

- REACTIVITY CONTROL
- MAINTENANCE OF VITAL AUXILIARIES
- RCS INVENTORY CONTROL
- RCS PRESSURE CONTROL
- CORE HEAT REMOVAL
- RCS HEAT REMOVAL
- CONTAINMENT ISOLATION
- CONTAINMENT PRESSURE/COMBUSTIBLE GAS

FLORIDA POWER & LIGHT ST. LUCIE PLANT UNIT NO. 1			
			<small>ALPHA</small> DATE _____ EOP _____ ROOM _____ FIVE _____ COMP. COMPLETED _____ BY _____
1-EOP-01 REVISION 3			
			
STANDARD POST TRIP ACTIONS			
EMERGENCY OPERATING PROCEDURE			
REVISION	REVIEWED BY FRG OR	APPROVED BY	DATE
0	December 23, 1985	D. A. Sagar Plant Manager	December 23, 1985
3	12-16-90	G. J. Boley Plant Manager	12-21-90
Responsible Department: OPERATIONS			
CAR 19808			

FLORIDA POWER & LIGHT ST. LUCIE PLANT UNIT NO. 2			
			<small>ALPHA</small> DATE _____ EOP _____ ROOM _____ FIVE _____ COMP. COMPLETED _____ BY _____
2-EOP-01 REVISION 5			
			
STANDARD POST TRIP ACTIONS			
EMERGENCY OPERATING PROCEDURE			
REVISION	REVIEWED BY FRG OR	APPROVED BY	DATE
0	December 23, 1985	D. A. Sagar Plant Manager	December 23, 1985
5	12-16-90	G. J. Boley Plant Manager	12-21-90
Responsible Department: OPERATIONS			
CAR 19808			

OPERATOR MILESTONES ON SBO ST. LUCIE UNIT 1 WITH LOOP ST. LUCIE UNIT 2

- **ENTER APPROPRIATE RECOVERY GUIDELINE**
 - **ST. LUCIE UNIT 1 will implement EOP 10**
 - **ST. LUCIE UNIT 2 will implement EOP 9**

- **ASSESS CORE AND RCS HEAT REMOVAL CAPABILITIES ON BOTH UNITS**
 - **Establish flow via C AFW pump**
 - **Verify natural circulation**

- **ESTABLISH COMMUNICATIONS**
- **SECURE NON-ESSENTIAL UNIT 2 LOADS**
- **STRIP UNIT 1 EMERGENCY BUSES**
- **CLOSE SBO CROSSTIES**
- **RESTORE UNIT 1 VITAL LOADS**
- **STABILIZE BOTH PLANTS**
- **RESTORE AC POWER**
- **EXIT EOPS, ENTER AN APPROPRIATE OPERATING PROCEDURE**

EMERGENCY DIESEL GENERATOR ST. LUCIE UNIT 2


LOAD RATINGS*

CONTINUOUS	3685 KW
2000 HR	3935 KW
200 HR	3985 KW
4 HR	3985 KW
30 MIN	3985 KW

- *NOTE:**
1. The EDG ratings are based on a 104^oF air intake temperature.
 2. The EDG's are rated for worst case operating conditions. An air intake temperature above 90^oF derates the engine capacity.

ST. LUCIE UNITS 1 AND 2 EDG LOAD PROFILE

200 HOUR RATING (3985 kw)



- UNIT 2**
- . EDG COOLING WTR. HTRS OFF
 - . EDG GEN. HTR. OFF
 - . MOVS. REPOSITIONED
 - . AFW. PUMP SECURED
 - . BAT CHRGS REDUCED TO EQUIVALENT OF 1
 - . RCP OIL LIFT PUMP SECURED
- UNIT 1**
- . MOVS REPOSITIONED
 - . 2 CONT. FAN COOLERS (2) SECURED
 - . HEAT TRACING LOAD REDUCED

NOTE: 1. THIS EDG LOAD PROFILE IS BASED ON UNIT 2 IN A LOOP AND UNIT 1 IN AN SBO EVENT.
2. THIS EDG LOAD PROFILE IS FOR TRAIN "A" OF BOTH UNITS (WORST CASE).

EDG LOAD PROFILE ASSUMPTIONS ST. LUCIE UNITS 1 AND 2

- **ELECTRICAL LOAD FOR PUMP MOTORS IS BASED ON THE BRAKE HORSEPOWER AT PUMP RUN OUT OR OPERATING CONDITIONS**
- **SHUTDOWN COOLING (LPSI) PUMPS ARE NOT INCLUDED IN THE UNIT 1 OR 2 LOADS**
 - Both Units will maintain Hot Standby conditions
 - The LPSI pumps are not automatically started for a LOOP event
- **STEAM DRIVEN AUXILIARY FEEDWATER PUMPS ARE USED ON BOTH UNITS 1 AND 2**
 - Steam driven AFW pumps are available. Therefore, the motor driven AFW pumps are not required.
- **200 HOUR RATING OF THE EDGs WILL BE USED**
 - Power will be restored within 8 hours
 - EDG tested every 18 months for 2 hours at 4 hour rating

REACTOR COOLANT SYSTEM INVENTORY ST. LUCIE UNIT 1

- COMBUSTION ENGINEERING NSSS
- THERMAL CORE RATING OF 2700 MWt
- 2 STEAM GENERATORS WITH 4 REACTOR COOLANT PUMPS
- 3 CHARGING PUMPS RATED AT 44 gpm EACH
- TOTAL RCS INVENTORY (NORMAL OPERATION) OF 75,000 GALLONS
- PRESSURIZER LIQUID VOLUME (NORMAL OPERATION) OF 4500 TO 6000 GALLONS


REACTOR COOLANT SYSTEM INVENTORY ST. LUCIE UNIT 1

- **ASSUMPTIONS IN DRAFT SER FOR RCS LEAKAGE**
 - **Maximum allowable RCS leakage per plant Technical Specifications (12 gpm for identified and unidentified)**
 - **25 gpm per pump losses through Reactor Coolant Pump seals (4 RCPs)**
 - **Therefore, a total of 112 gpm**

- **FPL ASSUMPTIONS FOR RCS LEAKAGE**
 - **Unit 2 SBO analysis is applicable to Unit 1**
 - **Maximum allowable RCS leakage per plant Technical Specifications (11 gpm for identified and unidentified)**
 - **Nominal RCP seal leakage of 1.25 gpm per pump (4 RCPs)**
 - **Therefore, a total of 16 gpm**

REACTOR COOLANT SYSTEM INVENTORY ST. LUCIE UNIT 1

- **BASIS FOR RCP SEAL LEAKAGE ASSUMPTION**
 - RCP seal maintains integrity after seal cooling is lost
 - A test by the pump manufacturer in August 1980
 - Greater than 36 hours at Hot Standby conditions without cooling
 - Maximum seal leakage was less than 0.3 gpm (16.1 gph)
 - Operational experience at St. Lucie Units 1 and 2 (approx. 23 reactor years)
 - 13 RCP seals subjected to loss of cooling
 - No significant increase in seal leakage



HVAC EVALUATION ST. LUCIE UNIT 1

- **AN ENGINEERING EVALUATION WAS PERFORMED FOR THE CONTROL ROOM, REACTOR CONTAINMENT BUILDING, AUXILIARY BUILDING AND ELECTRICAL EQUIPMENT ROOMS FOR THE SBO EVENT**

- **THE EVALUATION CONCLUDED THAT ROOM TEMPERATURES REMAIN BELOW PREVIOUSLY ANALYZED VALUES**

SUMMARY

- **OPERATOR ACTIONS REQUIRED FOR SBO AND NBO UNITS**
- **FPL LICENSING ASSUMPTIONS**
- **STATION BLACKOUT MODIFICATION**
- **REQUESTED REVISIONS TO SAFETY EVALUATION**

REQUESTED REVISIONS TO NRC DRAFT SAFETY EVALUATION ON SBO

PROPOSED CHANGE	SE SECTION/ SE PAGE	REASON FOR CHANGE
Add St. Lucie Unit 2 docket number to the SE.	Cover letter and page 1 of SE	The Unit 2 licensing basis for SBO is being amended by the SE.
Delete the recommendation that FPL verify the NBO unit's auxiliary or startup transformer capacity sufficiency.	Section 2.1/ page 3	FPL concurs that St. Lucie Unit 1 should be classified as independence of offsite power group I 3.
Revise SBO and NBO units SBO/LOOP loads.	Section 2.2.2/ pages 5 and 6	The SBO and LOOP loads have been recalculated by FPL.
Clarify that the time to repower SBO bus is 10 minutes from identification.	Section 2.2.2/ page 6 Section 2.3.5/ page 7	FPL has committed to repower the SBO unit's bus with the AAC source within 10 minutes following confirmation that an SBO has occurred.
Delete requirement to power motor-driven AFW pump and LPSI pump on AAC source for the NBO unit.	Section 2.2.2/ page 6	FPL will provide decay heat removal for the NBO unit using the turbine-driven AFW pump. FPL will maintain the SBO and NBO units in Hot Standby; therefore there is no need to provide for forced cooling decay heat removal.
Revise the AAC source load limit rating to the 200 hour rating.	Section 2.2.2/ page 6	FPL tests the NBO EDGs for 2 hours at the 4 hour rating every 18 months. Event postulated to last no more than 8 hours.

REQUESTED REVISIONS TO NRC DRAFT SAFETY EVALUATION ON SBO

PROPOSED CHANGE	SE SECTION/ SE PAGE	REASON FOR CHANGE
Delete the reference to diesel-driven air compressors.	Section 2.3.3/ page 7	The instrument air compressors at St. Lucie Plant are not diesel driven; the air compressors can be powered from the EDGs.
Revise the hypothesized RCS inventory loss rate to 16 gpm from the 112 gpm presented in the SE.	Section 2.3.6/ page 7	FPL has tested the St. Lucie Units 1 and 2 RCP seals under operating conditions without cooling. The leak rate determined by this testing was significantly less than the postulated value in the draft SER.
Revise the SE Section discussing the proposed modifications implementation schedule to reflect the 10 CFR 50.63 (c) (3) rule requirement of implementation within 2 years of the completion of the NRC's regulatory assessment.	Section 2.5/ page 8	FPL requests that the NRC Staff reflect in the SBO rule-required Safety Evaluation the scheduler requirements for implementation of the SBO modifications as specified in 10 CFR 50.63.
Revise the SE discussion of AAC power sources to accommodate securing of non-essential LOOP loads (NBO Unit).	Section 2.2.1/ pages 4-5 Section 2.2.2/ page 6	Selective load reduction is a desirable element of LOOP recovery for a NBO Unit.

TABLE 5.2 A
 UNIT 2 LOOP - UNIT 1 SBO
 EOP 10 & APPENDIX X/XX
 TRAIN "A" - BOTH UNITS

UNIT	TIME	KW	AUTO/MAN	KW LOAD BLOCK TOTAL	KW RUNNING TOTAL (LOAD BLOCKS)
2	Emerg. Lighting Pnl's	0 sec	82.4	A	
2	MOVs: V-2553,2555,3614,3642,FCV-25-11	0 sec	6.4	A	
	MV-09-09,21-03,21-4A				
2	Power Pnl's: PP-201,201A,211,220,246,250	0 sec	115.4	A	
	262,263,268,203,233,234				
2	RCP Oil Lift Pumps	0 sec	18.0	A	
2	Security Bld Computer A/C HVA-10A	0 sec	7.7	A	
2	Hydrogen Analyzer "SA"	0 sec	1.6	A	
2	D/G Cooling Water Htrs	0 sec	60.0	A	
2	D/G/ Turbo Lub Oil Pmps 2A1-1 and 2A2-1	0 sec	3.6	A	
2	D/G Soak Back Lub Oil Pmps 2A1-1 and 2A2-1	0 sec	1.8	A	
2	D/G Air Compressor	0 sec	6.7	A	
2	Fire/Security UPS	0 sec	30.0	A	
2	Vital (Non-IE) UPS	0 sec	20.0	A	353.6 353.6
2	Containment Fan Coolers 2 HVS-1A and 1B	3 sec	141.0	A	
2	Cntmt Fan Htrs PP-201	3 sec	-0.6	A	
2	D/G Fuel Oil Transfer Pmp 2A	3 sec	2.7	A	143.1 496.7
2	CCW P 2A	6 sec	368.9	A	
2	CCW P Htrs PP-201	6 sec	-1.1	A	367.8 864.5
2	ICW P 2A	9 sec	476.8	A	
2	ICW P Htrs PP-201	9 sec	-0.9	A	475.9 1340.4
2	EE Rm Fan 2 HVS-5A	18 sec	72.8	A	
2	EE Fan HVS-5A Htr PP-201	18 sec	-0.2	A	
2	Reactor Cavity Supply 2 HVS-2A	18 sec	13.7	A	
2	Reactor Support Cooling 2 HVE-3A	18 sec	21.8	A	
2	Support Cool Fan Htr PP-201	18 sec	-0.3	A	107.8 1448.2
2	EE Rm Exhaust Fan 2 RV-3	21 sec	4.5	A	
2	Battery Rm Exhaust Fan 2 RV-1	21 sec	0.7	A	
2	Intake Bld Exhaust Fan 2 HVE-41A	21 sec	6.7	A	11.9 1460.1
2	Control Rm A/C 2 HVA-3A and ACC-3A	24 sec	49.4	A	
2	CR HVA/ACC-3A Htrs PP-201	24 sec	-0.4	A	49.0 1509.1
2	CVCS Heat Trace	27 sec	3.5	A	
2	Battery Chargers 2A,2AA, and 2AB	27 sec	105.6	A	109.1 1618.2
2	AFW P 2A	30 sec	254.1	A	
2	AFW P Heater PP-201	30 sec	-1.1	A	253.0 1871.2
2	RAB Supply Fan 2 HVS-4A	33 sec	106.6	A	
2	RAB Fan HVS-4A Htr PP-206/201	33 sec	-0.3	A	106.3 1977.5
2	EE Rm Exhaust Fan 2 HVE-11	38 sec	39.4	A	
2	EE Rm Fan HVE-11 Htr PP-201	38 sec	-0.3	A	39.1 2016.6
2	D/G Cool Water Htrs	90 sec	-60.0	A	

TABLE 5.2 A
 UNIT 2 LOOP - UNIT 1 SBO
 EOP 10 & APPENDIX X/XX
 TRAIN "A" - BOTH UNITS

UNIT	TIME	KW	AUTO/HAN	KW LOAD BLOCK TOTAL	KW RUNNING TOTAL (LOAD BLOCKS)
2	D/G Gen Htr PP-211	90 sec	-4.5	A	
2	MOVs	90 sec	-6.4	A	-70.9 1945.7
2	Charging Pmp 2A	300 sec	52.1	A/M	
2	Charging Pmp Htr PP-201	300 sec	-0.6	A	
2	Battery Chargers	300 sec	-52.0	A	
2	EE Rm A/C 2 HVA-ACC-4	300 sec	11.7	A	
2	CVCS Heat Trace (1/2)	300 sec	-1.7	A	9.5 1955.2
2	AFW P 2A	900 sec	-254.1	M	
2	AFW P Htr PP-201	900 sec	1.1	A	
2	RCP Oil Lift Pumps	900 sec	-18.0	M	
2	Charging Pmp 2C	900 sec	52.1	M	
2	Charging Pmp Htr PP-203	900 sec	-0.6	A	
1	RCP Oil Lift Pmp - Secured	900 sec	0.0	M	-219.5 1735.7
2	Close SBO 2AB/1AB Tie Bkrs	1500 sec	0.0	M	
1	Close 480V LC Bkr	1500 sec	0.0	M	
1	D/G Oil Pmp	1500 sec	1.8	A	
1	D/G Air Compressor	1500 sec	6.7	A	
1	D/G Fuel Oil Transfer Pump 1A	1500 sec	4.5	A	
1	Emerg. Lighting Pnls.	1500 sec	125.8	A	
1	MOVs: V-3481,3644,3651,3659	1500 sec	9.4	A	
1	Power Pnls PP-101,111,114,135,PP-103,134	1500 sec	122.3	A	
1	Boric Acid MU Pmp 1A or 1B	1500 sec	16.2	A	
1	BA MU Pmp Htr PP-101	1500 sec	-0.3	A	
1	Cable Spread Rm A/C	1500 sec	31.5	A	
1	Cable Spread Rm Fan	1500 sec	4.5	A	
1	Computer Rm A/C 1 ACC-10A	1500 sec	8.0	A	
1	Computer Rm Fan 1 HVA-10A	1500 sec	2.7	A	
1	Hydrogen Analyzer	1500 sec	1.6	A	
1	Charging Pmp 1A	1500 sec	70.5	A	
1	Charging Pmp Htr PP-101	1500 sec	-0.6	A	404.6 2140.3
1	Containment Fan Coolers 1 HVS-1A and 1B	1503 sec	123.0	A	
1	Cntmt Fan Htrs PP-101	1503 sec	-0.9	A	122.1 2262.4
1	Boric Acid Heat Trace	1518 sec	33.8	A	
1	Control Rm A/C 1 ACC-3A	1518 sec	29.3	A	
1	Control Fan 1 HVA-3A	1518 sec	6.7	A	
1	RAB Supply Fan 1 HVS-4A	1518 sec	41.7	A	
1	Reactor Cavity Supply Fan HVS-2A	1518 sec	15.5	A	
1	Reactor Support Fan HVE-3A	1518 sec	21.6	A	
1	CVCS Heat Trace	1518 sec	10.1	A	
1	Boric Acid Tank Heaters	1518 sec	13.5	A	172.2 2434.6
1	Battery Chargers 1A,1AA	1530 sec	104.0	A	104.0 2538.6
1	MOVs	1560 sec	-9.4	A	
1	Boric Acid Tank Heaters	1560 sec	-13.5	A	-22.9 2515.7

TABLE 5.2 A
 UNIT 2 LOOP - UNIT 1 SBO
 EOP 10 & APPENDIX X/XX
 TRAIN "A" - BOTH UNITS

UNIT	TIME	KW	AUTO/MAN	KW LOAD BLOCK TOTAL	KW RUNNING TOTAL (LOAD BLOCKS)	
1	Containment Fan Coolers	28 min	-122.1	M	-122.1	2393.6
1	Boric Acid Heat Trace (1/2)	30 min	-16.9	A		
1	CVCS Heat Trace (1/2)	30 min	-5.1	A		
2	Przr Htrs	30 min	200.0	M		
2	Inst. Air Compressor 2A	30 min	54.0	M		
2	Inst. Air Cool Fan	30 min	4.5	M		
2	Inst. Air Cool Pmp	30 min	6.8	M	243.3	2636.9
1	D/G Fuel Oil Transfer Pmp	35 min	-4.5	A	-4.5	2632.4
1	Inst. Air compressor 1A	40 min	32.8	M		
1	Inst. Air Comp Fan	40 min	6.7	M		
1	Inst. Air Cool Water Pmp	40 min	1.8	M	41.3	2673.7
1	ICW P 1A	45 min	451.0	M		
1	ICW P Htrs PP-101	45 min	-1.2	A	449.8	3123.5
1	CCW P 1A	50 min	368.9	M		
1	CCW P Htrs PP-101	50 min	-1.1	A	367.8	3491.3
1	PRZR Htr*	55 min	186.0	M		
1	Charging Pmp 1A*	55 min	-70.5	M		
1	Charging Pmp Htr* PP-101	55 min	0.6	A	116.1	3607.4
1	Containment Fan Cooler	60 min	61.1	M		
2	D/G Air Compressor	60 min	-6.7	A		
2	Battery Chargers	60 min	-5.0	A	49.4	3656.8
1	Battery Chargers	90 min	-52.0	A		
1	Fire/Security UPS	90 min	20.0	M		
1	Vital (non-IE) UPS	90 min	20.0	M	-12.0	3644.8
1	EE Rm Roof Fan 1 RV-3	120 min	1.3	M		
1	EE Rm Exhaust Fan 1 HVE-11	120 min	4.1	M		
1	EE Rm Supply Fan 1 HVS-5A	120 min	27.0	M		
1	Cable Spread Rm A/C	120 min	-31.5	M		
1	Cable Spread Rm Fan	120 min	-4.5	M	-3.6	3641.2

DISCRETIONARY LOADS

I					
1	D/G Bld PP-111 Ckts 1, 7, 8, 11 & 12		-32.7		
1	D/G Air Compressor		-6.7		
1	EE Rm Supply Fan 1 HVS-5A		-27.0		
1	Balance of BA & CVCS Heat Trace		-21.9		-88.3
II					
1	Boric Acid MU Pump		-15.9		-15.9

*NOTE: The Unit 1 Pressurizer Heaters and Charging Pump are alternately cycled.

TB52ARCH.WK1

