

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

.ACCESSION NBR:9210260313 DOC.DATE: 92/10/21 NOTARIZED: YES DOCKET #
 FACTL:50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 AUTH.NAME AUTHOR AFFILIATION
 SAGER,D.A. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to license DPR-67, revising TS R
 4.5.2.d.1 to remove shutdown cooling auto-closure interlock I
 surveillance requirement.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+14 D
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES		
		LTR	ENCL		LTR	ENCL	/
	PD2-2 LA	1	1	PD2-2 PD	1	1	A
	NORRIS, J	2	2				D
INTERNAL:	ACRS	6	6	NRR/DET/ESGB	1	1	D
	NRR/DOEA/OTSB11	1	1	NRR/DST/SELB 7E	1	1	D
	NRR/DST/SICB8H7	1	1	NRR/DST/SRXB 8E	1	1	S
	NUDOCS-ABSTRACT	1	1	OC/LEMB	1	0	
	OGC/HDS3	1	0	<u>REG FILE</u> 01	1	1	
	RES/DSIR/EIB	1	1				
EXTERNAL:	NRC PDR	1	1	NSIC	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 20

R
 I
 D
 S
 /
 A
 D
 D
 S
 /
 A
 D
 S

AA-2
dhp

Faint header text at the top of the page, possibly containing a title or page number.



Faint footer text at the bottom of the page, possibly containing a date or page number.



October 21, 1992

L-92-301
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Unit 1
Docket No. 50-335
Proposed License Amendment
Removal of Shutdown Cooling Auto-Closure
Interlock Surveillance Requirement


Pursuant to 10 CFR 50.90, Florida Power & Light Company (FPL) requests to amend Facility Operating License DPR-67 for St. Lucie Unit 1. The proposed amendment revises Technical Specification 4.5.2.d.1 involving surveillance of the Shutdown Cooling System automatic closure interlock (ACI). Approval of this proposal is requested by April 1993 to support a plant modification that would remove the ACI from the St. Lucie Unit 1 design during the Spring 1993 refueling outage. Removal of this interlock and its surveillance requirement will provide a safety benefit in Shutdown Cooling System availability.

Attachment 1 is a marked up copy of the proposed Technical Specification change. Attachment 2 is a Safety Analysis in support of the proposed amendment. Attachment 3 is the "Determination of No Significant Hazards Consideration."

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b)(1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,


D. A. Sager
Vice President
St. Lucie Plant

DAS/RLD/kw
DAS/PSL #807-92

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant
Mr. Jacob D. Nash, Florida Department of Health and
Rehabilitative Services

260062

an FPL Group company

9210260313 921021
PDR ADDCK 05000335
P PDR

Handwritten initials/signature



St. Lucie Unit 1
Docket No. 50-335
Proposed License Amendment
Removal of Shutdown Cooling Auto-Closure
Interlock Surveillance Requirement

STATE OF FLORIDA)
)
COUNTY OF ST. LUCIE) SS.

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.

DA Sager
D. A. Sager

STATE OF FLORIDA
COUNTY OF ST. LUCIE

The foregoing instrument was acknowledged before me this 21 day of October, 19 92 by D. A. Sager, who is personally known to me and who did take an oath.

Karen West
KAREN WEST
Name of Notary Public

My Commission expires 4-18-94
Commission No. CC003229

