



November 30, 1992

L-92-316
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Unit 1
Docket No. 50-335
Proposed License Amendment
St. Lucie Unit 1 Emergency Bus
Undervoltage Relay Setpoint Changes


Pursuant to 10 CFR 50.90, Florida Power & Light Company (FPL) requests to amend Facility Operating License DPR-67 for St. Lucie Unit 1. The proposed amendment revises Technical Specifications Tables 3.3-3, 3.3-4, and 4.3-2 where they apply to the Emergency Bus Undervoltage Protection Devices and will permit improvements to be made in the undervoltage protective relaying scheme. FPL will be prepared to implement the new undervoltage relaying scheme during the next St. Lucie Unit 1 refueling outage.

Attachment 1 is a marked up copy of the proposed Technical Specification change. Attachment 2 is a Safety Analysis in support of the proposed amendment. Attachment 3 is the "Determination of No Significant Hazards Consideration."

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b)(1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,


D. A. Sager
Vice President
St. Lucie Plant

DAS/RLD/kw
DAS/PSL #817-92

030068

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant
Mr. Jacob D. Nash, Florida Department of Health and
Rehabilitative Services

ADD 1/1



Handwritten scribble or signature.

Handwritten text, possibly a date or number.


St. Lucie Unit 1
Docket No. 50-335
Proposed License Amendment
St. Lucie Unit 1 Emergency Bus
Undervoltage Relay Setpoint Changes

STATE OF FLORIDA)
)
COUNTY OF ST. LUCIE) SS.

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licensee herein;


That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.



D. A. Sager

STATE OF FLORIDA
COUNTY OF ST. LUCIE

The foregoing instrument was acknowledged before me this 30th day of November, 1992 by D.A. Sager, who is personally known to me and who did take an oath.



KAREN WEST
Name of Notary Public

My Commission expires 4-18-94

Commission No. CC003229



