

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9302220144 DOC. DATE: 93/02/16 NOTARIZED: YES DOCKET #
 FACILITY: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 AUTH. NAME AUTHOR AFFILIATION
 SAGAR, D.A. Florida Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to license DPR-67, to modify TS
 4.6.1.1.a.1, Containment Integrity SRs, by excluding
 penetrations located inside containment from verification
 required at least once per 31 days.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+8
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL	LTR	ENCL
	PD2-2 LA	1	1	PD2-2 PD	1	1		
	NORRIS, J	2	2					
INTERNAL:	ACRS	6	6	NRR/DET/ESGB	1	1		
	NRR/DOEA/OTSB11	1	1	NRR/DST/SELB 7E	1	1		
	NRR/DST/SICB8H7	1	1	NRR/DST/SRXB 8E	1	1		
	NUDOCS-ABSTRACT	1	1	OC/LEMB	1	0		
	OGC/HDS3	1	0	<u>REG-FILE</u> 01	1	1		
EXTERNAL:	NRC PDR	1	1	NSIC	1	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 19



[The main body of the document contains extremely faint and illegible text, likely bleed-through from the reverse side of the page. The text is scattered across the page and does not form any recognizable words or sentences.]



February 16, 1993

L-93-043
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Unit 1
Docket No. 50-335
Proposed Emergency License Amendment
St. Lucie Unit 1 Containment Penetrations
Surveillance Requirement


Pursuant to 10 CFR 50.90, Florida Power & Light Company (FPL) requests to amend Facility Operating License DPR-67 for St. Lucie Unit 1. The proposed amendment excludes penetrations that are inside containment from the surveillance requirement of Technical Specification (TS) 4.6.1.1.a.1 and is only valid for fuel cycle 11.

Attachment 1 contains a copy of the appropriate TS page marked-up to show the changes. Attachment 2 is a Safety Analysis in support of the proposed amendment. Attachment 3 is the "Determination of No Significant Hazards Consideration."

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b)(1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,


D. A. Sager
Vice President
St. Lucie Plant

DAS/RLD/kw
DAS/PSL #863-93 190122

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant.
Mr. W.A. Passetti, Florida Department of Health and
Rehabilitative Services.

9302220144 930216
PDR ADOCK 05000335
P PDR

ADD

1901


St. Lucie Unit 1
Docket No. 50-335
Proposed Emergency License Amendment
St. Lucie Unit 1 Containment Penetrations
Surveillance Requirement

STATE OF FLORIDA)
)
COUNTY OF ST. LUCIE) ss.

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licensee herein;


That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.



D. A. Sager

STATE OF FLORIDA
COUNTY OF ST. LUCIE

The foregoing instrument was acknowledged before me this 16th day of February, 19 93 by D.A. Sager, who is personally known to me and who did take an oath.



KAREN WEST
Name of Notary Public

My Commission expires 4-18-94
Commission No. CC003229

