

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9303080002      DOC. DATE: 93/03/04      NOTARIZED: YES      DOCKET # 05000335  
FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.  
AUTH. NAME      AUTHOR AFFILIATION  
SAGER, D.A.      Florida Power & Light Co.  
RECIP. NAME      RECIPIENT AFFILIATION  
                         Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-67, excluding penetrations inside containment from 31-day surveillance requirement of TS 4.6.1.1.a.1 per NUREG-1432 (STS for C-E plants).

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3+10  
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	L	ENCL	ID	CODE/NAME	L	ENCL
	PD2-2	LA	1	1	PD2-2	PD	1	1
	NORRIS,	J	2	2				
INTERNAL:	ACRS		6	6	NRR/DE/EELB		1	1
	NRR/DORS/OTSB		1	1	NRR/DRCH/HICB		1	1
	NRR/DSSA/SCSB		1	1	NRR/DSSA/SPLB		1	1
	NRR/DSSA/SRXB		1	1	NUDOCS-ABSTRACT		1	1
	OC/LEMB		1	0	OGC/HDS3		1	0
	<u>REG FILE</u>	01	1	1				
EXTERNAL:	NRC PDR		1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 20



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32

33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

101  
102  
103  
104  
105  
106  
107  
108  
109  
110  
111  
112  
113  
114  
115  
116  
117  
118  
119  
120  
121  
122  
123  
124  
125  
126  
127  
128  
129  
130  
131  
132

133  
134  
135  
136  
137  
138  
139  
140  
141  
142  
143  
144  
145  
146  
147  
148  
149  
150  
151  
152  
153  
154  
155  
156  
157  
158  
159  
160  
161  
162  
163  
164  
165  
166  
167  
168  
169  
170  
171  
172  
173  
174  
175  
176  
177  
178  
179  
180  
181  
182  
183  
184  
185  
186  
187  
188  
189  
190  
191  
192  
193  
194  
195  
196  
197  
198  
199  
200



March 4, 1993

L-93-055  
10 CFR 50.90

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

RE: St. Lucie Unit 1  
Docket No. 50-335  
Proposed License Amendment  
St. Lucie Unit 1 Containment  
Penetrations Surveillance Requirement

Pursuant to 10 CFR 50.90, Florida Power & Light Company (FPL) requests to amend Facility Operating License DPR-67 for St. Lucie Unit 1. The proposed amendment excludes penetrations inside containment from the 31 day surveillance requirement of Technical Specification (TS) 4.6.1.1.a.1. and is consistent with similar provisions contained in NUREG-1432, Standard Technical Specifications for Combustion Engineering Plants.

It is further requested that the proposed amendment be issued in time for Unit 1, Cycle 12 startup which is scheduled for May 23, 1993. Circumstances surrounding the prompt nature of this request are documented in USNRC letter to FPL dated February 16, 1993, Subject: St. Lucie Unit 1 - Temporary Waiver of Compliance.

Attachment 1 contains a copy of the appropriate TS page marked-up to show the proposed change. Attachment 2 is a Safety Analysis in support of the proposed amendment. Attachment 3 is the "Determination of No Significant Hazards Consideration."

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b)(1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,

*DA Sager*  
D. A. Sager  
Vice President  
St. Lucie Plant

050071

9303080002 930304  
PDR ADDCK 05000335  
P PDR



*ADD 1/1*

020071

St. Lucie Unit 1  
Docket No. 50-335  
Proposed License Amendment  
St. Lucie Unit 1 Containment  
Penetrations Surveillance Requirement

STATE OF FLORIDA            )  
  )  
COUNTY OF ST. LUCIE        )            SS.

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.


D.A. Sager  
D. A. Sager

STATE OF FLORIDA  
COUNTY OF St. Lucie

The foregoing instrument was acknowledged before me this 4<sup>th</sup> day of March, 1993 by D.A. Sager, who is personally known to me and who did take an oath.

Karen West  
KAREN WEST  
Name of Notary Public  
My Commission expires 4-18-94  
Commission No. CC003229

KAREN WEST  
Notary Public-State of Florida  
My Commission Expires APR 18, 1994  
COMM # CC 003229



St. Lucie Unit 1  
Docket No. 50-335  
Proposed License Amendment  
St. Lucie Unit 1 Containment  
Penetrations Surveillance Requirement

DAS/RLD/kw  
DAS/PSL #874-93

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, St. Lucie Plant.  
Mr. W.A. Passeti, Florida Department of Health and  
Rehabilitative Services.