

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9305280316 DOC. DATE: 93/05/20 NOTARIZED: YES DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 SAGER, D.A. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-67 & NPF-16,
 changing surveillance interval specified for performing air
 or smoke flow test through containment spray headers from 5
 to 10 yrs.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+10
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD2-2 LA	1 1	PD2-2 PD	1 1	
	NORRIS, J	2 2			
INTERNAL:	ACRS	6 6	NRR/DE/EELB	1 1	
	NRR/DORS/OTSB	1 1	NRR/DRCH/HICB	1 1	
	NRR/DSSA/SCSB	1 0	NRR/DSSA/SPLB	1 1	
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1	
	OC/LEMB	1 0	OGC/HDS3	1 0	
	<u>REG FILE</u> 01	1 1			
EXTERNAL:	NRC PDR	1 1	NSIC	1 1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 19

R
I
D
S
/
A
D
D
S
/
A
D
D
S



May 20, 1993

L-93-122
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Unit 1 and Unit 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Containment Spray System
Surveillance Requirements


Pursuant to 10 CFR 50.90, Florida Power & Light Company (FPL) requests to amend Facility Operating Licenses DPR-67 and NPF-16 for St. Lucie Unit 1 and Unit 2, respectively. The proposed amendments will change the surveillance interval specified for performing an air or smoke flow test through the Containment Spray headers from 5 years to 10 years. The proposed surveillance interval is consistent with NUREG-1432, "Standard Technical Specifications for Combustion Engineering Plants" and staff recommendations contained in NUREG-1366, "Improvements to Technical Specifications Surveillance Requirements". Approval of the proposed amendments is requested by December 31, 1993.

Attachments 1 and 2 contain copies of the appropriate TS pages marked-up to show the proposed changes. Attachment 3 is an evaluation of the proposed TS changes. Attachment 4 is the "Determination of No Significant Hazards Consideration."

The proposed amendments have been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b) (1), copies of the proposed amendments are being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,


D. A. Sager
Vice President
St. Lucie Plant

DAS/RLD/kw
DAS/PSL #924-93

Attachments

260045

9305280316 930520
PDR ADOCK 05000335
P PDR

an FPL Group company

ADD 11



10000

10000

St. Lucie Unit 1 and Unit 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Containment Spray System
Surveillance Requirements

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC.

Senior Resident Inspector, USNRC, St. Lucie Plant.

Mr. W.A. Passetti, Florida Department of Health and
Rehabilitative Services.

St. Lucie Unit 1 and Unit 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Containment Spray System
Surveillance Requirements

STATE OF FLORIDA)
)
COUNTY OF ST. LUCIE) SS.

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.

D. A. Sager
D. A. Sager

STATE OF FLORIDA
COUNTY OF ST. LUCIE

The foregoing instrument was acknowledged before

me, this 20th day of May, 1993
by D.A. Sager, who is personally known to me
and who did take an oath.

Karen West

KAREN WEST
Name of Notary Public

My Commission expires 4-18-94

Commission No. CC003229

