

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9308300106 DOC. DATE: 93/08/23 NOTARIZED: YES DOCKET # 05000389
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME: SAGER, D.A. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIPIENT NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to license NPF-16, deleting option of using movable incore detector to determine incore instrumentation sys operability from TS 3.3.3.2.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+9
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD2-2 LA	1	1		
	NORRIS, J	2	2		
INTERNAL:	ACRS	6	6		
	NRR/DORS/OTSB	1	1		
	NRR/DRPW	1	1		
	NRR/DSSA/SRXB	1	1		
	OC/LFDCB	1	0		
	<u>REG FILE</u> 01	1	1		
EXTERNAL:	NRC PDR	1	1		
	NSIC			1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 20

AA2



Vertical text on the right edge of the page, appearing as a dense column of small, illegible characters or noise.



August 23, 1993

L-93-183
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Unit 2
Docket No. 50-389
Proposed License Amendment
Deletion of Movable Incore Detector
Option from Technical Specifications

Pursuant to 10 CFR 50.90, Florida Power & Light Company (FPL) requests to amend Facility Operating License NPF-16 for St. Lucie Unit 2. The proposed amendment will delete the option of using a movable incore detector to determine Incore Instrumentation System operability from the provisions of Technical Specification (TS) 3.3.3.2. FPL considers that the burden of maintaining the redundant movable detector system as an option is not justified by any safety significance. Approval of the proposed amendment is requested by February 20, 1994, to support permanent removal of the movable incore detector equipment during the next scheduled refueling outage.

Attachment 1 contains a copy of the appropriate TS page marked-up to show the proposed change. Attachment 2 is an evaluation of the proposed TS change. Attachment 3 is the "Determination of No Significant Hazards Consideration."

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b)(1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,

DA Sager
D. A. Sager
Vice President
St. Lucie Plant

DAS/RLD/kw
DAS/PSL #970-93

Attachments

9308300106 930823
PDR ADCK 05000389
PDR

270021



Aool
11

St. Lucie Unit 2
Docket No. 50-389
Proposed License Amendment
Deletion of Movable Incore Detector
Option from Technical Specifications

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC.

Senior Resident Inspector, USNRC, St. Lucie Plant.

Mr. W.A. Passetti, Florida Department of Health and
Rehabilitative Services.

St. Lucie Unit 2
Docket No. 50-389
Proposed License Amendment
Deletion of Movable Incore Detector
Option from Technical Specifications

STATE OF FLORIDA)
)
COUNTY OF ST. LUCIE) ss.

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.

DA Sager
D. A. Sager


STATE OF FLORIDA
COUNTY OF St. Lucie

The foregoing instrument was acknowledged before me this 23rd day of August, 19 93 by D.A. Sager, who is personally known to me and who did take an oath.

Alexis R. Molenda
Alexis R. Molenda
Name of Notary Public

My Commission expires 10-29-95

Commission No. CC 156175



100-55-1

100-55-1