

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9311010098 DOC. DATE: 93/10/25 NOTARIZED: YES DOCKET #
FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
" 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
AUTH. NAME AUTHOR AFFILIATION
SAGAR, D.A. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-67 & NPF-16. removing surveillance requirements re dune & mangrove surveys from Tech Specs.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+17
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL	ID	CODE/NAME	LTR	ENCL
	PD2-2	LA	1	1	PD2-2	PD	1	1
	NORRIS,	J	2	2				
INTERNAL:	ACRS		6	6	NRR/DE/EELB		1	1
	NRR/DORS/OTSB		1	1	NRR/DRCH/HICB		1	1
	NRR/DSSA/SPLB		1	1	NRR/DSSA/SRXB		1	1
	NUDOCS-ABSTRACT		1	1	OC/LEDGB		1	0
	OGC/HDS3		1	0	<u>REG FILE</u>	01	1	1
EXTERNAL:	NRC	PDR	1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 19

R
I
D
S
/
A
D
D
S
/
A
D
D
S

AA-2
JJP



October 25, 1993

L-93-274
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: St. Lucie Units 1 & 2
Docket Nos. 50-335 & 50-389
Proposed License Amendments
Flood Protection

Pursuant to 10 CFR 50.90, Florida Power and Light Company (FPL) requests to amend Facility Operating Licenses DPR-67 and NPF-16 for St. Lucie Units 1 and 2. Changes to Technical Specification Limiting Conditions for Operation 3.7.6.1 for St. Lucie 1 and 2 and associated bases, design feature 5.1.3 for St. Lucie 1, and indexes are forwarded herewith. The safety analysis supporting this proposal is also provided. Review of this proposal is requested by May 1, 1994.

The purpose of this change is to remove surveillance requirements related to dune and mangrove surveys from the Technical Specifications. It is considered that inherent design features provide conservative protection for safety-related equipment. The burden of performing these surveillances is not warranted in light of the low nuclear safety significance of the dunes and mangroves.

Attachment 1 and 2 contains marked-up Technical Specification pages for St. Lucie 1 and 2, respectively. Attachment 3 is the Safety Analysis in support of this proposed amendment. Attachment 4 is the "Determination of No Significant Hazards Consideration."

010012

9311010098 931025
PDR ADOCK 05000335
P PDR

an FPL Group company

Adol
11




0300.0

St. Lucie Units 1 and 2
Docket Nos. 50-335 & 50-389
Proposed License Amendments
Flood Protection

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b) (1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,


D. A. Sager
Vice President
St. Lucie Plant

DAS/LLM/kw
DAS/PSL #1009-93

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant
Mr. W. A. Passetti, Florida Department of Health and
Rehabilitative Services.


St. Lucie Units 1 and 2
Docket Nos. 50-335 & 50-389
Proposed License Amendments
Flood Protection

STATE OF FLORIDA)
)
COUNTY OF ST. LUCIE) SS.

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licenses herein;


That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.



D. A. Sager

STATE OF FLORIDA
COUNTY OF ST. LUCIE


The foregoing instrument was acknowledged before me this 25th day of October, 1993 by D. A. Sager, who is personally known to me and who did take an oath.



KAREN WEST
Name of Notary Public

My Commission Expires 4-18-94

Commission No. CC 003229



COMMERCIAL
W. CONN. 1954
KAD 1111