

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403080319      DOC. DATE: 94/02/22      NOTARIZED: YES      DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.      05000335  
       50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389  
 AUTH. NAME      AUTHOR AFFILIATION  
 SAGER, D.A.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                   Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to licenses DPR-67 & NPF-16, proposing changes to TS, by relocating tables of instrument response time limits (GL-93-08).

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3+21  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-2 LA		1	1		PD2-2 PD		1	1
	NORRIS, J		2	2					
INTERNAL:	ACRS		6	6		NRR/DE/EELB		1	1
	NRR/DORS/OTSB		1	1		NRR/DRCH/HICB		1	1
	NRR/DRPW		1	1		NRR/DSSA/SPLB		1	1
	NRR/DSSA/SRXB		1	1		NUDOCS-ABSTRACT		1	1
	OC/LEDCB		1	0		OGC/HDS3		1	0
	<u>REG FILE</u> 01		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 20

R  
I  
D  
S  
/  
A  
D  
D  
S

AA-2



February 22, 1994

L-94-031  
10 CFR 50.90

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

RE: St. Lucie Unit 1 and Unit 2  
Docket Nos. 50-335 and 50-389  
Proposed License Amendments  
Relocation of Tables of Instrument  
Response Time Limits (GL 93-08)

Pursuant to 10 CFR 50.90, Florida Power & Light Company (FPL) requests to amend Facility Operating Licenses DPR-67 and NPF-16 for St. Lucie Unit 1 and Unit 2, respectively. The proposed amendments will relocate the instrument response time limits for the Reactor Protective System and Engineered Safety Features Actuation System from the Technical Specifications (TS) to the Updated Safety Analysis Report for both units. The proposed changes are line-item TS improvements and conform to the guidance given in Enclosures 1 and 2 of USNRC Generic Letter 93-08. Approval is requested by August 31, 1994.

Attachments 1 and 2 contain copies of the appropriate TS pages marked-up to show the proposed changes. Attachment 3 is an evaluation of the proposed TS changes. Attachment 4 is the "Determination of No Significant Hazards Consideration."

The proposed amendments have been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board. In accordance with 10 CFR 50.91 (b) (1), copies of the proposed amendments are being forwarded to the State Designee for the State of Florida.

Please contact us if there are any questions about this submittal.

Very truly yours,

D. A. Sager  
Vice President  
St. Lucie Plant

DAS/RLD/kw  
DAS/PSL #1066-94

Attachments

280006

ADD 11



806088

1954

St. Lucie Unit 1 and Unit 2  
Docket Nos. 50-335 and 50-389  
Proposed License Amendments  
Relocation of Tables of Instrument  
Response Time Limits (GL 93-08)

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC.

Senior Resident Inspector, USNRC, St. Lucie Plant.

Mr. W.A. Passetti, Florida Department of Health and  
Rehabilitative Services.

St. Lucie Unit 1 and Unit 2  
Docket Nos. 50-335 and 50-389  
Proposed License Amendments  
Relocation of Tables of Instrument  
Response Time Limits (GL 93-08)

STATE OF FLORIDA            )  
  )            ss.  
COUNTY OF ST. LUCIE    )

D. A. Sager being first duly sworn, deposes and says:

That he is Vice President, St. Lucie Plant for the Nuclear Division of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.

*D. A. Sager*  
D. A. Sager

STATE OF FLORIDA  
COUNTY OF ST. LUCIE

The foregoing instrument was acknowledged before me this 22nd day of February, 1994 by D.A. Sager, who is personally known to me and who did take an oath.

*Karen West*

KAREN WEST  
Name of Notary Public

My Commission expires 4-18-94

Commission No. CC003229



KAREN WOOD  
Notary Public - State of Texas  
My Comm. Expires 12/18/2024  
COMM # CC 000282