

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9408250250 DOC. DATE: 94/08/18 NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 SAGER, D.A. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Notifies that actions items 1.a, 1.b, 1.c, 1.d & 1.f completed, per w/schedules in attachment to ltr L-93-61, in response to NRC Bulletin 90-001, Suppl 1.

DISTRIBUTION CODE: IE39D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: NRC Bulletin 90-001, Loss of Fill Oil in Transmitters Mfg by Rosemount

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-2 PD		1	1		NORRIS, J		1	1
INTERNAL:	NRR/DRPW/OGCB		1	1		NRR/HICB		2	2
	NRR/OEAB		2	2		NRR/PDII-1		1	1
	<u>REG FILE</u> 02		1	1		RES/EMEB		1	1
	RGN2 FILE 01		1	1					
EXTERNAL:	NOAC		1	1		NRC PDR		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 13 ENCL 1

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



August 18, 1994

L-94-210
10 CFR 50.4

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Units 1 and 2
Docket No. 50-335 and 50-389
NRC Bulletin 90-01 Supplement 1
Additional Information

Florida Power and Light Company (FPL) provided a response to NRC Bulletin (NRCB) 90-01, Supplement 1, on March 5, 1993 (L-93-61) and supplemented this response on March 4, 1994 (L-94-61). In response to item 2.b. of the NRCB, FPL provided a schedule for replacement and monitoring the affected transmitters. This letter provides notification that action items 1.a, 1.b, 1.c, 1.d, and 1.f were completed in accordance with the schedules in the attachment to FPL Letter L-93-61.

The schedule for action item 1.e is dependent on the individual transmitter, when it was installed and its pressure history. As transmitters in this category meet the conditions specified in the response to action item 1.e, they may be removed from the enhanced surveillance program. It is currently estimated that all the transmitters this category will not reach time-pressure maturity until approximately January 1996.

Please contact us if there are any questions about this submittal.

Very truly yours,

D. A. Sager
Vice President
St. Lucie Plant

DAS/GRM/kw

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant

DAS/PSL #1189-94

240074

9408250250 940818
PDR ADCK 05000335
Q PDR

an FPL Group company

IE 39
/10