



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 130

TO FACILITY OPERATING LICENSE NO. DPR-67

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT, UNIT NO. 1

DOCKET NO. 50-335

1.0 INTRODUCTION

By letter dated March 19, 1993 (Reference 1), and supplement dated August 18, 1994, Florida Power and Light (FPL) the licensee for St. Lucie Power Plant (PSL1), proposed changes to the Technical Specifications (TS) for the Unit 1 facility. The supplemental information did not change the initial no significant hazards consideration determination. Specifically, the proposed changes are to TS figure 2.1-1, Tables 2.2-1 and 3.2-1 and the associated TS Bases pages B2-1 and B2-2. These changes are related to reducing the reactor coolant system (RCS) minimum design flow to remove core thermal power from 370,000 gpm to 355,000 gpm to accommodate future steam generator tube plugging (SGTP) beyond the current 15% to up to 25%.

2.0 EVALUATION

The licensee determined that the proposed changes could affect the plant safety analysis in three major ways. First, the reduction in the reactor flow rate can impact the calculated Departure from Nucleate Boiling Ratio (DNBR) for some transients. If Departure from Nucleate Boiling (DNB) occurs, the thermal margin (TM) for the corresponding transient is also reduced. Second, the removal of additional SG tubes from service reduces the primary to secondary heat transfer area in the steam generators. And finally, a reduction in RCS flowrate results in a corresponding increase in RCS average coolant temperature ( $T_{ave}$ ) which can impact both DNBR-related and loss of primary inventory types of events.

FPL reviewed the events described in their Updated Final Safety Analysis Report, for PSL1, to assess the impact of increasing the SGTP to 25% and reducing the flow rate to 355,000 gpm. The transient events were divided into three categories: (1) reanalysis required, (2) reanalysis not required, and (3) other analyses affected by the flow reduction.

## 2.1 Transient Events Requiring Reanalysis

The transients that required reanalysis were Loss of External Load, 4-Pump Loss of Reactor Coolant Flow, Seized RCP Rotor, Dropped Control Element Assembly (CEA), and Large and Small Break LOCAs.

### 2.1.1 Loss of External Load (LOEL)

Loss of external load is the limiting event in the Decrease in Heat Removal by the Secondary System class of events. This event can be impacted by the proposed change in two ways - challenging the DNBR acceptance criteria and the maximum calculated RCS pressure.

Increasing the SGTP and reducing the initial RCS flow will tend to reduce the calculated Minimum Departure from Nucleate Boiling Ratio (MDNBR) for DNB-related events and FPL has concluded, by its reanalysis, that the LOEL event still remains acceptable with respect to DNBR.

The licensee reanalyzed the event to determine the impact on the RCS pressure. This analysis resulted in a peak RCS pressure of 2701 psia, which is within the American Society of Mechanical Engineers (ASME) Code acceptance criteria of 2750 psia. The secondary steam pressure was calculated to be 1022 psia, within the acceptance criteria of 1100 psia.

### 2.1.2 Decrease in RCS Flow

Two events that result in reduced RCS flow were reanalyzed - Loss of Reactor Coolant Flow (4 Pump Coastdown) and Locked Rotor.

The Loss of Flow (LOF) event is the limiting Anticipated Operational Occurrence (AOO) for MDNBR for this category of transients. The licensee reanalyzed this event using NRC approved methods. The analysis included the event cases with and without the proposed design flow and allowable core power as a function of Axial Shape Index (ASI). The current margin to the acceptance criteria is 12%. The licensee indicated that the proposed changes reduce the margin less than 0.5%.

The locked rotor event was not reanalyzed. Instead, a set of conservative boundary conditions was assumed using the original system calculation as a basis to perform an evaluation. Their analytical approach for locked rotor events is part of the same reload methodology that has been used to evaluate previous operating cycles with Siemens fuel at St. Lucie. The staff, therefore, finds that the approach continues to be applicable for this evaluation.

The proposed rated RCS flow of 355,000 gpm, with an uncertainty of  $\pm 14,000$  gpm, was used in the evaluation. The licensee predicted that 1% of the fuel rods will experience DNB. This value remains bounded by the licensing basis radiological consequences analysis assumption of 2.5%.

### 2.1.3 Dropped Control Element Assembly

The dropped CEA is an AOO that ultimately affects the DNBR by changing the radial core power distribution. This event was reanalyzed using the same NRC approved methods that are used for refueling analysis incorporating the proposed RCS design flow and allowable values of core power as a function of ASI.

The licensee indicated that the reanalysis resulted in a conservative margin of more than 13% to the limiting acceptance criterion of MDNBR 1.22. Therefore, the licensee concluded that the proposed changes would not violate the specified acceptable fuel design limit for DNBR.

### 2.1.4 Loss-of-Coolant Accident Analyses

In submittals of March 19, 1993, and August 18, 1994, the licensee provided the results of loss-of-coolant accident (LOCA) analyses in support of the proposed St. Lucie Unit 1 reduction in RCS design flow license amendment. These analyses were performed using Siemens Power Corporation approved large break (LB) and small break (SB) LOCA evaluation models (EM).

#### Large Break LOCA

In the March 19, 1993 submittal, the licensee provided the results of LB LOCA analyses, performed using the Siemens LB LOCA EM as approved by the NRC on July 8, 1986 (Reference 3). The analyses were performed to account for the St. Lucie Unit 1 plant design with average steam generator tube plugging of 25%, with as much as 32% plugging in either steam generator.

The licensee has indicated that calculations support its conclusion that the limiting type and location of large breaks continues to be a double-ended cold leg guillotine (DECLG) rupture. These calculations also confirmed that the limiting coefficient of discharge ( $C_d$ ) continues to be 0.8. The limiting case assumes a loss of offsite power and the failure of one low pressure safety injection pump. Additional details of the analyses are given in EMF-92-165 (Reference 2), February 9, 1993.

In addition to the assumptions identified above, this case also assumed 102 percent of the St. Lucie 1 rated power level of 2700 MWt, an RCS rated design flow of 355,000 gpm, and peaking factors as specified in the St. Lucie Core Operating Limits report.

The calculated peak cladding temperature is 1912°F, the calculated maximum local metal/water reaction is less than 3.0%, and the calculated core-wide metal/water reaction is less than 1%. These results are within the criteria specified in 10 CFR 50.46(b) (1 through 3) of 2200°F, 17%, and 1%, respectively. The results assure that the core will remain amenable to cooling as required by 10 CFR 50.46(b)(4). The licensee reported that the



Handwritten marks and characters in the top right corner, including a cluster of small characters and a few scattered dots.

time of Emergency Core Cooling System (ECCS) hot leg switchover was determined by analysis to be within 8 hours. This, combined with the St. Lucie ECCS design as approved, assures continued conformance with the long-term cooling requirement of 10 CFR 50.46(b)(5).

### SBLOCA Analyses

In an August 18, 1994, submittal the licensee provided the results of a limited spectrum of SBLOCA reanalyses which were performed to account for the St. Lucie Unit 1 plant design with average steam generator tube plugging of 25%, and as much as 32% plugging in either steam generator. The reanalyses were performed using the Siemens SBLOCA Evaluation Model described in XN-NF-82-49, Revision 1, Supplement 1 which has been approved by the NRC (October 3, 1994) for licensing applications and is applicable to the St. Lucie plant.

The licensee has referenced previous studies to support its conclusion that the limiting location of small break continues to be a cold leg rupture. A crossflow sensitivity study was performed to identify the worst crossflow, but a time step sensitivity study was not performed since none of the criteria specified in the NRC October 3, 1994, Safety Evaluation (Reference 4) requiring the study were calculated to occur. The licensee provided the following sensitivity/spectrum analysis cases to identify and quantify the worst case:

- a. 0.05 ft<sup>2</sup> cold leg,
- b. 0.10 ft<sup>2</sup> cold leg,
- c. 0.15 ft<sup>2</sup> cold leg, and
- d. 0.20 ft<sup>2</sup> cold leg.

### Results of Licensing Basis SBLOCA Analysis

The 0.1 ft<sup>2</sup> case above was identified as the worst SBLOCA case. In addition to the assumptions identified above, this case also assumed 102 percent of a core power level of 2700 MWt, an RCS flow of 355,000 gpm, and peaking factors as specified in the St. Lucie Core Operating Limits report.

The calculated peak cladding temperature is 1846°F, the calculated maximum local metal/water reaction is less than 2.0%, and the calculated core-wide metal/water reaction is less than 1%. These results are within the criteria specified in 10 CFR 50.46(b) (1 through 3) of 2200°F, 17%, and 1%, respectively. The results assure that the core will remain amenable to cooling as required by 10 CFR 50.46(b)(4).

The St. Lucie ECCS design, as approved, assures continued conformance with the long-term cooling requirement of 10 CFR 50.46(b)(5). The results of the analyses of the limiting 0.1 ft<sup>2</sup> SBLOCA are bounded by the results for the limiting LBLOCA.

## LOCA Analysis Conclusions

St. Lucie Unit 1 LOCA analyses provided by the licensee in support of the St. Lucie increased steam generator plugging/reduced RCS flow were performed with NRC-approved evaluation models and identify a double-ended cold leg guillotine cold leg break with a discharge coefficient of 0.8, with loss of offsite power and failure of one low pressure safety injection pump, as the limiting LOCA event. The results of the analysis of this event demonstrate conformance with the criteria specified in 10 CFR 50.46(b) and, therefore, the analyses are acceptable.

### 2.2 Transient Events Not Requiring Reanalysis

Although the following events were not reanalyzed, they were evaluated by the licensee to determine the impact due to the proposed changes. The Uncontrolled CEA Withdrawal event, Inadvertent Opening of Pressurizer Pressure Relief Valves event, and the excess load event - Inadvertent Opening of the Steam Dump and Bypass Control System Valves at Full Power - all remain bounded by the 4 pump LOF event for DNB considerations.

The existing TM/low pressure Trip, the Variable High Power Trip (VHPT), and the Local Power Density Trip Limiting Safety System Settings provide protection against boron dilution events initiated at power. During Modes 2 - 5, the licensee concluded that the calculated times to lose the required shutdown margin is sufficient to accommodate the impact from the proposed changes.

The CEA Ejection Accident, which is a mechanical failure of a control rod drive mechanism pressure housing, results in the rapid reactivity insertion and adverse core power distribution, leading to possible core damage. Since the proposed changes do not impact the nuclear characteristics of the reactor core, the licensee concluded that the existing analysis remains valid.

The proposed changes would reduce the primary to secondary heat transfer rate across the steam generators and lower the initial secondary pressure. The licensee indicated that these changes would, in fact, reduce the effects of steamline break inside and outside of containment and the radiological consequences of inadvertent opening of a steam generator relief or safety valve. Therefore, the current analyses for these events remain valid.

### 2.3 Other Considerations Evaluated by the Licensee

The licensee also considered the impact of the amendment request on the following non-Chapter 15 analyses:

- a. Plant Natural Circulation Capability,
- b. Auxiliary Feedwater System High Energy Line Break,
- c. Low Temperature Overpressure Protection Analysis,
- d. Overpressure Protection Analysis, and
- e. Impact on Steam Generator Mechanical Loads.

Based on its evaluation, the licensee determined that the reduced flow rate will not significantly impact the acceptance criteria of the analyses listed above.

### 3.0 CONCLUSION

The staff has reviewed the licensee's proposal to decrease the RCS flow rate. The proposed changes were included in the reanalyses and evaluation of the applicable Chapter 15 UFSAR transient analyses. Since the reanalyses and evaluations were performed using staff approved methods and the licensee indicated that the results remain within the applicable acceptance criteria, the staff approves the reduction in RCS flow rate to 355,000 gpm.

### 4.0 REFERENCES

1. Letter from D. A. Sager, FPL to USNRC, "St Lucie Unit 1 Reduction of Reactor Coolant System Design Flow," dated March 19, 1993.
2. EMF-92-165, Siemens Power Corporation, "St. Lucie Unit 1 Chapter 15 Event Review and Analysis for 25% Steam Generator Tube Plugging," dated February 9, 1993.
3. Letter from D. M. Crutchfield (NRC) to G. M. Ward (Siemens Power Corporation), "Safety Evaluation of EXXON Nuclear Company Large Break ECCS Evaluation Model," dated July 8, 1986.
4. Letter from G. M. Holahan (NRC) to R. A. Copeland (Siemens Power Corporation), "Acceptance for Referencing of the Topical Report XN-NF-82-49-P Revision 1, Supplement 1, 'EXXON Nuclear Company Evaluation Model Revised EXEM PWR Small Break Model,' (TAC NO. M83302)," dated October 3, 1994.

### 5.0 STATE CONSULTATION

Based upon the written notice of the proposed amendments, the Florida State official had no comments.

### 6.0 ENVIRONMENTAL CONSIDERATION

These amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration and there has been no public comment on such finding (58 FR 25855). Accordingly, these amendments

meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

#### 7.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: F. Orr  
S. Brewer

Date: November 25, 1994



2000



1000

1000