

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9507100383 DOC. DATE: 95/07/07 NOTARIZED: NO DOCKET #
FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
AUTH. NAME AUTHOR AFFILIATION
SAGER, D.A. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards info requested by NRC 950609 ltr to support NRC approval of util evaluation of flaw indications & subsequent ISI plans submitted by util 950302 ltr.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 7
TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04


NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	PD2-1 LA NORRIS, J	1	1	PD2-1 PD	1	1
INTERNAL:	ACRS	6	6	AEOD/SPD/RAB	1	1
	ELLE-CENTER 01	1	1	NRR/DE/EMCB	1	1
	NRR/DE/EMEB	1	1	NUDOCS-ABSTRACT	1	1
	OGC/HDS3	1	0	RES/DSIR/EIB	1	1
EXTERNAL:	LITCO ANDERSON	1	1	LITCO RANSOME, C	1	1
	NOAC	1	1	NRC PDR	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 20 ENCL 19





July 7, 1995

L-95-185
10 CFR 50.4
10 CFR 50.55a

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Unit 2
Docket No. 50-389
In-Service-Inspection Plan
Second Ten-Year Interval
Request for Additional Information
Fracture Mechanics Evaluation
Pressurizer Instrument Nozzles - Response

By letter dated June 9, 1995, NRC requested additional information (RAI) to support the Staff's approval of the Florida Power and Light Company (FPL) evaluation of flaw indications and subsequent in-service inspection (ISI) plans submitted by FPL letter L-95-74 on March 2, 1995. FPL requested the approval by July 1, 1995, to support planning for the Fall 1995 Unit 2 refueling outage. Your letter requested a response to the RAI within 30 days of receipt (June 15, 1995).

The initial flaw evaluation, prepared according to ASME Section XI, Appendix A, justified operation for at least one cycle. It was submitted to the NRC, the authority having jurisdiction, by FPL letter L-94-72 on March 28, 1994. NRC approval was documented in your letters dated April 1, 1994, and April 5, 1994.

The information you requested is attached. Please contact us should you need any additional clarifications.

Very truly yours,

C. L. Burton for
D. A. Sager
Vice President
St. Lucie Plant

DAS/GRM

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant

110040

9507100383 950707
PDR ADDCK 05000389
Q PDR

AD47



THE UNIVERSITY OF CHICAGO
LIBRARY

St. Lucie Unit 2
Docket No. 50-389
In-Service-Inspection Plan
Second Ten-Year Interval
Request for Additional Information
Fracture Mechanics Evaluation
Pressurizer Instrument Nozzles - Response

ATTACHMENT

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

FPL Letter L-95-74 Attachment A Questions

Attachment A: Fracture Mechanics Evaluation of St. Lucie Pressurizer Instrument Nozzles, Proprietary Version, BWNT Document 32-1235128-00.

NRC Question 1

1.1 Assumptions, Page 4 - The upper shelf value for K_{IR} assumed for the nozzle material exceeds the limit of $200 \text{ ksi}\sqrt{\text{in}}$ for the K_{IR} vs. $(T - RT_{NDT})$ curve. Very few data test data exist beyond that limit. Revise the evaluation by using the value of $200 \text{ ksi}\sqrt{\text{in}}$, or provide data to justify the K_{IR} value used in the submittal.

FPL Response

This evaluation utilized an upper shelf fracture toughness value of $250 \text{ ksi}\sqrt{\text{in}}$ for the SA-533 Grade B, Class 1 material. Some of the industry data supports this upper shelf toughness value for ductile materials, however, these nozzles were re-evaluated using $200 \text{ ksi}\sqrt{\text{in}}$ value since Charpy upper shelf energy value for this particular SA 533 material could not be determined. The results of the re-analysis using the upper shelf toughness value of $200 \text{ ksi}\sqrt{\text{in}}$ indicate that all the instrument nozzles in the spherical shell are acceptable by ASME Section XI code rules.

FPL Letter L-95-74 Attachment B Questions

Attachment B: Stresses for St. Lucie Unit 2 Pressurizer LEFM, Proprietary Version, BWNT Document 32-1235127-00.

NRC Question 1

Assumptions, page 4 - Provide an estimation of the effect of thermal stratification.

FPL Response

Delete Assumption #5 on page 4 of the subject document (therefore, will not be contained in Revision 02 of the document).

NRC Question 2

Model Geometry, page 8 - To cover the stress concentration caused by nozzle insertion into the pressurizer wall, the radius of the modeled head was set to 2.5 times the actual radius. Revise the computer simulation by using models with the actual radius, then applying the concentration factors, or demonstrate that the thermal stresses due to transients would increase in proportion to the radius of the pressurizer head as the case for internal pressure.



••
••
•

•
•

[Faint, illegible text]

[Faint, illegible text]

[Faint, illegible text]

FPL Response

(i) Stress Concentrations

For radial nozzle penetrations in spherical and cylindrical shells of large radius which are subjected to a through-wall temperature gradient, the appropriate stress concentration factor (SCF) for the penetration is that of a flat plate with a circular hole subjected to a biaxial stress state (SCF=2.0). As noted in paragraph (ii), the thermal stresses in the modeled sphere are not significantly affected by the radius. Therefore, modeling a cylinder of radius R with a radial nozzle penetration as a sphere of radius 2.5R (to account for the 2.5 SCF on hoop stresses due to internal pressure loading) results in accurate maximum pressure and thermal hoop stresses at the penetration.

For nonradial nozzle penetrations in spherical shells, the stress concentration on hoop stress at the nozzle penetration for internal pressure loading is given by the following equation from NB-3338.2 of Reference [4]

$$K_2 = K_1(1 + 2\sin^2\phi)$$

where:

- K_1 - inside stress index for radial nozzle penetration, $K_1 = 2$
- K_2 - inside stress index for nonradial penetration
- ϕ - angle between the nonradial penetration and the shell normal

The stress concentration on hoop stress at a nonradial nozzle penetration in a sphere (of large radius) subjected to a through-wall temperature gradient is that of an elliptical hole in a flat plate subjected to a biaxial stress state. Therefore, modeling a sphere of radius R with a nonradial nozzle penetration as a sphere of radius $(1 + 2\sin^2\phi)R$ with a radial nozzle penetration results in accurate maximum hoop stresses for internal pressure loading. However, the maximum thermal hoop stresses due to a through-wall temperature gradient in the subject model will only reflect an SCF of 2.0 for the radial nozzle penetration. Therefore, Revision 02 of the subject document will include an additional 1.2 factor on thermal hoop stresses to fully account for the appropriate stress concentration (SCF=2.4) at the nonradial penetration. The 2.4 SCF is based on Figure 133 in Reference [5] for stress concentrations at an elliptical hole (with major diameter/minor diameter ratio = 1.2 for the subject St. Lucie nozzle penetrations) in a flat plate subjected to a biaxial stress state.

(ii) Effect of Radius on Thermal Stresses

For transient conditions with thermal gradients in the shell, the thermal stresses in the shell are primarily a function of the thickness of the shell and not the radius of the shell. Therefore, modeling the shell radius as the actual radius or 2.5 times the actual radius will result in essentially identical thermal stresses. The following example calculations for steady state heat flow in a sphere (for application to the spherical heads of the St. Lucie Unit 2 pressurizer) from pages 924 and 925 of Reference [2] show that the radius has negligible effect ($\Delta=3\%$) on the thermal stresses. The hoop stress is given by equation:

THE UNIVERSITY OF CHICAGO
DIVISION OF THE PHYSICAL SCIENCES
DEPARTMENT OF CHEMISTRY
5712 SOUTH DICKENS STREET
CHICAGO, ILLINOIS 60637
TEL: 773-936-3700
FAX: 773-936-3701
WWW: WWW.CHEM.UCHICAGO.EDU

$$\sigma_h = \frac{\alpha E \Delta t}{2(1-\nu)} \left(1 + \frac{2m}{3} \right)$$

where:

- α - coefficient of thermal expansion
- E - Young's Modulus
- Δt - the temperature difference across the thickness
- ν - Poisson's ratio
- m - $(R_o/R_i) - 1$
- R_o - outside radius
- R_i - inside radius

For the actual radii of R_i=48.4375" and R_o=52.3125"

$$\sigma_h = \frac{\alpha E \Delta t}{2(1-\nu)} \left(1 + \frac{2(52.3125/48.4375-1)}{3} \right) = 1.053 \left(\frac{\alpha E \Delta t}{2(1-\nu)} \right)$$

For 2.5 times the actual radii of R_i=121.094" and R_o=124.969"

$$\sigma_h = \frac{\alpha E \Delta t}{2(1-\nu)} \left(1 + \frac{2(124.969/121.094-1)}{3} \right) = 1.021 \left(\frac{\alpha E \Delta t}{2(1-\nu)} \right)$$

NRC Question 3

Finite Element Model, Pages 11 and 29 - The boundary conditions for the finite element method (FEM) model shown in Figure 6.2 are only true for an airborne sphere subjected to radially dependent structural or thermal load. Demonstrate that your simplified partial FEM model is adequate for the analyses conducted in this evaluation.

FPL Response

Zero displacement in the tangential direction (theta) of the cylindrical coordinate system is specified as the boundary condition of the partial axisymmetric model of the sphere as shown on page 29 of the subject document. This restraint in the hoop direction (remote from the hole



10
11
12

13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300

at the centerline of the axisymmetric model) prevents rigid body motion of the model. Note that the axis of the nozzle penetration is the axis of symmetry in the axisymmetric model.

Since the instrumentation nozzles are small compared to the vessel shell, the forces and moments imparted by the nozzle on the shell are insignificant and do not significantly influence the stresses in the shell or the amount of the structure that is required to be modeled. The only characteristic of the structure that affects the amount of the structure that is modeled is the hole in the shell at the nozzle penetration. A sufficient portion of the structure was modeled to attenuate the stress concentration effects at the nozzle penetration as evident in the model verification of hoop stress remote from the hole on page 38 of the subject document. The stresses 3" from the edge of the hole (4.3"sin45°) are within 1.6% of theoretical values for stresses in a sphere (without a hole) due to internal pressure and the total arc length of the model is approximately 10.5" ($R\theta = 120.5"(5°)(\pi/180°)$).

Therefore, the portion of the structure that was modeled and the boundary conditions used in the analysis are appropriate to yield accurate results for the stresses in the subject pressurizer shell.

NRC Question 4

Thermal Analysis, Pages 12 - The heat transfer coefficient (h) used for the reactor vessel is 471 Btu/Hr-Ft²-°F (SECY-82-465); the coefficient for feed water nozzle is 2000 Btu/Hr-Ft²-°F (NUREG-0619); and the number used in your first evaluation is 10,000 Btu/Hr-Ft²-°F. Revise the evaluation by using the test supported value of 2,000 Btu/Hr-Ft²-°F, or provide data to justify the heat transfer coefficient used in the submittal.

FPL Response

Heat transfer coefficients vary greatly depending on fluid parameters such as fluid type and the mode of heat transfer. Typical values of heat transfer coefficients listed in Table 2-2 of Reference [3] are shown in the following table:

Typical Heat Transfer Coefficients

Condition		h (Btu/Hr-Ft ² -°F)
Free Convection	Gases	1-5
	Water	20-150
Forced Convection	Water	50-2000
Phase Change	Boiling Liquids	500-10,000
	Condensing Vapors	1000-20,000

1948

1. The first part of the report deals with the general situation in the country. It is noted that the economy is in a state of stagnation and that the government is unable to meet its obligations. The report also mentions that the population is suffering from a severe shortage of food and that the government is unable to provide for their basic needs.

2. The second part of the report deals with the political situation. It is noted that the government is unable to carry out its policies and that the country is in a state of political instability. The report also mentions that the government is unable to maintain law and order and that the country is in a state of chaos.

3. The third part of the report deals with the social situation. It is noted that the population is suffering from a severe shortage of food and that the government is unable to provide for their basic needs. The report also mentions that the government is unable to provide for the education and health care of the population.

4. The fourth part of the report deals with the international situation. It is noted that the country is in a state of isolation and that the government is unable to maintain relations with other countries. The report also mentions that the country is unable to participate in international trade and that the economy is in a state of stagnation.

From the discussion in Section 5.0 of the subject document, the heat transfer coefficient used for the thermal analyses (461 Btu/Hr-Ft²-°F) is realistic or conservative for all nozzle locations and transients evaluated with the exception of the water space nozzles during the 53°F step-down transient and the loss of secondary pressure transient. For these fast cooling transients, a heat transfer coefficient representative of boiling should be used to conservatively determine stresses. Therefore, a heat transfer coefficient of 10,000 Btu/Hr-Ft²-°F will be used in Revision 02 of the subject document to conservatively determine the thermal gradients and resulting stresses for these fast cooling transients. For all other transients, the heat transfer coefficient of 461 Btu/Hr-Ft²-°F discussed above is appropriate and will be used in Revision 02 of the subject document.

References

- 1) BWNT 32-1235128-00, "FM Analysis of St. Lucie Pressurizer Instrument Nozzles."
- 2) Faupel, Joseph H., "Engineering Design, A Synthesis of Stress Analysis and Materials Engineering," Second Edition, Wiley-Interscience, New York, 1981.
- 3) Arpaci, Vedat S., "Conduction Heat Transfer," Addison-Wesley Publishing Co., 1966.
- 4) Section III, Subsection NB of the ASME Boiler & Pressure Vessel Code, 1986 Edition.
- 5) Peterson, R. E., "Stress Concentration Factors," Wiley-Interscience, New York, 1974.



12
11
10
9
8
7
6
5
4
3
2
1

1
2
3
4
5
6
7
8
9
10
11
12

1
2
3
4
5
6
7
8
9
10
11
12

1
2
3
4
5
6
7
8
9
10
11
12

1
2
3
4
5
6
7
8
9
10
11
12

1
2
3
4
5
6
7
8
9
10
11
12