

October 10, 1995

Florida Power and Light Company
ATTN: Mr. J. H. Goldberg
President - Nuclear Division
P. O. Box 14000
Juno Beach, FL 33408-0420

SUBJECT: PLANT PERFORMANCE REVIEW (PPR) - ST. LUCIE

Dear Mr. Goldberg:

On September 21, 1995, the NRC staff completed the semiannual Plant Performance Review (PPR) of St. Lucie. The staff conducts these reviews for all operating nuclear power plants to develop an integrated understanding of safety performance. The results are used by regional management to facilitate planning and allocation of inspection resources. The PPR for St. Lucie involved the participation of all Regional Technical Divisions and NRR in evaluating inspection results and safety performance information for the period from March 1995 to September 1995. PPRs provide regional management with a current summary of licensee performance and serve as inputs to the NRC Systematic Assessment of Licensee Performance (SALP) and senior management meeting (SMM) reviews.

This letter advises you of our planned inspection effort resulting from the St. Lucie PPR review. It is provided to minimize the resource impact on your staff and to allow for scheduling conflicts and personnel availability issues to be resolved in advance of inspector arrival onsite. The enclosure details our inspection plan for the next 6 months. The rationale or basis for each inspection outside the core inspection program is provided so that you are aware of the reason for emphasis in these program areas. Resident inspections are not listed due to their ongoing and continuous nature.

We will inform you of any changes to the inspection plan. If you have any questions, please contact K. Landis at (404) 331-5509.

Sincerely,

Orig signed by Ellis W. Merschoff

9510230304 951010
PDR ADOCK 05000335
P PDR

Ellis W. Merschoff, Director
Division of Reactor Projects

Docket No.: 50-335, 50-389
License No.: DPR-67, NPF-16

Enclosure: Inspection Plan

cc w/encl: (See page 2)

OFFICIAL COPY

210180

11
11
11

FP&L

2

cc w/encl:

D. A. Sager

Vice President

St. Lucie Nuclear Plant

P. O. Box 128

Ft. Pierce, FL 34954-0128

H. N. Paduano, Manager

Licensing and Special Programs

Florida Power and Light Company

P. O. Box 14000

Juno Beach, FL 33408-0420

J. Scarola

Plant General Manager

St. Lucie Nuclear Plant

P. O. Box 128

Ft. Pierce, FL 34954-0128

Robert E. Dawson

Plant Licensing Manager

St. Lucie Nuclear Plant

P. O. Box 128

Ft. Pierce, FL 34954-0218

J. R. Newman, Esq.

Morgan, Lewis & Bockius

1800 M Street, NW

Washington, D. C. 20036

John T. Butler, Esq.

Steel, Hector and Davis

4000 Southeast Financial Center

Miami, FL 33131-2398

Bill Passeti

Office of Radiation Control

Department of Health and

Rehabilitative Services

1317 Winewood Boulevard

Tallahassee, FL 32399-0700

Jack Shreve

Public Counsel

Office of the Public Counsel

c/o The Florida Legislature

111 West Madison Avenue, Room 812

Tallahassee, FL 32399-1400

cc w/encl: Continued see page 3

FP&L

3

cc w/encl: Continued
Joe Myers, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, FL 32399-2100





Thomas R. L. Kindred
County Administrator
St. Lucie County
2300 Virginia Avenue
Ft. Pierce, FL 34982

Charles B. Brinkman
Washington Nuclear Operations
ABB Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 3300
Rockville, MD 20852

Distribution w/encl:

J. Norris, NRR
G. Hallstrom, RII
PUBLIC

NRC Resident Inspector
U.S. Nuclear Regulatory Comm.
7585 South Highway A1A
Jensen Beach, FL 34957-2010

SEND TO PUBLIC DOCUMENT ROOM?						
<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO						
OFFICE	RII	RII	RII	RII		
SIGNATURE						
NAME	J. Norris	G. Hallstrom	J. Norris	G. Hallstrom		
DATE	10 / 10 / 95	10 / 10 / 95	10 / 10 / 95	10 / 11 / 95	10 / / 95	10 / / 95
COPY?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO

OFFICIAL RECORD COPY DOCUMENT NAME: G:\SL.PPR

ST LUCIE
INSPECTION PLAN

IP - Inspection Procedure

TI - Temporary Instruction

Core Inspection - Minimum NRC Inspection Program (mandatory all plants)

INSPECTION PROCEDURE	TITLE/ PROGRAM AREA	NUMBER OF INSPECTORS	PLANNED INSPECTION DATES	TYPE OF INSPECTION - COMMENTS
IP 84750 IP 86750	Radioactive Waste Systems, Water Chemistry Confirmatory Measurements and Radiological Environmental Monitoring Solid Radioactive Waste Management and Transportation of Radioactive Materials	1	10/16-20/95	Core Inspection
IP 38701 IP 38702 IP 38703	Procurement Program; Receipt, Storage, and Handling of Equipment and Materials Program Commercial Grade Procurement Inspection.	1	12/04-15/95	Regional Initiative - to address recent concerns in the procurement area.
IP 40500 IP 92720	Safety Assessment Corrective Action Program	3	12/95 or 01/96 1-week	Regional Initiative Inspection to review the adequacy and status of the ongoing Safety Assessment and Corrective Action Program at St Lucie.

INSPECTION	TITLE/ PROGRAM AREA	NUMBER OF INSPECTORS	PLANNED INSPECTION DATES	TYPE OF INSPECTION - COMMENTS
IP 61726 IP 62703	Surveillance Observation Maintenance Observation	1	11/95 1-week, 01/96 1-week, 03/96 1-week	Core Inspection
IP 82701 IP 82301 IP 82302	Operational Status of the Emergency Preparedness Program Evaluation of Exercises for Power Reactors Review of Exercise Objectives and Scenarios for Power Reactors	2	02/05-09/96	Core Inspection - EP Exercise
IP 83750 IP 84750 IP 86750	Occupational Radiation Exposure Radioactive Waste Systems, Water Chemistry Confirmatory Measurements and Radiological Environmental Monitoring Solid Radioactive Waste Management and Transportation of Radioactive Materials	2	02/26-03/01/96	Core Inspection
TI 2515/109	Inspection Requirements for Generic Letter 89-10, Safety-Related Motor- Operated Valve Testing and Surveillance	1 or 2	TBD - 01-03/96	Area of Emphasis - Inspection to close out Generic Letter 89-10
	Licensing Examination Preparation	3	03/11-15/96	Operator Exam Preparation
	Initial Licensing Examination	3	03/25-29/96	Scheduled Operator Exam