

PRIORITY 1
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9511280234 DOC. DATE: 95/11/20 NOTARIZED: NO DOCKET # 05000389
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME AUTHOR AFFILIATION
 SAGER, D.A. Florida Power & Light Co.
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides info re St Lucie Unit 2 TS 4.4.5.5.a & SG Tube Plugging Rept.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-1 LA	1 1	PD2-1 PD	1 1
	NORRIS, J	1 1		
INTERNAL:	ACRS	6 6	<u>FILE CENTER 01</u>	1 1
	NRR/DE/EMCB	1 1	NRR/DRCH/HICB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS3	1 0
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 18 ENCL 17

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



November 20, 1995

L-95-310
10 CFR 50.36
10 CFR 50.4

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Gentlemen:

Re: St. Lucie Unit 2
Docket No. 50-389
Special Report
Steam Generator Tube Plugging Report

This letter is being sent pursuant to St. Lucie Unit 2 Technical Specification 4.4.5.5.a. The following number of tubes were plugged during the Fall Unit 2 refueling outage:

Steam Generator 2A - 5
Steam Generator 2B - 11

Should you have any questions on this information, please contact us.

Very truly yours,

D. A. Sager
Vice President
St. Lucie Plant

DAS/GRM

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant

9511280234 951120
PDR ADDCK 05000389
PDR

ADD 11/0



11

12

13

14