

# CATEGORY 2

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9606210154      DOC. DATE: 96/06/07      NOTARIZED: NO      DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.      05000335  
       50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389  
 AUTH. NAME      AUTHOR AFFILIATION  
 LANDIS, K.D.      Region 2 (Post 820201)  
 RECIP. NAME      RECIPIENT AFFILIATION  
 PLUNKETT, T.F.      Florida Power & Light Co.

SUBJECT: Forwards insp rept 50-335/96-06 & 50-389/96-06 on 960331-0511 & notice of violation. Violation reflects failure of fire protection program to ensure that fire brigade members properly qualified.

DISTRIBUTION CODE: IE01D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3+52  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:


	RECIPIENT ID CODE/NAME		COPIES			RECIPIENT ID CODE/NAME		COPIES		
	LTR	ENCL	LTR	ENCL		LTR	ENCL	LTR	ENCL	
	PD2-3	PD	1	1		WIENS, L.	1	1		
INTERNAL:	ACRS		2	2		AEOD/SPD/RAB	1	1		
	AEOD/TTC		1	1		DEDRO	1	1		
	<del>FILE CENTER</del>		1	1		NRR/DISP/PIPB	1	1		
	NRR/DRCH/HHFB		1	1		NRR/DRPM/PECB	1	1		2
	NRR/DRPM/PERB		1	1		NUDOCS-ABSTRACT	1	1		
	OE DIR		1	1		OGC/HDS3	1	1		
	RGN2	FILE 01	1	1						
EXTERNAL:	LITCO BRYCE, J H		1	1		NOAC	1	1		
	NRC PDR		1	1						

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 19

C  
A  
T  
E  
G  
O  
R  
Y  
D  
O  
C  
U  
M  
E  
N  
T



June 7, 1996

Florida Power & Light Company  
ATTN: T. F. Plunkett  
President - Nuclear Division  
P. O. Box 14000  
Juno Beach, Florida 33408-0420

SUBJECT: NRC INTEGRATED INSPECTION REPORT 50-335/96-06, 50-389/96-06  
NOTICE OF VIOLATION.

Dear Mr. Plunkett:

On May 11, 1996, the NRC completed an inspection at your St. Lucie 1 and 2 reactor facilities. The enclosed report presents the results of that inspection.

Based on the results of this inspection, the NRC has determined that a violation of NRC requirements occurred. The violation is of concern because it reflects a failure of your fire protection program to ensure that fire brigade members were properly qualified. Fire protection program concerns were also described in Inspection Report 95-12 indicating that weaknesses persist.

This violation is cited in the enclosed Notice of Violation, and the circumstances surrounding the violation is described in detail in the enclosed report. Please note that you are required to respond to this letter and should follow the instructions specified in the enclosed Notice when preparing your response. The NRC will use your response, in part, to determine whether further enforcement action is necessary to ensure compliance with regulatory requirements.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room (PDR).

Sincerely,

Orig signed by Kerry Landis  
Kerry D. Landis, Chief  
-Reactor Projects Branch 3  
Division of Reactor Projects

Docket Nos. 50-335, 50-389  
License Nos. DPR-67, NPF-16

Enclosures: Notice of Violation  
Inspection Report 50-335/96-06, 50-389/96-06

210022

OFFICIAL COPY

9606210154 960607  
PDR ADOCK 05000335  
Q PDR

11  
1031

cc w/encl:

J. A. Stall  
Site Vice President  
St. Lucie Nuclear Plant  
P. O. Box 128  
Ft. Pierce, FL 34954-0128

H. N. Paduano, Manager  
Licensing and Special Programs  
Florida Power and Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

J. Scarola  
Plant General Manager  
St. Lucie Nuclear Plant  
P. O. Box 128  
Ft. Pierce, FL 34954-0128

E. J. Weinkam  
Plant Licensing Manager  
St. Lucie Nuclear Plant  
P. O. Box 128  
Ft. Pierce, FL 34954-0218

J. R. Newman, Esq.  
Morgan, Lewis & Bockius  
1800 M Street, NW  
Washington, D. C. 20036

John T. Butler, Esq.  
Steel, Hector and Davis  
4000 Southeast Financial Center  
Miami, FL 33131-2398

Bill Passeti  
Office of Radiation Control  
Department of Health and  
Rehabilitative Services  
1317 Winewood Boulevard  
Tallahassee, FL 32399-0700

Jack Shreve, Public Counsel  
Office of the Public Counsel  
c/o The Florida Legislature  
111 West Madison Avenue, Room 812  
Tallahassee, FL 32399-1400

Joe Myers, Director  
 Division of Emergency Preparedness  
 Department of Community Affairs  
 2740 Centerview Drive  
 Tallahassee, FL 32399-2100

Thomas R. L. Kindred  
 County Administrator  
 St. Lucie County  
 2300 Virginia Avenue  
 Ft. Pierce, FL 34982

Charles B. Brinkman  
 Washington Nuclear Operations  
 ABB Combustion Engineering, Inc.  
 12300 Twinbrook Parkway, Suite 3300  
 Rockville, MD 20852

Distribution w/encl:  
 K. Landis, RII  
 J. Norris, NRR  
 B. R. Crowley, RII  
 G. A. Hallstrom, RII  
 PUBLIC

NRC Resident Inspector  
 U.S. Nuclear Regulatory Comm.  
 7585 South Highway A1A  
 Jensen Beach, FL 34957-2010

OFFICE						
SIGNATURE	<i>J.S. Mellin</i>	<i>J.M. Miller</i>	<i>J.S. Sandin</i>	<i>P. Mellin</i>	<i>J.C. Lany</i>	<i>J.S. Mellin</i>
NAME	ELea	J.M. Miller	J.S. Sandin	RChou	J.C. Lany	J.S. Mellin
DATE	06/6/96	06/7/96	06/7/96	06/6/96	06/7/96	06/6/96
COPY?	YES <input checked="" type="radio"/> NO	YES <input checked="" type="radio"/> NO	YES <input checked="" type="radio"/> NO	YES <input checked="" type="radio"/> NO	YES <input checked="" type="radio"/> NO	YES <input checked="" type="radio"/> NO