

Mr. Thomas F. Plunkett  
President, Nuclear Division  
Florida Power and Light Company  
Post Office Box 14000  
Juno Beach, Florida 33408-0420

July 16, 1996

SUBJECT: REQUEST FOR INFORMATION CONCERNING STEAM GENERATOR TUBE INTEGRITY  
ANALYSIS - ST. LUCIE PLANT, UNIT 1 (TAC NO. M95230)

Dear Mr. Plunkett:

As a result of the NRC staff's review of steam generator inspection and repair criteria for St. Lucie Unit 1, you provided additional information concerning these criteria in a letter dated June 25, 1996. Based on a review of the material provided, the NRC staff has several comments and questions which are specified in the enclosure to this letter. Your response to these comments and questions should be included in the probabilistic tube integrity analysis, scheduled to be completed in September 1996. This information, in part, is necessary for the staff to adequately perform an independent evaluation of this analysis.

Sincerely,

Original signed by

Leonard A. Wiens, Senior Project Manager  
Project Directorate II-3  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-335

Enclosure: Staff Review Comments

cc w/enclosure: See next page

DISTRIBUTION

Docket File J. Zwolinski  
PUBLIC OGC  
St. Lucie Rdg. ACRS  
S. Varga J. Johnson

DF011/1

DOCUMENT NAME: G:\STLUCIE\SLLTRSG.RAI

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDII-3/LA	PDII-3/PM	PDII-3/D	
NAME	Bclayton	LWiens	FHebdon	
DATE	07/15/96	07/16/96	07/16/96	

OFFICIAL RECORD COPY

9607170169 960716  
PDR ADOCK 05000335  
PDR

NRC FILE CENTER COPY



Handwritten marks and scribbles in the top right corner.

A large, dense, and mostly illegible handwritten area in the center of the page, possibly containing a list or a collection of notes.

Small handwritten marks or characters on the right side of the page.

Small handwritten marks or characters on the right side of the page.

Small handwritten marks or characters on the right side of the page.

Small handwritten marks or characters at the bottom right of the page.

Mr. T. F. Plunkett  
Florida Power and Light Company

St. Lucie Plant

cc:

Jack Shreve, Public Counsel  
Office of the Public Counsel  
c/o The Florida Legislature  
111 West Madison Avenue, Room 812  
Tallahassee, Florida 32399-1400

Regional Administrator,  
Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W. Suite 2900  
Atlanta, Georgia 30323

Senior Resident Inspector  
St. Lucie Plant  
U.S. Nuclear Regulatory Commission  
7585 S. Hwy A1A  
Jensen Beach, Florida 34957

H. N. Paduano, Manager  
Licensing & Special Programs  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, Florida 33408-0420

Joe Myers, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
2740 Centerview Drive  
Tallahassee, Florida 32399-2100

J. A. Stall, Site Vice President  
St. Lucie Nuclear Plant  
P. O. Box 128  
Ft. Pierce, Florida 34954-0128

J. R. Newman  
Morgan, Lewis & Bockius  
1800 M Street, N.W.  
Washington, DC 20036

J. Scarola  
Plant General Manager  
St. Lucie Nuclear Plant  
P.O. Box 128  
Ft. Pierce, Florida 34954-0128

John T. Butler, Esquire  
Steel, Hector and Davis  
4000 Southeast Financial Center  
Miami, Florida 33131-2398

Mr. Kerry Landis  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W. Suite 2900  
Atlanta, Georgia 30323-0199

Mr. Thomas R.L. Kindred  
County Administrator  
St. Lucie County  
2300 Virginia Avenue  
Fort Pierce, Florida 34982

E. J. Weinkam  
Licensing Manager  
St. Lucie Nuclear Plant  
P.O. Box 128  
Fort Pierce, Florida 34954-0128

Mr. Charles Brinkman, Manager  
Washington Nuclear Operations  
ABB Combustion Engineering, Nuclear  
Power  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Mr. Thomas J. Saporito  
National Litigation Consultants  
6230 W. Indiantown Road #7-355  
Jupiter, Florida 33458

Mr. Bill Passetti  
Office of Radiation Control  
Department of Health and  
Rehabilitative Services  
1317 Winewood Blvd.  
Tallahassee, Florida 32399-0700

STAFF COMMENTS AND QUESTIONS RELATING TO  
TUBE INTEGRITY ANALYSIS

1. Clarify how free span indications which are not crack-like and which can not be traced back to the preservice baseline inspection were dispositioned.
2. Discuss the extent to which the data used in the sizing qualification program have similar morphologies and eddy current responses (e.g., extent of intergranular attack, cracking, voltage responses, noise levels, etc.).

Discuss the basis for including data from different frequencies in the qualification program (400 kHz and 560 kHz) given that the ability to reliably size defects will, in part, depend on the frequency.


3. In the June 25, 1996, response to NRC Request 3, it was indicated that the burst pressure correlation that will be used relies on average crack depth. The qualification data for the sizing program relies on maximum crack depth. Discuss how the uncertainties associated with converting from maximum to average crack depth will be addressed (e.g., using a curve similar to that in Figure 3 of Attachment A to the June 25, 1996 letter). Provide the supporting metallographic and eddy current data to support this approach.

Discuss how the uncertainties in the predicted burst pressure will be accounted for in the probabilistic methodology (i.e., the predicted burst pressure does not exactly match the observed burst pressure as is illustrated in Figure 1 of Attachment A).

In Figures 4, 5, and 6 of Attachment A to your June 25, 1996 letter, information regarding the distribution of material properties expected in the St. Lucie Unit 1 steam generator tubes is provided. Discuss if this data is from steam generators tubes that have been in service. If not, provide the distribution of material properties based on destructive examination of pulled tubes from similarly fabricated Combustion Engineering steam generators. Provide the mean and standard deviation of this data along with the 95/95 confidence value (i.e., the lower tolerance limit).

Discuss how the growth rate distribution was developed. Discuss how the average growth rate was determined.

Clarify whether a lower 95% prediction interval curve for the burst pressure versus crack size correlation was used in the deterministic run-time evaluation. Use of the lower 95% prediction interval curve is consistent with the approach in Generic Letter 95-05. Please provide for comparative purposes a deterministic run-time evaluation assuming a lower 95% prediction interval curve for the burst pressure correlation adjusted for lower bound (95/95) material properties based on the destructive examination of inservice steam generator tubes. This analysis should also assume a 95% cumulative probability value for non-destructive examination uncertainty.



4. In the June 25, 1996, response to NRC request 4, EPRI report TR-104788 was cited. EPRI report TR-104788 contains guidelines for primary-to-secondary leakage monitoring programs. In this report, deviations from the guidelines are considered acceptable following plant-specific evaluations. Please clarify any significant deviations taken from these guidelines. In addition, specifically address the leakage limits/action levels to be implemented at St. Lucie Unit 1.
5. In the June 25, 1996, response to NRC Request 5, it was indicated that undetected flaws will be projected to give the end-of-cycle (EOC) distribution of through-wall cracks. Discuss whether the detected flaws will also be included in this projection. Discuss the need to include in the leakage analysis indications which are near through-wall and will pop-through the wall under postulated accident conditions. Discuss how nondestructive examination (NDE) uncertainty will be accounted for in the projection of the EOC distribution.

The staff has accepted a value for the probability of detection which is independent of flaw depth of 0.6. Clarify the value of the probability of detection that will be used in your analyses for predicting the EOC distribution of indications. If different than the 0.6 value discussed above, provide a sensitivity study using this value.

Clarify whether the analyses to be performed to determine the EOC distribution will start from a beginning of cycle distribution which has been adjusted for the probability of detection and the number of indications repaired similar to the methodology described in Generic Letter 95-05.

6. Discuss and provide the qualification data for the leakage model that will be implemented. Discuss how the results from the in-situ pressure tests will be factored into the leakage model.
7. Provide tabularized and graphical data for the distribution of indications detected (length and depth) for each steam generator, the distribution of indications repaired for each steam generator, the growth rate of indications (length and depth) for each steam generator, the material properties distribution, the NDE uncertainty models, and the burst pressure correlation. For the distribution of indications detected and repaired, the growth rate distribution, and the material properties distribution, provide the number of indications with depths/lengths/material properties within a given interval (e.g., 10 indications with depths between 35% and 40% through-wall). For the remaining distributions, provide the data in a format suitable for the staff to independently verify the results of the tube integrity analysis.
8. In the June 25, 1996, response to NRC Request 7, it is stated that the "burst pressure will be treated deterministically." Clarify what is meant by this statement.