



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

FLORIDA POWER & LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 146
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power & Light Company, et al. (the licensee), dated May 17, 1995, and supplemented July 15, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, Facility Operating License No. DPR-67 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and by amending paragraph 2.C.(2) to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 146, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 14, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 146

TO FACILITY OPERATING LICENSE NO. DPR-67

DOCKET NO. 50-335

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove Pages

1-2
6-1
6-2

Insert Pages

1-2
6-1
6-2

DEFINITIONS

CHANNEL FUNCTIONAL TEST

- 1.6 A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated signal into the channel as close to the primary sensor as practicable to verify OPERABILITY including alarm and/or trip functions.

CONTAINMENT VESSEL INTEGRITY

- 1.7 CONTAINMENT VESSEL INTEGRITY shall exist when:
- a. All containment vessel penetrations required to be closed during accident conditions are either:
 - 1. Capable of being closed by an OPERABLE containment automatic isolation valve system, or
 - 2. Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed position except as provided in Table 3.6-2 of Specification 3.6.3.1,
 - b. All containment vessel equipment hatches are closed and sealed,
 - c. Each containment vessel air lock is in compliance with the requirements of Specification 3.6.1.3,
 - d. The containment leakage rates are within the limits of Specification 3.6.1.2, and
 - e. The sealing mechanism associated with each penetration (e.g., welds, bellows or O-rings) is OPERABLE.

CONTROLLED LEAKAGE

- 1.8 CONTROLLED LEAKAGE shall be the seal water flow supplied from the reactor coolant pump seals.

CORE ALTERATION

- 1.9 CORE ALTERATION shall be the movement or manipulation of any fuel, sources, reactivity control components, or other components affecting reactivity within the reactor vessel with the vessel head removed and fuel in the vessel. Exceptions to the above include shared (4 fingered) control element assemblies (CEAs) withdrawn into the upper guide structure (UGS) or evolutions performed with the UGS in place such as CEA latching/unlatching or verification of latching/unlatching which do not constitute a CORE ALTERATION. Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.

6.0 ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILITY

- 6.1.1 The Plant General Manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.
- 6.1.2 The Shift Supervisor, or during his absence from the control room a designated individual, shall be responsible for the control room command function. A management directive to this effect, signed by the Site Vice President, shall be reissued to all station personnel on an annual basis.

6.2 ORGANIZATION

ONSITE AND OFFSITE ORGANIZATION

- 6.2.1 An onsite and an offsite organization shall be established for unit operation and corporate management. This onsite and offsite organization shall include the positions for activities affecting the safety of the nuclear power plant.
- a. Lines of authority, responsibility and communication shall be established and defined from the highest management levels through intermediate levels to and including all operating organization positions. Those relationships shall be documented and updated, as appropriate, in the form of organizational charts. These organizational charts will be documented in the Topical Quality Assurance Report and updated in accordance with 10 CFR 50.54(a)(3).
 - b. The President - Nuclear Division shall be responsible for overall plant nuclear safety. This individual shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support in the plant so that continued nuclear safety is assured.
 - c. The Plant General Manager shall be responsible for overall unit safe operation and shall have control over those onsite resources necessary for safe operation and maintenance of the plant.
 - d. Although the individuals who train the operating staff and those who carry out the quality assurance functions may report to the appropriate manager onsite, they shall have sufficient organizational freedom to be independent from operating pressures.
 - e. Although health physics individuals may report to any appropriate manager onsite, for matters relating to radiological health and safety of employees and the public, the Health Physics Supervisor shall have direct access to that onsite individual having responsibility for overall unit management. Health physics personnel shall have the authority to cease any work activity when worker safety is jeopardized or in the event of unnecessary personnel radiation exposures.

6.2 ORGANIZATION (continued)

UNIT STAFF

6.2.2 The unit organization shall be subject to the following:

- a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the control room when fuel is in the reactor. In addition, while the reactor is in MODE 1, 2, 3, or 4, at least one licensed Senior Reactor Operator shall be in the control room.
- c. A health physics technician[#] shall be on site when fuel is in the reactor.
- d. Either a licensed SRO or licensed SRO limited to fuel handling who has no concurrent responsibilities during this operation shall be present during fuel handling and shall directly supervise all CORE ALTERATIONS.

[#] The health physics technician may be less than the minimum requirement for a period of time not to exceed 2 hours, in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

FLORIDA POWER & LIGHT COMPANY
ORLANDO UTILITIES COMMISSION OF
THE CITY OF ORLANDO, FLORIDA

AND

FLORIDA MUNICIPAL POWER AGENCY

DOCKET NO. 50-389

ST. LUCIE PLANT UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 85
License No. NPF-16

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power & Light Company, et al. (the licensee), dated May 17, 1995, and supplemented July 15, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, Facility Operating License No. NPF-16 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and by amending paragraph 2.C.2 to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 85, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 14, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 85

TO FACILITY OPERATING LICENSE NO. NPF-16

DOCKET NO. 50-389

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove Pages

1-2
6-1
6-2

Insert Pages

1-2
6-1
6-2

DEFINITIONS

CHANNEL FUNCTIONAL TEST

- 1.6 A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated signal into the channel as close to the primary sensor as practicable to verify OPERABILITY including alarm and/or trip functions.

CONTAINMENT VESSEL INTEGRITY

- 1.7 CONTAINMENT VESSEL INTEGRITY shall exist when:
- a. All containment vessel penetrations required to be closed during accident conditions are either:
 - 1. Capable of being closed by an OPERABLE containment automatic isolation valve system, or
 - 2. Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except as provided in Table 3.6-2 of Specification 3.6.3.
 - b. All containment vessel equipment hatches are closed and sealed,
 - c. Each containment vessel air lock is in compliance with the requirements of Specification 3.6.1.3,
 - d. The containment leakage rates are within the limits of Specification 3.6.1.2, and
 - e. The sealing mechanism associated with each penetration (e.g., welds, bellows or O-rings) is OPERABLE.

CONTROLLED LEAKAGE

- 1.8 CONTROLLED LEAKAGE shall be the seal water flow supplied from the reactor coolant pump seals.

CORE ALTERATION

- 1.9 CORE ALTERATION shall be the movement or manipulation of any fuel, sources, reactivity control components, or other components affecting reactivity within the reactor vessel with the vessel head removed and fuel in the vessel. Exceptions to the above include shared (4 fingered) control element assemblies (CEAs) withdrawn into the upper guide structure (UGS) or evolutions performed with the UGS in place such as CEA latching/unlatching or verification of latching/unlatching which do not constitute a CORE ALTERATION. Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.

ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILITY

- 6.1.1 The Plant General Manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.
- 6.1.2 The Shift Supervisor, or during his absence from the control room, a designated individual, shall be responsible for the control room command function. A management directive to this effect, signed by the Site Vice President, shall be reissued to all station personnel on an annual basis.

6.2 ORGANIZATION

ONSITE AND OFFSITE ORGANIZATION

- 6.2.1 An onsite and an offsite organization shall be established for unit operation and corporate management. This onsite and offsite organization shall include the positions for activities affecting the safety of the nuclear power plant.
 - a. Lines of authority, responsibility and communication shall be established and defined from the highest management levels through intermediate levels to and including all operating organization positions. Those relationships shall be documented and updated, as appropriate, in the form of organizational charts. These organizational charts will be documented in the Topical Quality Assurance Report and updated in accordance with 10 CFR 50.54(a)(3).
 - b. The President - Nuclear Division shall be responsible for overall plant nuclear safety. This individual shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support in the plant so that continued nuclear safety is assured.
 - c. The Plant General Manager shall be responsible for overall unit safe operation and shall have control over those onsite resources necessary for safe operation and maintenance of the plant.
 - d. Although the individuals who train the operating staff and those who carry out the quality assurance functions may report to the appropriate manager onsite, they shall have sufficient organizational freedom to be independent from operating pressures.
 - e. Although health physics individuals may report to any appropriate manager onsite, for matters relating to radiological health and safety of employees and the public, the Health Physics Supervisor shall have direct access to that onsite individual having responsibility for overall unit management. Health physics personnel shall have the authority to cease any work activity when worker safety is jeopardized or in the event of unnecessary personnel radiation exposures.

6.2 ORGANIZATION (Continued)

UNIT STAFF

6.2.2 The unit organization shall be subject to the following:

- a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the control room when fuel is in the reactor. In addition, while the reactor is in MODE 1, 2, 3, or 4, at least one licensed Senior Reactor Operator shall be in the control room.
- c. A health physics technician[#] shall be on site when fuel is in the reactor.
- d. Either a licensed SRO or licensed SRO limited to fuel handling who has no concurrent responsibilities during this operation shall be present during fuel handling and shall directly supervise all CORE ALTERATIONS.
- e. DELETED
- f. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions; e.g., senior reactor operators, reactor operators, health physicists, auxiliary operators, and key maintenance personnel. Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the plant is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance or major plant modification, on a temporary basis the following guidelines shall be followed:

[#] The health physics technician may be less than the minimum requirement for a period of time not to exceed 2 hours, in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.

