

# CATEGORY 2

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9608230195 DOC.DATE: 96/08/05 NOTARIZED: NO DOCKET #  
FACIL:50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335  
50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389  
AUTH.NAME AUTHOR AFFILIATION  
LANDIS,K.D. Region 2 (Post 820201)  
RECIP.NAME RECIPIENT AFFILIATION  
PLUNKETT,T.F. Florida Power & Light Co.

SUBJECT: Discusses insp repts 50-335/96-09 & 50-389/96-09 on 960609-0706 & notice of violation.Lack of control over use of overtime by personnel performing safety-related activities of particular concern.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 10x44  
TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	WIENS,L.	1 1
INTERNAL:	ACRS	2 2	AEOD/SPD/RAB	1 1
	AEOD/TTC	1 1	DEDRO	1 1
	<u>FILE CENTER</u>	1 1	NRR/DISP/PIPB	1 1
	NRR/DRCH/HHFB	1 1	NRR/DRPM/PECB	1 1
	NRR/DRPM/PERB	1 1	NUDOCS-ABSTRACT	1 1
	OE DIR	1 1	OGC/HDS3	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	LITCO BRYCE,J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM  
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19

C  
A  
T  
E  
G  
O  
R  
Y  
2  
D  
O  
C  
U  
M  
E  
N  
T

August 5, 1996

EA 96-263

Florida Power & Light Company  
ATTN: T. F. Plunkett  
President - Nuclear Division  
P. O. Box 14000  
Juno Beach, Florida 33408-0420

SUBJECT: NRC INTEGRATED INSPECTION REPORT 50-335/96-09, 50-389/96-09 and  
NOTICE OF VIOLATION.

Dear Mr. Plunkett:

On July 6, 1996, the NRC completed an inspection at your St. Lucie 1 and 2 reactor facilities. The enclosed report presents the results of that inspection.

Based on the results of this inspection, the NRC has determined that violations of NRC requirements occurred. The violations are of concern because they collectively indicate that weaknesses in regulatory and procedural compliance extend across organizational lines, to include management, maintenance planning and performance, and health physics.

An area of particular concern involves the lack of control over the use of overtime by personnel performing safety-related activities. The number of examples identified in a relatively small population of personnel audited indicates that management was ineffective in controlling the excessive use of unapproved overtime. This indicated a weakness in management commitment to maintaining overtime usage at acceptable levels in order to minimize human error.

In addition, an element of your contamination control program is of concern, in that it had not been effective in preventing the improper use of contaminated tools.

The violations are cited in the enclosed Notice of Violation, and the circumstances surrounding the violations are described in detail in the enclosed report. Please note that you are required to respond to this letter and should follow the instructions specified in the enclosed Notice when preparing your response. The NRC will use your response, in part, to determine whether further enforcement action is necessary to ensure compliance with regulatory requirements.

OFFICIAL COPY

230036

9608230195 960805  
PDR ADOCK 05000335  
G PDR

1/1

JE C 1

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room (PDR).

Sincerely,

Orig signed by Kerry D. Landis

Kerry D. Landis, Chief  
Reactor Projects Branch 3  
Division of Reactor Projects

Docket Nos. 50-335, 50-389  
License Nos. DPR-67, NPF-16

Enclosures: Notice of Violation  
Inspection Report 50-335/96-09, 50-389/96-09

cc w/encl:  
J. A. Stall  
Site Vice President  
St. Lucie Nuclear Plant  
P. O. Box 128  
Ft. Pierce, FL 34954-0128

H. N. Paduano, Manager  
Licensing and Special Programs  
Florida Power and Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

J. Scarola  
Plant General Manager  
St. Lucie Nuclear Plant  
P. O. Box 128  
Ft. Pierce, FL 34954-0128

E. J. Weinkam  
Plant Licensing Manager  
St. Lucie Nuclear Plant  
P. O. Box 128  
Ft. Pierce, FL 34954-0218

J. R. Newman, Esq.  
Morgan, Lewis & Bockius  
1800 M Street, NW  
Washington, D. C. 20036

cc w/encl continued: See page 3



cc w/encl: Continued  
John T. Butler, Esq.  
Steel, Hector and Davis  
4000 Southeast Financial Center  
Miami, FL 33131-2398

Bill Passeti  
Office of Radiation Control  
Department of Health and  
Rehabilitative Services  
1317 Winewood Boulevard  
Tallahassee, FL 32399-0700

Jack Shreve, Public Counsel  
Office of the Public Counsel  
c/o The Florida Legislature  
111 West Madison Avenue, Room 812  
Tallahassee, FL 32399-1400

Joe Myers, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
2740 Centerview Drive  
Tallahassee, FL 32399-2100

Thomas R. L. Kindred  
County Administrator  
St. Lucie County  
2300 Virginia Avenue  
Ft. Pierce, FL 34982

Charles B. Brinkman  
Washington Nuclear Operations  
ABB Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 3300  
Rockville, MD 20852

Distribution w/encl: See page 4

Distribution w/encl:

- L. Wiens, NRR
- W. Bearden, RII
- J. York, RII
- F. Wright, RII
- L. Stratton, RII
- G. Hopper, RII
- B. Crowley, RII
- G. Hallstrom, RII
- PUBLIC

NRC Resident Inspector  
 U.S. Nuclear Regulatory Comm.  
 7585 South Highway A1A  
 Jensen Beach, FL 34957-2010

OFFICE	RII:DRR	RII:DRP	RII:DRP	RII:DBS	RII:DBS	RII:DRP
SIGNATURE	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>
NAME	MMiller alt	WMiller	TJohnson	FWright	JYork	LMellen
DATE	08/15/96	07/1/96	07/12/96	07/31/96	07/27/96	07/31/96
COPY?	(YES) NO	YES NO	YES (NO)	YES (NO)	(YES) NO	(YES) NO

OFFICIAL RECORD COPY      DOCUMENT NAME: A:\SL9609C.JUN