

St. Lucie Unit 1 and Unit 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Refueling Technical Specifications

ATTACHMENT 3

ST. LUCIE UNIT 1 MARKED-UP TECHNICAL SPECIFICATION PAGES

Page 3/4 9-9

Page 3/4 9-10

9611050011 961030
PDR ADOCK 05000335
PDR

REFUELING OPERATIONS

CONTAINMENT ISOLATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.9.9 The containment isolation system shall be OPERABLE .

APPLICABILITY: ~~MODE 6.~~ ^{REPLACE}

ACTION: ^{During CORE ALTERATIONS.}
^{During movement of irradiated fuel assemblies within containment.}

With the containment isolation system inoperable, close each of the penetrations providing direct access from the containment atmosphere to the outside atmosphere. ~~The provisions of Specification 3.0.3 are not applicable.~~

^{DELETE}

SURVEILLANCE REQUIREMENTS

4.9.9 The containment isolation system shall be demonstrated OPERABLE within 72 hours prior to the start of and at least once per 7 days during CORE ALTERATIONS by verifying that containment isolation occurs on manual initiation and on a high radiation signal from two of the containment radiation monitoring instrumentation channels.

REVENUE
5

DELETED

1

REFUELING OPERATIONS

WATER LEVEL - REACTOR VESSEL

LIMITING CONDITION FOR OPERATION

3.9.10 At least 23 feet of water shall be maintained over the top of irradiated fuel assemblies seated within the reactor pressure vessel.

APPLICABILITY: ~~During movement of fuel assemblies or GEAs within the reactor pressure vessel while in MODE 6.~~ **REPLACE**

ACTION: **During CORE ALTERATIONS.**
During movement of irradiated fuel assemblies within containment.

With the requirements of the above specification not satisfied, ~~suspend all operations involving movement of fuel assemblies or GEAs within the pressure vessel.~~ **REPLACE**

Immediately suspend CORE ALTERATIONS and movement of irradiated fuel assemblies within containment, and immediately initiate action to restore refueling cavity water level to within limits.

SURVEILLANCE REQUIREMENTS

4.9.10 The water level shall be determined to be at least its minimum required depth within 2 hours prior to the start of and at least once per 24 hours thereafter ~~during movement of fuel assemblies or GEAs.~~

CORE ALTERATIONS and during movement of irradiated fuel assemblies within containment.

REPLACE

REPLACE

REPLACE

REPLACE

St. Lucie Unit 1 and Unit 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Refueling Technical Specifications

ATTACHMENT 4

ST. LUCIE UNIT 2 MARKED-UP TECHNICAL SPECIFICATION PAGES

Page 3/4 9-10

Page 3/4 9-11

REFUELING OPERATIONS

3/4.9.9 CONTAINMENT ISOLATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.9.9 The containment isolation system shall be OPERABLE.

APPLICABILITY: During CORE ALTERATIONS or movement of irradiated fuel within the containment.

ACTION:

With the containment isolation system inoperable, close each of the containment penetrations providing direct access from the containment atmosphere to the outside atmosphere. ~~The provisions of Specification 3.0.4 are not applicable.~~

DELETE

SURVEILLANCE REQUIREMENTS

4.9.9 The containment isolation system shall be demonstrated OPERABLE within 72 hours prior to the start of and at least once per 7 days during CORE ALTERATIONS by verifying that containment isolation occurs on manual initiation and on a high radiation test signal from each of the containment radiation monitoring instrumentation channels.

428

1945

1945

REFUELING OPERATIONS

3/4.9.10 WATER LEVEL - REACTOR VESSEL

LIMITING CONDITION FOR OPERATION

3.9.10 At least 23 feet of water shall be maintained over the top of the reactor pressure vessel flange.

~~APPLICABILITY: During movement of fuel assemblies or GEAs within the reactor pressure vessel when either the fuel assemblies being moved or the fuel assemblies seated within the reactor pressure vessel are irradiated.~~ ← REPLACE

ACTION:

During CORE ALTERATIONS.
During movement of irradiated fuel assemblies within containment.

With the requirements of the above specification not satisfied, ~~suspend all operations involving movement of fuel assemblies or GEAs within the pressure vessel.~~ → REPLACE

immediately suspend CORE ALTERATIONS and movement of irradiated fuel assemblies within containment, and immediately initiate action to restore refueling cavity water level to within limits.

SURVEILLANCE REQUIREMENTS

4.9.10 The water level shall be determined to be at least its minimum required depth within 2 hours prior to the start of and at least once per 24 hours thereafter during ~~movement of fuel assemblies or GEAs.~~ → REPLACE

CORE ALTERATIONS and during movement of irradiated fuel assemblies within containment.

100

REPLACE

REPLACE

REPLACE

Attachment No.