•	· 14.9	REGULATO.		ATEC MATION	GORY 1 DISTRIBUTION	EM (RIDS)	
	ACCESSION FACIL:50 AUTH.NA STALL,J RECIP.1	N NBR:9612260326 0-335 St. Lucie Pl 0-389 St. Lucie Pl AME AUTHOR .A. Florida NAME RECIPIE Docume	DOC.I ant; Ui ant; Ui AFFILI Power { NT AFF: nt Con	DATE: 9 nit 1, nit 2, ATION & Light ILIATIC trol Bi	96/12/17 NOTARIZED Florida Power & Li Florida Power & Li Co. N Canch (Document Cor): NO E ght Co. () ght Co. () htrol Desk)	OCKET # 5000335 5000389
	SUBJECT	: Requests approva Rule for Selecti attachments,Sect programs.	l to in on & Ex ion XI	ncorpon kam of ,Div 1	cate Code Case N-50 Class 1,2 & 3 inte for use in Unit 1	9,Alternative grally welded & 2 10-Yr ISI	C A
	DISTRIB	UTION CODE: A047D OR Submittal: Inse	COPIE: rvice/'	S RECEI Festing	VED:LTR / ENCL	SIZE: 6 Code - GL-89-	т •04 Е
	NOTES:		• •		κ. K		G
		RECIPIENT · ID CODE/NAME PD2-3 LA	COPII LTTR 1	ES ENCL 1	RECIPIENT ID CODE/NAME PD2-3 PD	COPIES LTTR ENCL l l	0
	•	WIENS, L.	1	1			ĸ
	INTERNAL.	ACRS FILE_CENTER 01 NUDOCS-ABSTRACT RES/DET/EIB	1 1 1 1	1 1 1 1	AEOD/SPD/RAB NRR/DE/EMEB OGC/HDS3 RES/DET/EMMEB	1 1 1 1 1 0 1 1	Y 1
	EXTERNAL:	LITCO ANDERSON	٦	٦			
		NRC PDR	, ī	ī		· · ·	, D
		,					0
		•					с
		, · · · · · · · · · · · · · · · · · · ·					υ
	,						м
	·						E
							न म
			_	u			1
			•	_			
				·			a.

.

Í

NOTE TO ALL "RIDS" RECIPIENTS: PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

14 ENCL 13 TOTAL NUMBER OF COPIES REQUIRED: LTTR

,





December 17, 1996

L-96-303 10 CFR 50.4 10 CFR 50.55a

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D. C. 20555

RE: St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 Inservice Inspection Plan Second Ten-Year Interval <u>ASME Code Case N-509 - Request for Use</u>

Pursuant to 10 CFR 50.55a, (Footnote 6) and 10 CFR 50.55a(a)(3), Florida Power and Light Company (FPL) requests approval to incorporate Code Case N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments, Section XI, Division 1, for use in the St. Lucie Unit 1 and Unit 2 Ten Year Inservice Inspection Programs. In addition to the elements of the Code Case, upon approval for use at St. Lucie Units 1 and 2 of Code Case N-509, FPL commits to schedule a minimum of ten percent (10%) of all integral attachments in non-exempt Code Class 1, 2, and 3 systems in each interval. Code Case N-509 was approved for use by ASME on November 25, 1992.

This Code Case is an alternative to the selection and examination requirements of ASME Code Sections IWB, IWC, and IWD for integrally welded Class 1, 2, and 3 attachments. Use of this alternative reduces the need for building scaffolding and insulation removal for the Reactor Coolant Pumps (RCP) and Class 1, 2, and 3 piping systems. The preparation for and the performance of the Section XI required examinations involve excessive cost, man-hours, and man-REM exposure with little or no compensating increase in the level of safety. In establishing the basis of the Code Case, ASME conducted a survey of the nuclear industry to determine the extent of the integral welded attachment failures. The data which was collected from the survey (43 plants responded) concluded the following:

Over the past 20 years, a total of five integral attachments failures were reported;

The failures were identified as a result of the connected support member deformation rather than during the scheduled examination of the integral attachment;

Of the five failures, only one resulted in leakage from the pressure boundary. The root cause was determined to be design error.

A047/1:

DR ADDCK 05000335

,

.

,

• • •

۳ -

λει 27 λ. πε γεριατικός 2 γεριατικός 2





St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 L-96-303 Page 2

٤.,

There are a total of 88 integral attachments on Unit 1 and 178 on Unit 2. A review of the inspection history at St. Lucie Units 1 and 2 revealed that 54 Unit 1 and 103 Unit 2 integral attachments have been examined since initial start-up. Only 2 of the attachments examined had indications and both were subsequently accepted for use as-is. These examination results are consistent with and support the technical basis established by ASME. A copy of the Code Case is attached for your information.

Code Case approval is requested to support its use in the upcoming St. Lucie Unit 2 refueling outage (SL2-10) currently scheduled to begin April 15, 1997.

If approved, this letter contains a regulatory commitment to inspect a minimum of 10 percent of the integral attachments in non-exempt ASME Code Class 1, 2, and 3 systems in each interval. Please contact us if there are any questions about this submittal.

Very truly yours,

J. A. Stall Vice President St. Lucie Plant

JAS/GRM

Attachment

The state of the second s

cc: Stewart D. Ebneter, Regional Administrator, Region II, USNRC Senior Resident Inspector, USNRC, St. Lucie Plant

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

Approval Date: November 25, 1992

See Numeric Index for expiration and any reaffirmation dates.

Case N-509

Alternative Rules for the Selection and Examinaion of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1

Inquiry: What alternative requirements to those of IWB, IWC, and IWD may be used to select and examine integrally welded attachments?

Reply: It is the opinion of the Committee that the following_rules may be used to select and examine integrally welded attachments:

(a) This Case is limited to Examination Gategories B-H, B-K-1, C-C, D-A, D-B, and D-C.

(b) Class 1, 2, and 3 component supports shall be selected for examination in accordance with IWF of the 1989 Edition with the 1990 Addenda.

(c) Except for the selection of component supports for examination, all references to Section XI within this Case shall be from the edition and addenda specified in the Owner's Inservice Inspection Program.

1.0 SCOPE

These requirements apply to examination and sample selection of Class 1, 2, and 3 integrally welded attachments of vessels, piping, pumps, and valves listed in Table 2500-1 as follows:

(a) Table 2500-1, Examination Category B-K shall be used for Class 1 integrally welded attachments in Examination Categories B-H and B-K-1 of IWB.

(b) Table 2500-1, Examination Category C-C shall be used for Class 2 integrally welded attachments in Examination Category C-C of IWC.

(c) Table.2500-1, Examination Category D-A shall be used for Class 3 integrally welded attachments in Examination Categories D-A, D-B, and D-C of IWD.

1.1 Exemption Criteria

(a) The exemption criteria provided in IWB-1220, IWC-1220, and IWD-1220 may be applied to Class 1, 2, and 3 components respectively, with integrally welded attachments, required to be examined in accordance with Table 2500-1.

(b) Class 1, 2, and 3 integrally welded attachment examinations performed as a result of component support deformation cannot be credited under the requirements of IWB-2411 or IWB-2412, IWC-2411 or IWC-2412, and IWD-2411 or IWD-2412; respectively.

1.2 Inspection Schedule

Class 1, 2, or 3 integrally welded attachments selected for examination by sample selection criteria in accordance with Table 2500-1, Examination Categories B-K, C-C, and D-A, shall meet the requirements of IWB-2411 or IWB-2412, IWC-2411 or IWC-2412, or IWD-2411 or IWD-2412, repectively.

1.3 Additional and Successive Examinations

(a) Class 1, 2, and 3 additional and successive examination requirements of IWB-2430 and IWB-2420 for Class 1, IWC-2430 and IWC-2420 for Class 2 and 3 as applicable, shall be applied to integrally welded attachments whose examinations reveal flaws or relevant conditions that exceed the acceptance standards of IWB-3000, IWC-3000, and IWD-3000, respectively.

(b) When integrally welded attachments are examined as a result of identified component support deformation and the results of these examinations exceed the applicable acceptance standards listed above, additional or successive examinations shall be performed when determined necessary based on an evaluation by the Owner.

	i		EXAMINATION CA	ILGURIES		
	EXAMINATIO	N CATEGORY B-K, INTEGR	AL ATTACHMENTS FO	R CLASS 1 VESSE	LS, PIPING, PUMPS, AND VALV	ES
Item No.	Parts Examined ¹	Examination Requirements/ Fig. No.	Examination Method	Acceptance Standard -	Extent of Examination ²³	Frequency of Examination ⁴
B10.10	Pressure Vessels Integrally Welded Attachments	IW8-2500-13, -14, and -15	Surface'	IWB-3516	100% of required areas of each welded attachment	Each Identified occurrence and each inspection interval*
B10.20	Piping Integrally Weided Attachments	IWB-2500-13, -14, and -15	Surface	IWB-3516	100% of required areas of each welded attachment	Each Identified occurrence and each Inspection Interval*
B10.30	Pumps Integrally Welded Attachments	IWB-2500-13, -14, and -15	Surface	IWB-3516 ,	100% of required areas of each welded attachment	Each identified occurrence and each inspection interval*
B10.40	Valves Integrally Welded Attachments	IWB-2500-13, -14, and -15	Surface I	IWB-3516	100% of required areas of each welded attachment	Each identified occurrence and each inspection interval ³

: TABLE 2500-1 EXAMINATION CATEGORIES

NOTES:

986

.

(1) Examination is limited to those integrally welded attachments that meet the following conditions:

1

(a) the attachment is on the outside surface of the pressure retaining component;

(b) the attachment provides component support as defined in NF-1110; and

(c) the attachment weld joins the attachment either directly to the surface of the component or to an integrally cast or forged attachment to the component.

(2) The extent of the examination includes essentially 100% of the length of the attachment weld at each attachment subject to examination.

4

(3) Selected samples of integrally welded attachments shall be examined each inspection interval.

(4) In the case of multiple vessels of similar design, function and service, only one integrally welded attachment of only one of the multiple vessels shall be selected for examination.

(5) For piping, pumps, and valves, a sample of 10% of the welded attachments associated with the component supports selected for examination under the 1990 Addenda, IWF-2510 shall be examined.

(6) Examination is required whenever component support member deformation (e.g., broken, bent, or pulled out parts) is identified during operation, refueling, maintenance, examination, inservice inspection, or testing.

(7) For the configuration shown in Fig. IWB-2500-14, a volumetric examination of volume A-B-C-D from side (B-C) of the circumferential welds may be performed in lieu of the surface examination of surfaces A-D and B-C.

N-509

CASE (continued)

TABLE 2500-1 (CONT'D) **EXAMINATION CATEGORIES**

1

C3.10 Pr Int C3.20 Pi	ressure Vessels tegrally Welded Attachments	IWC-2500-5	Surface			-
C3.20 Pi		•		IWC-3512 ,	100% of required areas of each welded attachment	Each identified occurrence and each inspection interval*
In	ping legrally Welded Attachments	. · IWC-2500-5	• Surface	IWC-3512 1	100% of required areas of each welded attachment	Each Identified occurrence and each inspection Interval*
C3.30 Pa Int	imps tegrally Welded Attachments	IWC-2500-5	Surface _	IWC-3512 '	100% of required areas of each 'welded attachment	Each identified occurrence and each inspection interval ^a
C3.40 Va	lives legrally Welded Attachments	IWC-2500-5	Surface	IWC-3512	100% of required areas of each welded attachment	Each Identified occurrence and each Inspection Interval*

1

:

(4) In the case of multiple vessels of similar design, function and service, only one integrally welded attachment of only one of the multiple vessels shall be selected for examination. (5) For piping, pumps, and valves, a sample of 10% of the welded attachments associated with the component supports selected for examination under the 1990 Addenda, IWF-2510 shall be examined.

(6) Examination is required whenever component support member deformation (e.g., broken, bent, or pulled out parts) is identified during operation, refueling, maintenance, examination, inservice inspection, or testing.

CASE (continued) N-509

J.

5

	EXAMINATIO	I CATEGORY D-A, INTEGR	AL ATTACHMENTS FO	DR CLASS 3 VESSI	ELS, PIPING, PUMPS, AND VALV	ES
Item No.	Parts Examined ¹	Examination Requirements/ Fig. No.	Examination Method	Acceptance Standard	• Extent of Examination**	Frequency of Examination ^{3,4}
D1.10	Pressure Vessels Integrally Welded Attachments	IW0-2500-1	Visual, VT-1	1WD-3000	100% of required areas of each welded attachment	Each Identified occurrence and each Inspection Interval
01.20	Piping Integrally Welded Attachments	IWD-2500-1	Visual, VT-1	1WD-3000	100% of required areas of each welded attachment	Each Identified occurrence and each inspection interval
01.30	Pumps Integrally Welded Attachments	IWD-2500-1	' Visual, VT-1	1WD-3000 ¹ !	100% of required areas of each welded attachment	Each Identified occurrence and each Inspection Interval
D1.40	Valves Integrally Welded Attachments	IWD-2500-1	Visual, VT-1	IWD-3000	100% of required areas of each welded attachment	Each identified occurrence and each inspection interval

TABLE 2500-1 (CONT'D) EXAMINATION CATEGORIES

ŧ

NOTES:

(1) Examination is limited to those integrally welded attachments that meet the following conditions:

1

(a) the attachment is on the outside surface of the pressure retaining component;

(b) the attachment provides component support as defined in NF-1110; and

(c) the attachment weld joins the attachment either directly to the surface of the component or to an integrally cast or forged attachment to the component.

(2) The extent of the examination includes essentially 100% of the length of the attachment weld at each attachment subject to examination.

(3) Selected samples of integrally weided attachments shall be examined each inspection interval. All integrally weided attachments selected for examination shall be subject to corrosion, as determined by the Owner, such as the integrally weided attachments of the Service Water or Emergency Service Water systems. In the case of multiple vessels of similar design, function and service, the integrally weided attachments of only one of the multiple vessels shall be selected for examination. For integrally weided attachments of piping, pumps, and valves a 10% sample shall be selected for examination. This percentage sample shall be proportional to the total number of nonexempt integrally weided attachments connected to the piping, pumps, and valves, located within each system subject to these examinations.

(4) Examination is required whenever component support member deformation (e.g., broken, bent, or pulled out parts) is identified during operation, refueling, maintenance, examination, inservice inspection, or testing.

<u>م</u>

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

1

N-509

CASE (continued)