

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9801130326 DOC.DATE: 98/01/05 NOTARIZED: YES DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 AUTH.NAME AUTHOR AFFILIATION
 STALL, J.A. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Notifies NRC that commitment was completed during SG replacement/refueling outage (SL1-15). Commitment was transmitted by FPL ltr L-92-28, dtd 920203 & later modified by FPL ltr L-95-149 dtd 950523.

DISTRIBUTION CODE: A002D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2
 TITLE: OR Submittal: Inadequate Core Cooling (Item II.F.2) GL 82-28

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	WIENS, L.	1 1
INTERNAL:	ACRS	1 1	<u>FILE CENTER</u> 01	1 1
	NRR/DSSA/SRXB	1 1	RES DE	1 1
	RES/DET/EIB	1 1	RES/DSIR/RPSB	1 1
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



January 5, 1998

L-98-7
10 CFR 50.4

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

RE: St. Lucie Unit 1
Docket No. 50-335
Regulatory Guide 1.97
Wide Range Steam Generator Level Commitment

In response to NRC letter dated November 12, 1991, Florida Power & Light Company (FPL) made a commitment to install a redundant wide range steam generator level instrument with an independent lower tap on St. Lucie Unit 1 during the steam generator replacement outage. The commitment was transmitted by FPL letter L-92-28, dated February 3, 1992 and later modified by FPL letter L-95-149, dated May 23, 1995.

The purpose of this letter is to notify the NRC that the commitment was completed during the steam generator replacement/refueling outage (SL1-15).

Please contact us if there are any questions.

Very truly yours,

J. A. Stall
Vice President
St. Lucie Plant

JAS/GRM

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant

40024/1

9801130326 980105
PDR ADDCK 05000335
P PDR



