
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

APR1400 Design Certification

Korea Electric Power Corporation / Korea Hydro & Nuclear Power Co., LTD

Docket No. 52-046

RAI No.: 541-8724
SRP Section: 06.02.05 – Combustible Gas Control in Containment
Application Section: 6.2.5
Date of RAI Issue: 02/21/2017

Question No. 06.02.05-12

This is a follow up question to KHNP's response to RAI 155-8167, Question 6.2.5-4, regarding passive autocatalytic recombiner (PAR) recombination rates.

10 CFR 52.44(c)(1) requires that a standard design certification applicant must ensure a mixed atmosphere in containment during design-basis and significant beyond design basis accidents. A mixed atmosphere means that the concentration of combustible gases in any part of the containment is below a level that supports combustion or detonation that could cause loss of containment integrity.

APR1400 Design Control Document (DCD) Tier 2, Section 6.2.5 credits the passive autocatalytic recombiners (PAR) with meeting the above criteria.

However, in DCD Tier 1, Table 2.11.4-1, "Containment Hydrogen Control System ITAAC," there is insufficient information to determine that the containment hydrogen control system design meets the above criteria. In DCD Tier 2, Table 6.2.5-1, "Location of PARs and His," PAR and hydrogen igniters (HI) locations in containment are provided. This information should either be included in Tier 1, Table 2.11.4-1, or a link to Tier 2, Table 6.2.5-1 should be provided in Tier 1, Table 2.11.4-1.

Also, DCD Tier 2, Table 6.2.5-1 describes the PARs as "small, middle, large." The actual PAR recombination rates which form the basis of the hydrogen containment analysis should be provided in the DCD.

The response stated that the equation for the recombination rate for the large (FR1-1500) PARs has the two coefficients, A and B. The staff's review indicates that these coefficients, A and B, should be larger. These coefficients were deduced by comparing the recombination rate that is predicted by the formula to the performance specifications published for an AREVA PAR.

KHNP's response to RAI 472-8564, Question 6.2.5-11, confirmed the larger coefficients above were used by KHNP in their analyses. This is in agreement with the coefficients used in staff's MELCOR confirmatory calculation.

In the original RAI 155-8167, question 6.2.5-4, staff also requested the following:

DCD Tier 2, Table 6.2.5-1 describes the PARs as "small, middle, large." The actual PAR recombination rates which form the basis of the hydrogen containment analysis should be provided in the DCD, either:

- Into both Tier 2, Table 6.2.5-1 and Tier 1, Table 2.11.4-1, or
- Into just Tier 2, Table 6.2.5-1, with a link to Tier 2, Table 6.2.5-1 being provided in Tier 1, Table 2.11.4-1.

Please provide the recombination rates of the three sizes of PARs which establish the capacity of the containment hydrogen control system.

Response

The performance criteria for depletion rates of PARs are provided in the following table. This information will be added to DCD Tier 2 Table 6.2.5-3 as shown in Attachment 1

Performance criteria for depletion rates of PARs

| Condition Size | Hydrogen 4% | Hydrogen 8% |
|-------------------|-------------|-------------|
| Small | 0.9 kg/hr | 1.8 kg/hr |
| Medium | 1.8 kg/hr | 3.6 kg/hr |
| Large | 4.0 kg/hr | 8.0 kg/hr |

Tier 1 is a standalone document that should both minimize the amount of design-level data subject to revision and not contain links to DCD Tier 2. Attachment 2 reflects these revisions.

Impact on DCD

DCD Tier 2, Subsection 6.2.5.2.1 and 6.2.9 will be revised and Tier 2, Table 6.2.5-3 will be added as indicated in Attachment 1 associated with this response.

DCD Tier 1, Tables 2.11.4-1 will be revised as indicated in the Attachment 2 associated with this response.

Impact on PRA

There is no impact on the PRA.

Impact on Technical Specifications

There is no impact on the Technical Specifications.

Impact on Technical/Topical/Environmental Reports

There is no impact on any Technical, Topical, or Environmental Report.

APR1400 DCD TIER 2

| | | |
|----------------|--|---------|
| Table 6.2.1-35 | Letdown Heat Exchanger and Valve Subcompartments Vent Path Description..... | 6.2-396 |
| Table 6.2.1-36 | Mass and Energy Release Data..... | 6.2-398 |
| Table 6.2.1-37 | Stored Energy Sources..... | 6.2-403 |
| Table 6.2.1-38 | Primary Side Resistance Factors Used in FLOOD3 Code | 6.2-433 |
| Table 6.2.1-39 | Blowdown and Reflood Mass and Energy Release for the Minimum Containment Pressure Analysis | 6.2-434 |
| Table 6.2.2-1 | Input Values Used in CSS Evaluation Calculations | 6.2-438 |
| Table 6.2.2-2 | Containment Spray System Design Parameters | 6.2-439 |
| Table 6.2.2-3 | Containment Spray System Failure Modes and Effects Analysis | 6.2-441 |
| Table 6.2.2-4 | Containment Spray System Display Instrumentation..... | 6.2-446 |
| Table 6.2.2-5 | Mass Mean Diameter..... | 6.2-447 |
| Table 6.2.4-1 | List of Containment Penetrations and System Isolation Positions..... | 6.2-448 |
| Table 6.2.5-1 | Location of PARs and HIs..... | 6.2-458 |
| Table 6.2.5-2 | Hydrogen Monitoring System Failure Modes and Effects Analysis..... | 6.2-460 |
| Table 6.3.1-1 | Responses of APR1400 to TMI Action Plan..... | 6.3-35 |
| Table 6.3.1-2 | Responses of APR1400 to Generic Safety Issues..... | 6.3-36 |
| Table 6.3.1-3 | Responses of APR1400 to Generic Letters | 6.3-37 |
| Table 6.3.2-1 | SIS Component Parameters | 6.3-38 |
| Table 6.3.2-2 | Safety Injection System Failure Modes and Effects Analysis..... | 6.3-41 |
| Table 6.3.2-3 | Safety Injection System Head Loss Requirements | 6.3-55 |
| Table 6.3.2-4 | Safety Injection System Flow Delivery to RCS ⁽¹⁾ | 6.3-56 |
| Table 6.4-1 | The Accident Radiation Source Description and Radiation Shielding Design for MCR and TSC | 6.4-15 |
| Table 6.4-2 | MCR and TSC Doses from Design Basis Accidents..... | 6.4-16 |
| Table 6.4-3 | Amounts of Hazardous Chemicals Stored Onsite | 6.4-17 |
| Table 6.5-1 | Engineered Safety Features Filter Systems – Component Specification | 6.5-24 |

Table 6.2.5-3 Performance Criteria for Depletion Rates of PARs

APR1400 DCD TIER 2

The PARs in the containment and inside the IRWST vent stack, and the HIs in the containment are designed to withstand severe accident conditions. The PARs and HIs provide reasonable assurance that the equipment can perform its identified function during severe accident conditions as described in Section 19.2.

PARs are considered a 15 percent efficiency reduction for iodine vapor and 10 percent efficiency reduction for cable fire. Thus, a total 25 percent efficiency reduction for the PAR was considered for capacity reduction. The HIs include a consideration of the combustion model of the MAAP computer code.

The PARs and HIs are designed to prevent any significant pocketing of hydrogen in order to minimize the potential for localized hydrogen detonation.

The PARs and HIs are able to withstand the effects of their own operations and are designed to provide reasonable assurance that equipment necessary for achieving and maintaining a safe shutdown of the plant and containment integrity are capable of performing their functions during and after their exposure to hydrogen burning.

The PARs and HIs are located throughout the containment open volumes and compartments. The following location criteria are used:

- a. Flow path requirements
- b. Consideration of enclosed spaces
- c. Equipment performance efficiency
- d. Installation and maintenance
- e. Consideration of dynamic effect

For the surveillance test of PARs, a sample of the PAR cartridges or plates is selected and removed from each PAR. Surveillance bench tests are performed on the removed specimens to confirm continued satisfactory performance. The HIs are capable of attaining the surface temperature that is sufficient for igniting hydrogen gases under any environmental conditions including CS actuation. The HI configuration, including possible spray shields, is supported by combustion test data.

The performance criteria for depletion rates of PARs is provided in Table 6.2.5-3.

APR1400 DCD TIER 2

Table 6.2.5-2 (6 of 6)

| Name/Valve No. | Potential Failure Mode | Plant Condition | Symptoms and Local Effect Including Dependent Failure | Method of Detection | Inherent Compensating Provision | Remarks and Other Effects |
|--|-----------------------------|---|---|---|---|--|
| 6. Channel B containment monitor discharge to containment CM-010 | a) Fails to open on demand | Detection of hydrogen in containment building | <ul style="list-style-type: none"> No safety-related impact on plant Isolation is achieved by redundant valve | Valve information: <ul style="list-style-type: none"> Valve position indication in MCR | Isolation is achieved by redundant containment isolation valve (CM-009) | <ul style="list-style-type: none"> Normally closed Fail closed |
| | b) Fails to close on demand | <ul style="list-style-type: none"> Loss of electrical power Receipt of high containment pressure signal Receipt of low pressurizer pressure signal | <ul style="list-style-type: none"> No safety-related impact on plant H₂ monitoring line is formed in the closed loop | | H ₂ monitoring line is formed in the closed loop | |

← add Table 6.2.5-3 in next page

Table 6.2.5-3

Performance criteria for depletion rate of PARs

| Condition Size | Hydrogen concentration 4 v/o (percent by volume) | Hydrogen concentration 8% (percent by volume) |
|-------------------|---|--|
| Small | 0.9 kg/hr | 1.8 kg/hr |
| Medium | 1.8 kg/hr | 3.57 kg/hr |
| Large | 4.01 kg/hr | 8.04 kg/hr |

- 1) This PAR performance criteria uses PAR depletion rate equation from MAAP manual (Reference 43)
- 2) Performance criteria is hydrogen depletion rate at 1.5 bar, 60oC condition, and it also considers the 25%degradation in PAR performance.

APR1400 DCD TIER 2

39. ASME Section III, Division 1, Article NE 2300, "Fracture Toughness Requirements for Material," The American Society of Mechanical Engineers.
40. NUREG-0800, Section 6.2.1.2, "Subcompartment Analysis," Rev. 3, U.S. Nuclear Regulatory Commission, March 2007.
41. NRC RG 1.141, "Containment Isolation Provisions for Fluid Systems."
42. APR1400-E-P-NR-14003-P(Proprietary)&NP(Non-Proprietary) "Severe Accident Analysis Report," Rev. 1 KHNP, February 2017.

43. FAI/12-0005, "MAAP 4.0.8 Transmittal Document," Electric Power Research Institute, February 2012.

APR1400 DCD TIER 1

Table 2.11.4-1

Containment Hydrogen Control System Components List

| Component Name | Item No. | Location ⁽⁴⁾ | ASME Section III Class | Seismic Category | Class 1E/Harsh Envir. Qual. | Display/Control at MCR | Display/Control at RSR | Control Signal | Active Safety Function | Loss of Motive Power Position |
|----------------------------------|-----------------------|-------------------------|------------------------|------------------|-----------------------------|------------------------|------------------------|----------------|------------------------|-------------------------------|
| Passive Autocatalytic Recombiner | HR01A/01B ~ HR15A/15B | Containment | - | I | -/- | -/- | -/- | - | No | - |
| Hydrogen Igniter | HI01 ~ HI08 | Containment | - | I | No/- | Yes/Yes | Yes/Yes | - | No | - |
| Containment Temperature Element | CM-TE-031A | Containment | - | I | Yes/Yes | Yes/No | Yes/No | - | No | - |

(1) ~~Location of PARs and His are provided in DCD Tier 2, Table 6.2.5-1~~

(2) Dash (-) indicates not applicable.

Deleted