



**Global Nuclear Fuel**

A Joint Venture of GE, Toshiba, & Hitachi

**Global Nuclear Fuel**

**Scott P. Murray**  
Manager, Facility Licensing

3901 Castle Hayne Road  
P.O. Box 780  
Wilmington, NC 28402  
USA

T (910) 819-5950  
scott.murray@ge.com

M170210

August 23, 2017

Attn: Document Control Desk  
Director, Office of Nuclear Material Safety and Safeguards  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Subject: GNF-A Semi-Annual Effluent Monitoring Report

References: 1) NRC License SNM-1097, Docket 70-1113  
2) NRC Regulation 10CFR70.59

Dear Sir or Madam:

With respect to activities authorized by NRC License SNM-1097, the Global Nuclear Fuel-Americas, L.L.C. (GNF-A) facility in Wilmington, North Carolina hereby submits the semi-annual effluent monitoring report required by 10CFR70.59 for the time period of January through June 2017.

If you have any questions regarding this matter, please contact me at (910) 819-5950.

Sincerely,

  
Scott Murray, Manager  
Facility Licensing

Commitments: None

Attachment: 1) Semi-Annual Effluent Monitoring Report (January- June 2017)

cc: NRC Region II Administrator, Atlanta, GA  
T. Vukovisky, USNRC, RII  
T. Naquin, USNRC, NMSS  
L. Cox, NCDHHS  
M. Poirier, ANI  
SPM 17-034

## SEMI-ANNUAL EFFLUENT REPORT

Global Nuclear Fuel - Americas, LLC  
 Wilmington, North Carolina

January 2017 - June 2017

NRC License SNM 1097, Docket # 70-1113

Fiscal Weeks 1-26

### I. GASEOUS EFFLUENT-PARTICULATE

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	* APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE mrem	CDE (Lung) mrem
U234	7.09E-06	3.76E-15	5 E-12	0.08%	1.88E-02	1.58E-01
U235	2.90E-07	1.53E-16	6 E-12	0.00%	6.44E-04	5.37E-03
U236	1.78E-09	9.44E-19	6 E-12	0.00%	3.96E-06	3.30E-05
U238	9.75E-07	5.16E-16	6 E-12	0.01%	2.17E-03	1.81E-02
<b>TOTAL</b>	<b>8.36E-06</b>	---	---	---	<b>0.0216</b>	<b>0.181</b>

**EXHAUST VOLUME =** 1.89E+15 (cc)

### II. LIQUID EFFLUENT

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	* APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE (mrem)	CDE (Lung) (mrem)	CDE (Bone Surface) (mrem)
U234	3.33E-03	1.57E-08	3 E-07	5.23%	1.15E-06	7.22E-07	1.66E-05
U235	1.36E-04	6.41E-10	3 E-07	0.21%	6.66E-08	4.23E-08	9.66E-07
U236	8.38E-07	3.94E-12	3 E-07	0.00%	2.72E-10	1.74E-10	3.95E-09
U238	4.58E-04	2.16E-09	3 E-07	0.72%	1.42E-07	9.06E-08	2.06E-06
<b>TOTAL U</b>	<b>3.93E-03</b>	---	---	---	<b>1.36E-06</b>	<b>8.55E-07</b>	<b>1.97E-05</b>

**TOTAL VOLUME OF LIQUID EFFLUENT =** 2.12E+08 (litres)

### III. ABNORMAL RELEASES

	Air	Water	Total
# Releases	0	0	0
Activity Released (Ci)	0	0	0

### IV. SUMMARY

	** Max Release (uCi/cc)	CEDE, total (mrem)	CDE (Lung), total (mrem)
Value	1.57E-08	2.16E-02	1.81E-01
Limit	3.00E-07	25	25
% of Limit	5.23%	0.09%	0.72%

\* Limit from 10 CFR 20 Appendix B, Table 2, Columns 1 and 2. Air limit adjusted to reflect NRC License SNM-1097, Section 1.3.9.

\*\* From nuclide with release that is the largest percentage of its release limit.

#### NOTES:

Air sampling is continuous. Water samples analyzed are representative, continuous composite samples of the process effluent stream.  
 Reported effluent concentration values are representative of the effluent concentration at the point of release and do not consider effects of dilution from point of release to the plant site boundary.