



Clinton Power Station  
8401 Power Road  
Clinton, IL 61727

U-604372

August 23, 2017

US Nuclear Regulatory Commission  
ATTN: Document Control Center  
Washington, DC 20555-0001

Clinton Power Station, Unit 1  
Facility Operating License No. NPF-62  
NRC Docket No. 50-461

Subject: Notification of Intention Regarding Inspection Report 05000461/2017009 and Preliminary White Finding (EA-17-098)

Reference: Letter from Patrick L. Loudon (NRC) to Bryan C. Hanson (EGC), "Clinton Power Station – NRC Inspection Report 05000461/2017009 and Preliminary White Finding [EA-17-098]," dated August 14, 2017 (ADAMS Accession No. ML17226A321)

In the referenced letter, the NRC documented a finding concerning the failure to evaluate the change in the actual drop out voltages for replacement relays associated with the Division 1 Emergency Diesel Generator (EDG) Room Vent Fan which has been preliminarily determined to be a White finding with low to moderate safety significance.

The referenced letter requested verbal and written notification within ten days of the date of the letter stating Exelon Generation Company, LLC's (EGC) intention to communicate EGC's position on the facts and assumptions used to arrive at the finding and assess its significance by either (1) requesting a Regulatory Conference to meet with the NRC and provide EGC's views in person; or (2) submit EGC's position on the finding in writing. On August 23, 2017, Mr. Bradley Kapellas discussed with Ms. Karla Stoedter, of the NRC, EGC's choice to submit a written response on this matter. This letter provides the written notification that EGC will submit a written response within 40 days of the receipt of the referenced letter.

There are no regulatory commitments contained in this letter. If you have any questions, please contact Mr. Dale A. Shelton, Regulatory Assurance Manager, at (217) 937-2800.

U-604372  
U.S. Nuclear Regulatory Commission  
Page 2

Respectfully,

A handwritten signature in blue ink, appearing to read "T. Stoner", with a stylized flourish at the end.

Theodore R. Stoner  
Site Vice President  
Clinton Power Station

cc: Ms. Karla Stodter, Chief, Branch 1, Division of Reactor Projects - NRC Region III  
NRC Project Manager, NRR – Clinton Power Station  
NRC Senior Resident Inspector - Clinton Power Station