

**Distribution:**

1. Boyer, Robert P
2. Gardner, Troy R
3. Howell, Pamela T
4. Mc Ginnis, Vickie L
5. OPS HUMAN PERFORMANCE -
6. OPS TRNG MGR.
7. QATS-
8. RESIDENT NRC INSPECT
9. SERV BLDG FILE ROOM -
10. U S NUC REG WASHINGTON, DC ✓
11. USNRC
12. WESTINGHOUSE ELECTRIC CO LLC

## Duke Energy DOCUMENT TRANSMITTAL FORM

Facility: **MCGUIRE NUCLEAR STATION**  
SUBJECT  
**Technical Specification Changes - Amendment Nos.296/275**

Page 1 of 1

Date: **8/17/2017**

Document Transmittal #: **TR-NUC-MC-006874**

Purpose: **Issue**

Released By:

**Duke Energy**  
**13225 Hagers Ferry Road**  
**Document Management**  
**MG02DM**  
**Huntersville, NC 28078**  
**MNSDCRM@duke-energy.com**

Document ID	1	2	3	4	5	6	7	8	9	10	11	12
LICN - MC - MNS-TS-3.6.10 - 001 - ISSUED	FYI E	FYI E	FYI E	FYI E	FYI E	R&A E	FYI E	PRINT LP	FYI E	R&A E	R&A E	R&A E
LICN - MC - MNS-TS-3.7.9 - 002 - ISSUED	FYI E	FYI E	FYI E	FYI E	FYI E	R&A E	FYI E	PRINT LP	FYI E	R&A E	R&A E	R&A E

Remarks:

*ADD  
NRR*

3.6 CONTAINMENT SYSTEMS

3.6.10 Annulus Ventilation System (AVS)

LCO 3.6.10 Two AVS trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One AVS train inoperable.	A.1 Restore AVS train to OPERABLE status.	7 days
B. One or more AVS train(s) heater inoperable.	B.1 Restore AVS train(s) heater to OPERABLE status.	7 days
	<u>OR</u> B.2 Initiate action in accordance with Specification 5.6.6.	7 days
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3.	6 hours
	<u>AND</u> C.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.10.1 Operate each AVS train for $\geq 15$ continuous minutes.	In accordance with the Surveillance Frequency Control Program
SR 3.6.10.2 Perform required AVS filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with the VFTP
SR 3.6.10.3 Verify each AVS train actuates on an actual or simulated actuation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.6.10.4 Verify each AVS filter cooling bypass valve can be opened.	In accordance with the Surveillance Frequency Control Program
SR 3.6.10.5 Verify each AVS train flow rate is $\geq 7200$ cfm and $\leq 8800$ cfm.	In accordance with the Surveillance Frequency Control Program

3.7 PLANT SYSTEMS

3.7.9 Control Room Area Ventilation System (CRAVS)

LCO 3.7.9 Two CRAVS trains shall be OPERABLE.

-----NOTE-----

The control room envelope (CRE) boundary may be opened intermittently under administrative control.

-----

APPLICABILITY: MODES 1, 2, 3, 4, 5, and 6,  
During movement of irradiated fuel assemblies,  
During CORE ALTERATIONS.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CRAVS train inoperable for reasons other than Condition B.	A.1 Restore CRAVS train to OPERABLE status.	7 days*
B. One or more CRAVS trains inoperable due to inoperable CRE boundary in MODE 1,2,3, or 4.	B.1 Initiate action to implement mitigating actions.	Immediately
	<u>AND</u>	24 hours
	B.2 Verify mitigating actions ensure CRE occupant exposures to radiological, chemical, and smoke hazards will not exceed limits.	
	<u>AND</u>	90 days
	B.3 Restore CRE boundary to OPERABLE status.	
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, 3, or 4.	C.1 Be in MODE 3.	6 hours
	<u>AND</u> C.2 Be in MODE 5.	36 hours (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. Required Action and associated Completion Time of Condition A not met in MODE 5 or 6, or during movement of irradiated fuel assemblies, or during CORE ALTERATIONS.</p>	<p>D.1 Place OPERABLE CRAVS train in emergency mode.</p> <p><u>OR</u></p> <p>D.2.1 Suspend CORE ALTERATIONS.</p> <p><u>AND</u></p> <p>D.2.2. Suspend movement of irradiated fuel assemblies.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p>
<p>E. Two CRAVS trains inoperable in MODE 5 or 6, or during movement of irradiated fuel assemblies, or during CORE ALTERATIONS.</p> <p><u>OR</u></p> <p>One or more CRAVS trans inoperable due to an inoperable CRE boundary in MODE 5 or 6, or during movement of irradiated fuel assemblies, or during CORE ALTERATIONS.</p>	<p>E.1 Suspend CORE ALTERATIONS.</p> <p><u>AND</u></p> <p>E.2 Suspend movement of irradiated fuel assemblies.</p>	<p>Immediately</p> <p>Immediately</p>
<p>Two CRAVS trains inoperable in MODE 1, 2, 3, or 4 (for reasons other than Condition B).</p>	<p>F.1 Enter LCO 3.0.3.</p>	<p>Immediately</p> <p>(continued)</p>

CONDITION	REQUIRED ACTION	COMPLETION TIME
G. One or more CRAVS train(s) heater inoperable.	G.1 Restore CRAVS train(s) heater to OPERABLE status.	7 days
	OR G.2 Initiate action in accordance with Specification 5.6.6.	7 days

-----NOTE-----

\* 'A' Train CRAVS is allowed to be inoperable for a total of 14 days for the correction of a degraded condition on the 'A' Train supply piping from the Standby Nuclear Service Water Pond (SNSWP). The 14 days may be taken consecutively or in parts until completion of the activity, or by March 1, 2017, whichever occurs first. During the period in which the 'A' Train NSWS supply piping from the SNSWP is not available, the 'A' Train NSWS will remain aligned to Lake Norman until the system is ready for post maintenance testing. Any maintenance that is performed on the remaining portions of 'A' Train NSWS during the period in which the 'A' NSWS from the SNSWP supply piping is not available will be limited to a 72 hour completion time. The latter will not count against the 14 day completion time. Allowance of the extended Completion Time is contingent on meeting the Compensatory Measures and Commitments as described in MNS LAR submittal correspondence letter MNS-16-005.

**SURVEILLANCE REQUIREMENTS**

SURVEILLANCE	FREQUENCY
SR 3.7.9.1 Operate each CRAVS train for $\geq 15$ continuous minutes.	In accordance with the Surveillance Frequency Control Program
SR 3.7.9.2 Perform required CRAVS filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with the VFTP
SR 3.7.9.3 Verify each CRAVS train actuates on an actual or simulated actuation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.7.9.4 Perform required CRE unfiltered air inleakage testing in accordance with the Control Room Envelope Habitability Program.	In accordance with the Control Room Envelope Habitability Program