

MAR 27 1974

Docket Nos. 50-237 and 50-249

Distribution
Docket Files

AEC PDRs
Local PDR
Branch Reading
JRBuchanan, ORNL
DJSkovholt, L:OR
TJCarter, L:OR
ACRS (16)
RO (3)
OGC
DLZiemann, L:ORB #2
RDSilver, L:ORB #2
RMDiggs, L:ORB #2
SVarga, L:RP
J. R. Ireland, L:ORB #2

Commonwealth Edison Company
ATTN: Mr. J. S. Abal
Nuclear Licensing Administrator -
Boiling Water Reactors
Post Office Box 767
Chicago, Illinois 60690

Gentlemen:

By letter dated March 11, 1974, you requested approval of modifications and technical specification changes concerning a switch for post-isolation bypass of isolation signals for certain containment isolation valves. To proceed with our review, we require a description, electrical diagram, and a single failure analysis of the proposed installation to assure that the modification is in conformance with IEEE-279. Your reply should be submitted with one signed original and thirty-nine additional copies.

Sincerely,

Original signed by
Dennis L. Ziemann

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Directorate of Licensing

cc: John W. Rowe, Esquire
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza
Chicago, Illinois 60670

Anthony Z. Roisman, Esquire
Berlin, Roisman and Kessler
1712 N Street, N. W.
Washington, D. C. 20036

Morris Public Library

App'l.

OFFICE >	L:ORB #2	L:ORB #2				
X7403 SURNAME >	RDSilver:sh	DLZiemann				lh
DATE >	3/27/74	3/27/74				