



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TELEPHONE
(312) 858-2660

REGULATORY OPERATIONS, REGION III

A. RO Inspection Report No. _____

Transmittal Date : _____

Distribution:

RO Chief, RT&OB or RO Chief, RCB
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:

RO Chief, M&FFB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files

B. RO Inquiry Report No. _____

Transmittal Date : _____

Distribution:

RO Chief, RT&OB or RO Chief, RCB (2)
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:

RO Chief, M&FFB
RO:HQ
DR Central Files

C. Incident Notification From: Commonwealth Edison DPR-25 50-249
(Licensee & Docket No. (or License No.))

Transmittal Date : April 13, 1973

Distribution:

RO Chief, RT&OB or RO Chief, RCB
RO:HQ (4)
Licensing (4)
DR Central Files

Distribution:

RO Chief, M&FFB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files



Telegram

1973 APR 10

EF

BOOK & GIFT SHOP
MORRIS ILL

APR 10 CFN FURN

530P

PBD

BOYCE GRIER
DIRECTOR DIVISION OF COMPLIANCE
REGION 3

U S ATOMIC ENERGY COMMISSION

WUX

799 ROOSEVELT ROAD
GLEN ELLYN ILL 60137

A GIAMBUSSO
DIRECTOR FOR REACTOR PROJECTS
DIRECTORATE OF LICENSING
U S ATOMIC ENERGY COMMISSION
WUX
WASHINGTON D C 20545

114

APR 13 1973

TELEGRAMS (OTHER THAN MONEY ORDERS)
 IS PHYSICAL DELIVERY requested? _____ (YES-AGENT, NO-ADDRESSEE)
 AGENT SECTION
 Nbr. & Name 312 858 2660 ADDRESS SECTION
 Date dtd 4-11 Time of 8:53A
 To be mailed or filed 592 By JM
 Attempts to deliver (Indicate DA or SX)

WU 1201 (R 5-69)

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3

THIS WILL CONFIRM A CONVERSATION WITH MR MAURA OF YOUR OFFICE AT 1445 HOURS THIS DATE CONCERNING DRIFT OF MAIN STEAM LINE LOW PRESSURE SWITCH PFL-3-261-30A WHICH DRIFTED BELOW TECHNICAL SPECIFICATION SETTING OF 850 POUNDS TO 816 POUNDS. SWITCH RESET TO 872 POUNDS AND PLAN TO REPLACE THIS BARKSDALE B2T-A12SS SWITCH IN NEAR FUTURE. REACTOR WAS IN REFUEL AT THE TIME AND SWITCH FUNCTION WAS NOT REQUIRED. LAST SUCCESSFUL CHECK 2-13-73.

BILL DIRECT TO SENDER:
DRESDEN NUCLEAR POWER STATION
ROUTE 1
MORRIS ILL 60450
PHONE 815-942-2920
114

W P WORDEN
SUPERINTENDENT
DRESDEN NUCLEAR POWER STATION

WU 1201 (R 5-69)