

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9908110208 DOC. DATE: ~~99/07/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 ROGERS, J.A. Florida Power & Light Co.
 STALL, J.A. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: ~~Monthly operating repts~~ for Jul 1999 for St Lucie Units 1 &
 2. With 990805 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 7
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	GLEAVES, W	1	1			
INTERNAL:	ACRS	1	1	<u>FILE CENTER 01</u>	1	1
	OC/DBA/PAD	1	1	RES/DRAA/OERAB	1	1
	RGN2	1	1			
EXTERNAL:	LMITCO MARSHALL	1	1	NOAC	1	1
	NRC PDR	1	1			

RECEIVED

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

MR



Florida Power & Light Company, 6501 South Ocean Drive, Jensen Beach, FL 34957

August 5, 1999

L-99-177
10 CFR 50.36
10 CFR 50.4

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Re: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Monthly Operating Report

Pursuant to Technical Specification 6.9.1.6 and the guidance of Generic Letter 97-02, attached are the July 1999 Operating Data Reports, Summary of Operating Experience Reports, and Unit Shutdowns and Power Reductions for St. Lucie Units 1 and 2.

Please contact us should there be any questions regarding this information.

Very truly yours,

J. A. Stall
Vice President
St. Lucie Plant

JAS/tlt

Attachments

cc: Regional Administrator, USNRC, Region II
Senior Resident Inspector, USNRC, St. Lucie Plant

1/1
IB24

9908110208 990731
PDR ADDCK 05000335
R PDR

18001

DOCKET NO 50 - 335
UNIT NAME ST. LUCIE UNIT 1
DATE 08/03/99
COMPLETED BY J. A. ROGERS
TELEPHONE 561/467/7296

REPORTING PERIOD: JULY 1999

1. Design Electrical Rating (Mwe-Net)_____ 830
2. Maximum Dependable Capacity (Mwe-Net)___ 839

	MONTH	-YTD-	CUMULATIVE
3. Number of Hours Reactor Critical _____	744	5087	157056.5
4. Number of Hours Generator On Line _____	744	5087	155420.7
5. Unit Reserve Shutdown Hours _____	0.0	0.0	0.0
6. Net Electrical Energy (MWH) _____	632072	4338977	126259515

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.: 50-335
UNIT: St. Lucie #1
DATE: Aug. 3, 1999
COMPLETED BY: J.A.ROGERS
TELEPHONE: (561) 467-7296

REPORT MONTH July 1999

Unit 1 operated at essentially full power for the entire month of July.

In accordance with the requirements of Technical Specification 6.9.1.6, there were no challenges to the power operated relief valves or the safety valves during the report period.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.: 50-335
 UNIT: St. Lucie #1
 DATE: Aug. 3, 1999
 COMPLETED BY: J.A. ROGERS
 TELEPHONE: (561) 467-7296

REPORT MONTH July 1999

Number	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor 3	Cause & Corrective Action to Prevent Recurrence
						Unit 1 operated at essentially full power for the entire month of July.

¹
 F Forced
 S Scheduled

²
 Reason
 A - Equipment failure (explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

³
 Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

DOCKET NO 50 - 389
 UNIT NAME ST. LUCIE UNIT 2
 DATE 08/03/99
 COMPLETED BY J. A. ROGERS
 TELEPHONE 561/467/7296

REPORTING PERIOD: JULY 1999

1. Design Electrical Rating (Mwe-Net)_____	830		
2. Maximum Dependable Capacity (Mwe-Net)___	839		
	MONTH	-YTD-	CUMULATIVE
3. Number of Hours Reactor Critical_____	744	4919.6	120219.3
4. Number of Hours Generator On Line_____	744	4910.7	118561.4
5. Unit Reserve Shutdown Hours_____	0.0	0.0	0.0
6. Net Electrical Energy (MWH)_____	633951	4088983	97094827

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.: 50-389
UNIT: St. Lucie #2
DATE: Aug. 3, 1999
COMPLETED BY: J.A.ROGERS
TELEPHONE: (561) 467-7296

REPORT MONTH July 1999

Unit 2 operated at essentially full power for the entire month of July.

In accordance with the requirements of Technical Specification 6.9.1.6, there were no challenges to the power operated relief valves or the safety valves during the report period.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.: 50-389
 UNIT: St. Lucie #2
 DATE: Aug. 3, 1999
 COMPLETED BY: J.A. ROGERS
 TELEPHONE: (561) 467-7296

REPORT MONTH July 1999

Number	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
						Unit 2 operated at essentially full power for the entire month of July.

1
 F Forced
 S Scheduled

2
 Reason
 A - Equipment failure (explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3
 Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)