

A017

REGULATORY INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 50-244 RE GINNA 1
RECIPIENT: ZIEMANN, D.L.
ORIGINATOR: WHITE, L.D.
COMPANY: ROCHESTER GAS & ELEC

DOC DATE: 781103
ACCESSION NBR: 7811130232
COPIES RECEIVED:
LTR 1 ENCL 0
SIZE: 1

SUBJECT: Notifies that Provisional Oper Lic #DPR-18 issued on 780328 omitted Tech Specs for piping penetrations w/ expansion bellows. Leakage testing w/air medium is not req for containment penetration sys.

DISTRIBUTION CODE: A017

DISTRIBUTION TITLE:

CONTAINMENT LEAK RATE TESTING-APPENDIX J.

NOTARIZED


NAME	ENCL?	FOR ACTION
BR CHIEF	W/7 ENCL	ORB#2 BC
REG FILE	W/ENCL	
NRC PDR	W/ENCL	
I & E	W/2 ENCL	
OELD	W/ENCL	
HANAUER	W/ENCL	
CONTAINMENT SYSTEMS	W/ENCL	
AD FOR SYS & PROJ	W/ENCL	
ENGINEERING BR	W/ENCL	
REACTOR SAFETY BR	W/ENCL	
PLANT SYSTEMS BR	W/ENCL	
EEB	W/ENCL	
M FAIRTILE	W/ENCL	
EFFLUENT TREAT SYS	W/ENCL	
LPDR	W/ENCL	
TERA	W/ENCL	
NSIC	W/ENCL	
ACRS	W/16 ENCL	

TOTAL NUMBER OF COPIES REQUIRED:

LTR 40
ENCL 40

NOV 14 1978

NOTES:





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700



November 3, 1978

Director of Nuclear Reactor Regulation
ATTN: Mr. Dennis L. Ziemann, Chief
Operating Reactors Branch #2
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

REGULATORY DOCKET FILE COPY

Dear Mr. Ziemann:

Amendment 17 to Provisional Operating License No. DPR-18 issued on March 28, 1978 included containment leakage test requirements for certain containment penetrations. Due to an oversight no requirements were included for piping penetrations with expansion bellows even though there are penetrations of this type at R.E. Ginna. Testing of these penetrations has been regularly performed in the past and will continue to be tested as required by Appendix J to 10 CFR Part 50. A technical specification will be proposed at a convenient time to specifically include these requirements.

In a letter dated September 21, 1978 Rochester Gas and Electric committed to modify the piping of eight containment penetrations. The modifications are to provide the capability to drain fluid away from containment isolation valves and assure exposure of the valves to containment air test pressure during leakage testing of those systems which may be open to the containment atmosphere under post-accident conditions. However, leakage testing of the containment spray system isolation valves will continue to be performed with water on the valves in accordance with section III.C.2 of Appendix J to 10 CFR Part 50. This system is normally filled with water and will be operating under post-accident conditions. In addition seal water is provided by the residual heat removal system, which has a discharge head of 120 psig and is capable of maintaining the fluid pressure at the valves in excess of the containment pressure. A thirty day supply of water is assured by recycling containment sump water through the containment spray system piping back to the containment. Therefore leakage testing with an air medium is not required for this system.

Sincerely yours,

L.D. White, Jr.
L. D. White, Jr.

REGULATORY DOCKET FILE COPY

AP 17
1/10

7811190232

081107