

ACCESSION NBR: 7908090510      DATE: 79/08/03      NOTARIZED  NO      DOCKET #  
 FACIL: 50-244 Robert. Emmet Ginna Nuclear Plant, Unit 1, Rochester G      05000244  
 AUTH. NAME      AUTHOR AFFILIATION  
 FARON, R.S.      LeBoeuf, Lamb, Leiby & MacRae  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
 ZIEMANN, D.L.      Operating Reactors Branch 2

SUBJECT: Forwards util 790731 response to NRC 790712 request re undervoltage protection. Requests info be withheld (ref 10CFR2.790).

DISTRIBUTION CODE: A001S      COPIES RECEIVED: LTR 1 ENCL 7 SIZE: 2+16  
 TITLE: GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LIC

NOTES: LCY: J. SHAPAKER, C. HOFMAYER. NO AFFIDAVIT REC'D.

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	L	ENCL	ID CODE/NAME	L	ENCL
ACTION:	05 BC ORB #2	7	7			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	12 I&E	2	2	14 TA/EDO	1	1
	15 CORE PERF BR	1	1	16 AD SYS/PROJ	1	1
	17 ENGR BR	1	1	18 REAC SFTY BR	1	1
	19 PLANT SYS BR	1	1	20 EEB	1	1
	21 EFLT TRT SYS	1	1	22 BRINKMAN	1	1
	OELD	1	0			
EXTERNAL:	03 LPDR	1	X	04 NSIC	1	X
	23 ACRS	16	16			

DIST. PER H. SMITH.

LCY ONLY


ENCL TO: S. RHOW #2  
 J. SHEA #3  
REG FILE #1  
 H. SMITH (EXTRA CYS) #5-7  
 TERA - #4

NSIC  
 LPDR

TT24  
 CC

AUG 14 1979

TOTAL NUMBER OF COPIES REQUIRED: LTR 41 ENCL 36 <sup>42</sup>



LEBOEUF, LAMB, LEIBY & MACRAE

1333 NEW HAMPSHIRE AVENUE, N. W.

WASHINGTON, D. C. 20036

TELEPHONE 202-457-7500

CABLE ADDRESS

LEBWIN, WASHINGTON, D. C.

TELEX: 440274

TELECOPIER:

202-457-7543

RANDALL J. LeBOEUF, JR. 1929-1975

HORACE R. LAMB 1934-1977

ADRIAN C. LEIBY 1952-1976

140' BROADWAY

NEW YORK, N. Y. 10005

TELEPHONE 212-269-1100

CABLE ADDRESS

LEBWIN, NEW YORK


TELEX: 423416

47 BERKELEY SQUARE

LONDON W1X 5DB, ENGLAND

TELEPHONE 01-493-7331

TELEX: 25955



LEON A. ALLEN, JR.  
JOSEPH E. BACHELDER, III  
ERNEST S. BALLARD, JR.  
G. S. PETER BERGEN  
GEOFFRY D. C. BEST  
DAVID P. BICKS  
TAYLOR R. BRIGGS  
CHARLES N. BURGER  
THOMAS E. BURKE  
JOHN B. CHASE  
ROGER D. FELDMAN  
EUGENE R. FIDELL  
JACOB FRIEDLANDER  
GERARD GIORDANO  
DONALD J. GREENE  
JAMES A. GREER, II  
JOHN L. GROSE  
DOUGLAS W. HAWES  
CARL D. HOBELMAN  
MICHAEL IOVENKO  
JAMES F. JOHNSON, 4TH  
RONALD D. JONES  
JAMES A. LAPENN  
LEX K. LARSON  
GRANT S. LEWIS  
KIMBA W. LOVEJOY

CAMERON F. MACRAE  
CAMERON F. MACRAE, III  
GERARD A. MAHER  
SHEILA H. MARSHALL  
JAMES G. McELROY  
JAMES P. McGRANERY, JR.  
PHILIP PALMER McGUIGAN  
E. ELLSWORTH McMEEN, III  
WILLIAM D. MORRISON  
HARVEY A. NAPIER  
JAMES O'MALLEY, JR.  
J. MICHAEL PARISH  
JOHN C. RICHARDSON  
WILLIAM W. ROSENBLATT  
JOHN A. RUDY  
PATRICK J. SCOGNAMIGLIO  
HAROLD M. SEIDEL  
HALCYON G. SKINNER  
JOSEPH S. STRAUSS  
SAMUEL M. SUGDEN  
EUGENE B. THOMAS, JR.  
LEONARD M. TROSTEN  
HARRY H. VOIGT  
H. RICHARD WATCHEL  
GERARD P. WATSON  
THOMAS A. ZIERK

- \* RESIDENT PARTNERS WASHINGTON OFFICE
- \* RESIDENT PARTNERS LONDON OFFICE
- \* ADMITTED TO THE DISTRICT OF COLUMBIA BAR

August 3, 1979

Director of Nuclear Reactor Regulation  
Attention: Mr. Dennis L. Ziemann, Cheif  
Operating Reactors Branch No. 2  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Undervoltage Protection  
RG&E Ginna Nuclear Power Plant  
Docket 50-244

Dear Mr. Ziemann:

As Counsel for Rochester Gas & Electric Corporation we enclose the following letter (including 3 copies for your convenience) in response to your letter of July 12, 1979 concerning Undervoltage Protection at the RG&E Ginna Nuclear Power Plant. It is accompanied by Figure 1, "A Single Line Diagram Train A for Existing Undervoltage System," and Enclosure A, "The Ongoing Evaluation of Safety System Integrity," which the licensee has requested be treated as proprietary and be withheld from public disclosure in accordance with the applicable rules and regulations of the Commission. The request is submitted by affidavit of Mr. L. D. White, Jr., Vice President, Electric and System Production, Rochester Gas and Electric Corporation.

This material is proprietary as it contains trade secrets and commercial information held in confidence by its owner, Rochester Gas and Electric Corporation, is information

Dist Per  
H. Smith  
8/8/79

Note: "No Affidavit Rec'd"

Appl  
S 1/7 7908090510

Encl To  
S. Rhov  
J. Shea  
Reg File  
H. Smith (Extra Cys)



1  
2  
3

THE  
UNITED STATES  
DEPARTMENT OF THE INTERIOR  
BUREAU OF LAND MANAGEMENT

WATER RESOURCES  
DIVISION  
SALT LAKE CITY, UTAH

WATER RESOURCES  
DIVISION  
SALT LAKE CITY, UTAH

WATER RESOURCES  
DIVISION  
SALT LAKE CITY, UTAH

WATER RESOURCES  
DIVISION  
SALT LAKE CITY, UTAH

of the type customarily held in confidence by its owner due to its unique nature; has been transmitted to us and to you in confidence; it not generally available in public sources; and the public disclosure of which would cause substantial harm to the competitive position of the owner, Rochester Gas and Electric in that it has high commercial value developed with substantial expenditures of effort and money by its owner which could not be easily duplicated by others.

Therefore, pursuant to 10 C.F.R. Section 2.790 of the Commissions Rules of Practice and Part 9.5 of the Commissions Regulations, we request that the enclosed Figure 1 and Enclosure A be withheld from public disclosure.


Very truly yours,



Robert S. Faron

LeBOEUF, LAMB, LEIBY & MacRae  
Attorneys for Rochester Gas  
and Electric Corporation

Enclosures





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELEPHONE  
AREA CODE 716 546-2700

July 31, 1979

Director of Nuclear Reactor Regulation  
Attention: Mr. Dennis L. Ziemann, Chief  
Operating Reactors Branch No. 2  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Undervoltage Protection  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Ziemann:


In response to your letter of July 12, 1979, the following letter is submitted.

Question 1. Provide the voltage setpoint trip and time delay and the tolerance on the 4160 volt side for the second level voltage protection monitors in the Technical Specification.

Response: As shown on the enclosed single line for train A (from our submittal of May 1, 1978), the undervoltage load shedding and sequencing system is entirely at the 480V level. Since there are no 4160V safety related loads, there are no undervoltage protection monitors for the load shedding and sequencing system at that level.

Question 2. State the operating modes, total number of channels, and number of channels to trip on the under-voltage degradation protection system. Refer to Table 3.3-3, NRC letter, "Safety Evaluation and Statement of Staff Positions Relative to the Emergency Power Systems For Operating Reactors," June 2, 1977. Describe the coincident logic used.

Response: The operating modes, total number of channels, and number of channels to trip are described in our Application for Amendment to Operating License is enclosed with this response. The coincident logic used in this design is described in our submittal to you, dated July 24, 1979, under the subject "Amendments to Prior Design Modifications on Undervoltage Protection Systems."





DATE July 31, 1979

TO Mr. Dennis L. Ziemann, Chief

2

Question 3. State the channel check frequency. Describe more fully the bases for performing the channel functional tests monthly. Give the operating modes in which surveillance is required.

Response: The subject undervoltage monitoring system does not supply inputs to either the Reactor Protection System, or the Safeguards Actuation System and therefore is subject to checks associated with those systems. Our enclosed Application for Amendment to Operating License as well as our submission to you dated December 22, 1977, describes the simulation of loss of voltage and degraded voltage to be performed during refueling shutdowns. The system reliability of the proposed design has been analyzed and the sensitivity to variation in component reliability is considered. This analysis (Enclosure A of this attachment) assumes an approximate one year interval between functional tests.

Question 4. Describe the extent to which the design of the voltage monitors of the second-level protection meet IEEE Std. 279-1971.

Response: The applicability of IEEE Std. 279-1971 to this system is discussed in Section 6.6 of our submission to you dated July 21, 1977, under the subject "Design Analysis for the Addition of a Second Level of Undervoltage Protection."

Pursuant to Section 2.790 of the Commission's Rules of Practice and Part 9.5 of the Commission's Regulations, we request that the enclosed Figure 1 and Enclosure A be withheld from public disclosure.

Very truly yours,



L. D. White, Jr.

Subscribed and sworn to before me  
on this 31<sup>st</sup> day of July 1979.



ROSE MARIE PERRONE  
NOTARY PUBLIC, State of N. Y., Monroe County  
My Commission Expires March 30, 1982.





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

MEMORANDUM FOR: TERA Corp.  
FROM: US NRC/TIDC/Distribution Services Branch  
SUBJECT: Special Document Handling Requirements



1. Please use the following special distribution list for the attached document.

Ltr Only  
NSIC  
LPOR



2. The attached document requires the following special considerations:

- Do not send oversize enclosure to the NRC PDR.
- Only one oversize enclosure was received - please return for Regulatory File storage.
- Proprietary information - send <sup>Ltr</sup> affidavit only to the NRC PDR
- Other: (specify)

TIDC/DSB Authorized Signature

cc: DSB Files

DOCKET NO. 50-244

DATE: 8-10-79

NOTE TO NRC AND/OR LOCAL PUBLIC DOCUMENT ROOMS

The following item submitted with letter dated 8-3-79  
from LeBOEUF, Lamb, Leiby + MacRae is being withheld from public  
disclosure in accordance with Section 2.790.


PROPRIETARY INFORMATION

Fig. 1 + ENCL. A dealing with SAFETY  
System Integrity

Dou Paulson  
016

Distribution Service's Branch

480V 3 $\phi$ -60 ~ BUS N $\phi$  1A



THIS REPORT CONTAINS  
 PROPRIETARY INFORMATION  
 AND SHALL NOT BE RELEASED  
 IN WHOLE OR IN PART EXCEPT  
 WITH THE WRITTEN PERMISSION  
 OF ROCHESTER GAS AND  
 ELECTRIC CORPORATION.

480V 3 $\phi$ -60 ~ BUS N $\phi$  1B




FIG. 1 SINGLE LINE DIAGRAM TRAIN A  
 EXISTING UNDERVOLTAGE SYSTEM



ENCLOSURE A

Ongoing Evaluation of Safety System Integrity

I Introduction

It is the purpose of this analysis to provide a methodology for ongoing review and assessment of Safety System integrity. This methodology is based on detailed review of the system design coupled with the results of plant specific and industry operating experience and test results as they become available during the operating life of the plant.

The most suitable figure of merit for this type of analysis is the system availability, as defined in IEEE Std. 352-1975. Availability, unlike reliability, is time invariant and allows for failure and subsequent repair of individual components.

As will be shown for the Load Shedding and Sequencing System below, it is imperative to establish not only a "best estimate" of availability from the most current data, but to also determine the "sensitivity" of this figure of merit to the uncertainties in the input data. Since there is almost no available information or published estimates of uncertainty in industry data, such estimates must be based on engineering judgement and the experience of operating, maintenance, and test personnel.

II Quantitative Methods

Quantitative methods for estimating individual component availability are in conformance with section 5.1.2 of IEEE Std 352-1975 for failures which can only be detected during

periodic testing. Component failures which are self annunciating are considered using best estimates of failure rate and associated "down time".

The system availability is considered to be the product of all component availabilities.

$$A_s = \prod_{j=1}^n A_j$$

*For the existing system.*

This approach accounts for all single failures and any combination of failures that may occur when the system is called upon to function.

III System Description **THIS REPORT CONTAINS PROPRIETARY INFORMATION**

**AND SHALL NOT BE RELEASED IN WHOLE OR IN PART EXCEPT WITH THE WRITTEN PERMISSION OF ROCHESTER GAS AND ELECTRIC CORPORATION**

The Load Shedding and Sequencing System detects the loss of voltage on the Class 1E 480V buses, opens the feeder breakers to all safety related loads, and blocks the Safety Injection starting sequence until bus voltage is restored. If a Safety Injection Signal is present, the system resets when voltage is restored by the diesel generators and the Engineered Safety Features are loaded on the bus in proper sequence by the Agastat time relay relays. It is important to note that the load shedding and sequencing relay logic is an integrated system of primary and auxiliary relays. This is a significant consideration when evaluating the degree to which the addition of coincident logic improves system availability. The requirement for coincident undervoltage logic, as stated by the NRC in their letter of June 3, 1977 applies only to the initiating, undervoltage relays. The



NRC Staff has never provided a quantitative basis for this requirement. Since the only system failures which are mitigated by this modification are those due to the failure of fuses, potential transformers, or undervoltage relays, it is of very limited value in increasing system availability. It is shown however, that the system availability is highly sensitive to the uncertainty in auxiliary relay failure rates. Because of this sensitivity, it is recommended that the design modification of this system, proposed by the RG&E Electrical Engineering Group in August 1978, and reviewed and approved by the NRC Staff be installed during the 1980 refueling shutdown.

THIS REPORT CONTAINS  
 PROPRIETARY INFORMATION  
 AND SHOULD NOT BE RELEASED

IV Active and Passive Components BE RELEASED

The passive elements in this system are fuses, potential transformers, cable terminations and enclosures. Normally such components are highly reliable and contribute negligibly to the system failure rate. However, fuses are often pulled during test and maintenance activities. This can result in abnormal wear and tear on fuse clips, and possible errors when the fuses are replaced. Thus a large uncertainty should be attached to fuse reliability data.

The active components in the system are electromechanical relays. There are induction disk type, U.V. relays (CV7), auxiliary relays (MG-6 and BFD), and Agastat time delay relays. In addition, SG type relays are used to monitor DC control voltage. The switchgear that is controlled by this system is not within the scope of this evaluation. Active

components are inherently subject to a greater diversity of failure modes than passive ones and thus greater uncertainty in failure rate data.

V Detectable and Undetectable Failures


Failure of potential transformers or A.C. fuses is self-annunciating in the existing system, since they activate the undervoltage relays. The D.C. fuses are monitored and alarmed. Thus there are no undetectable failure modes for the passive components. However following any such failure there will be a period, conservatively estimated at one day, for repair and replacement.

Failure of relays during the periodic test interval must be considered undetectable (although some failures might be self-annunciating) and are treated in accordance with IEEE 352-1975, section 5.2. AND

VI Component Availability

1. Available Industry Data

Failure rate data used in this analysis are taken from IEEE Std 500-1977, IEEE Nuclear Reliability Manual. The span of failure rates considered here is from the "recommended" to the "maximum" value. Availabilities calculated from the "maximum" failure rates are referred to as "worst case" values. The uncertainty in the availability is considered to be conservatively enveloped in the span between "recommended" and "worst case" values. Ginna operating experience may provide a sufficient basis for a less conservative estimate



of uncertainty. In all cases the consistency of the industry data with Ginna operating experience is considered.

2. Potential Transformers

All failures are assumed self annunciating and the mean time to repair is estimated to be one day.

	0.5360 failures/10 <sup>6</sup> hr	Recommended
IEEE Std 500-1978	8.0 failures/10 <sup>6</sup> hr	Maximum

$$A_{PT1} \text{ (Recommended Availability)} = 1 - \frac{0.536 \times 24}{10^6} = 0.99999$$

$$A_{PT2} \text{ (Worst Case Availability)} = 1 - \frac{8.0 \times 24}{10^6} = 0.99981$$

THIS REPORT CONTAINS  
 PROPRIETARY INFORMATION  
 AND SHALL NOT BE RELEASED

IN WHOLE OR IN PART EXCEPT

These results appear to be conservative when Ginna experience is considered. The current best estimate" for Ginna is approximately

OF ROCHESTER GAS AND  
 ELECTRIC CORPORATION 0.108 failures/10<sup>6</sup> hrs.

3. <u>Fuses</u>	0.03 failures/10 <sup>6</sup> hr	Recommended
	0.3 failures/10 <sup>6</sup> hr	Worst Case

$$A_{F1} = 1 - \frac{.03 \times 24 \text{ hr}}{10^6 \text{ hr.}} = 0.99999 \quad \text{Recommended}$$

$$A_{F2} = 1 - \frac{.3 \times 24}{10^6} = 0.99999 \quad \text{Worst Case}$$

These results appear to be conservative when Ginna experience is considered. The current best estimate for Ginna is:

0.0060 failures/10<sup>6</sup> hr.

- 4. Relays      0.102 failures/10<sup>6</sup> hrs. (Recommended)
- 12.04 failures/10<sup>6</sup> hrs. (Maximum)

availability based on one year periodic test interval

THIS REPORT CONTAINS

U = 1/2 ~~PROPRIETARY INFORMATION~~ 10<sup>-4</sup>

AND SHALL NOT BE RELEASED

IN WHOLE OR IN PART EXCEPT

A<sub>R1</sub> = 0.99955 Rec. WITH THE WRITTEN PERMISSION

U = 12.04 ~~OF ROCHESTER GAS AND ELECTRIC CORPORATION.~~ 10<sup>-2</sup>

A<sub>R2</sub> = 0.94726 Worst Case

There has been one operational auxiliary relay failure during ten years of testing at Ginna. Assuming this relay was inoperative for one half the test interval (6 mo.), this yields an availability,

$$A_{R3} = \frac{40 \times 10 - 0.5}{40 \times 10} = 1 - \frac{0.5}{400} = 0.99875$$

This result falls between the recommended and "worst case" availabilities calculated using IEEE-Std 500 values. This gives some confidence in the conservatism of the industry data. However, there have been several relay malfunctions which, although not resulting in operational failures have indicated the potential for such failures. It is therefore prudent to consider the "worst case" availability as the lower limit on the uncertainty of the data.

VII System Analyses

The availability of each train of the existing system depends on the availability of all components in the train. There are differences in consequences of failure by the various components. For example some auxiliary relay failures will result in the lock out of particular pumps, others result in lock out of all pumps fed off a particular bus. Conservatively however any loss of function is considered to be a system failure.

THIS REPORT CONTAINS  
 PROPRIETARY INFORMATION  
 AND SHALL NOT BE RELEASED  
 IN WHOLE OR IN PART EXCEPT  
 WITH THE WRITTEN PERMISSION  
 OF ROCHESTER GAS AND  
 ELECTRIC CORPORATION.

The arrangement of the existing system is shown in Figure 1. The availability of this system is given by

$$A_s \text{ (Existing System Availability)} = A_{PT}^p A_F^q A_R^r$$

where p = ( # of potential transformers) = 2

q = ( # of fuses) = 5

r = ( # of relays) = 30

The availabilities of cables, terminations, and enclosures is considered to be unity.

$$A_{S1} \text{ (Recommended Value)} = (.99999)^2 \times (.99999)^5 \times (.99955)^{30} \\ = .99998 \times .99995 \times .98659 = 0.98652$$

$$A_{S2} \text{ (Worst Case)} = (.99981)^2 \times (.99999)^5 \times (.94726)^{30} \\ = (.99962) \times (.99995) \times (.19682) = 0.19674$$

$$A_{S3} \text{ (Ginna experience)} = .99998 \times .99995 \times .96317 = 0.96310$$

**THIS REPORT CONTAINS  
PROPRIETARY INFORMATION**

The system availability experience at Ginna is well above the worst case value. However the availability is extremely sensitive to any uncertainty in individual relay failure rate.

This is of particular concern as the components become older. Any significant increase in relay failure rate due to aging effects could result in high system unavailability.

It should be noted that the NRC Staff requirement for coincident undervoltage logic would only mitigate failures due to the CV 7 U.V. relays, not failures in the auxiliary relays. This comment applies also to the scheme proposed by Dasgupta and Murphy.

## 2. The Proposed System

The general arrangement of the proposed system is shown in Figure 2. This system will function if one of each pair

of corresponding relays operates. The general relation for the availability of two components in an "OR" configuration is,

$$A_s = A_1 + A_2 - A_1 A_2.$$

Since all relays are assigned the same availability in this analysis, this expression may be simplified as shown,

$$A_s = A (2 - A)$$

It is necessary for ten relay pairs (loss of voltage and second level) to function in this manner, in each of four arrangements. The four arrangements represent the primary and backup protection on each of two buses. The system availability for this scheme is given by,

THIS REPORT CONTAINS  
PROPRIETARY INFORMATION  
AND SHALL NOT BE RELEASED  
IN WHOLE OR IN PART EXCEPT  
WITH THE WRITTEN PERMISSION  
OF ROCHESTER GAS AND  
ELECTRIC CORPORATION.

The effect of fuse and PT availability is negligible. There are however ten Agastat and BFD relays, which remain unmodified in the proposed design, all of which must function. Accounting for these, the final system availability is given by,

$$A_{rs} = A^{50} (2-A)^{40}$$

Recommended Value	A = .99955	A <sub>rs</sub> = 0.99550
Worst Case Value	A = .94726	A <sub>rs</sub> = 0.52036
Ginna Experience	A = .99875	A <sub>rs</sub> = 0.98751



A comparison of the existing and proposed designs is shown below.


	Existing Design	Proposed Design
Recommended Value	0.98652	0.99550
Worst Case	0.19674	0.52036
Ginna Experience	0.96310	0.98751

### VIII Conclusion

It is concluded that the availability of the proposed design offers a distinctly higher tolerance to uncertainty in relay failure rate. The tolerance of higher failure rates will become more significant as these components age. It is recommended that the design be modified as proposed.


THIS REPORT CONTAINS  
PROPRIETARY INFORMATION  
AND SHALL NOT BE RELEASED  
IN WHOLE OR IN PART EXCEPT  
WITH THE WRITTEN PERMISSION  
OF ROCHESTER GAS AND  
ELECTRIC CORPORATION.

480V-3 $\phi$ -60~ BUS N $\circ$ . 14.




THIS REPORT CONTAINS  
 INFORMATION IN CONFIDENCE  
 AND SHALL BE UNCLASSIFIED  
 IN WHOLE OR IN PART EXCEPT  
 WITH THE WRITTEN PERMISSION  
 OF ROCHESTER GAS AND  
 ELECTRIC CORPORATION.

FIG. 1. SINGLE LINE DIAGRAM TRAIN A  
 EXISTING UNDERVOLTAGE SYSTEM



THIS REPORT CONTAINS  
 PROPRIETARY INFORMATION  
 AND SHALL NOT BE RELEASED  
 IN WHOLE OR IN PART EXCEPT  
 WITH THE WRITTEN PERMISSION  
 OF ROCHESTER GAS AND  
 ELECTRIC CORPORATION.



- 27 - INVERSE TIME UNDERVOLTAGE RELAY - (SECOND LEVEL DETECTION)
- 27D - DEFINITE TIME UNDERVOLTAGE RELAY (LOSS OF VOLTAGE DETECTION)

FIG. 1 SINGLE LINE DIAGRAM EWR-1484  
 PROPOSED UNDERVOLTAGE SYSTEM

JOB NO.	DATE	BY	REVISION
REVISION		REVISION	REVISION
DATE	BY	REVISION	REVISION
ROCHESTER GAS & ELECTRIC CORP.			
660 WEST 10TH ST. ROCHESTER, N.Y.			
NEW YORK			



