

MEETING SUMMARY DISTRIBUTION:

REGULATORY DOCKET FILE COPY

Docket 50-244

NRC PDR

Local PDR

ORB#2 RDG

NRR RDG

H. R. Denton

E. G. Case

D. Eisenhut

R. Vollmer

B. Grimes

L. Shao

W. Gammill

J. Miller

W. Russell

T. Carter

D. Crutchfield

D. Ziemann

V. Noonan

Seismic Review Group

A. Schwencer

T. Ippolito

R. Reid

G. Lainas

P. Check

R. Clark

F. Pagano

G. Knighton

J. Shea

OELD

OI&E(3)

H. Smith

R. Fraley, ACRS(16)

T. Wambach

H. J. Wong

P. T. Kuo

H. Levin

T. Cheng

C. Hofmayer

K. Jabbour

J. Glynn

S. Hosford

J. Fair

R. W. Klecker

W. J. Collins

R. A. Hermann
J. Strosnider
T. H. Liu
J. B. Henderson
J. R. Buchanan
TERA

MEMO

OFFICE >					
SURNAME >					
DATE >					



AUG 16 1979

Docket No. 50-244

LICENSEE: Rochester Gas & Electric Corporation (RG&E)

FACILITY: R. E. Ginna Nuclear Power Plant

SUBJECT: SUMMARY OF MEETING WITH RG&E

NRC and RG&E representatives met in Bethesda, Maryland, on July 24, 1979 for presentations by RG&E regarding:

- o RG&E decision to upgrade the Ginna Station Seismic Analysis of Category I Piping Systems;
- o RG&E responses to IE Bulletin 79-02, "Pipe Support Base Plate Design Using Concrete Expansion Anchor Bolts";
- o RG&E responses to IE Bulletin 79-07, "Seismic Stress Analysis of Safety Relating Piping - Algebraic Summation Error"; and
- o RG&E responses to IE Bulletin 79-13, "Inspection for Cracks In the Steam Generator Feedwater Piping."

The meeting attendees are listed in Attachments 2 and 3. The meeting progressed as summarized below.

1. Seismic Upgrade

The RG&E decision to upgrade the Ginna Nuclear Power Plant seismic analysis of Category I piping systems and the seismic upgrading program were discussed by various RG&E representatives within the context of the meeting outline provided by RG&E and included with this meeting summary as Attachment 1. The RG&E representatives stated that the analytical program and the potential resultant modifications will require three years for completion at an estimated cost of five million dollars. The RG&E schedule for completion of the program follows:

- data gathering
5/1/79 started on initial systems outside containment.

scope expanded and schedule accelerated upon receipt of IE Bulletin 79-14 and the July-August 1979 outage for Feedwater Crack inspections.

MEMO 4

OFFICE					
SURNAME					
DATE					

The first part of the report deals with the general situation of the country and the progress of the work. It is followed by a detailed account of the various projects and the results achieved. The report concludes with a summary of the work done and the prospects for the future.

The work has been carried out in accordance with the programme of work approved by the Council of the League of Nations. It has been carried out in a spirit of cooperation and in the best interests of the League.

The results of the work have been most satisfactory and it is hoped that they will be of great value to the League and to the world.

The work has been carried out in a spirit of cooperation and in the best interests of the League.

The results of the work have been most satisfactory and it is hoped that they will be of great value to the League and to the world.

The work has been carried out in a spirit of cooperation and in the best interests of the League.

The results of the work have been most satisfactory and it is hoped that they will be of great value to the League and to the world.

The work has been carried out in a spirit of cooperation and in the best interests of the League.

The results of the work have been most satisfactory and it is hoped that they will be of great value to the League and to the world.

7/31/79 data from inside containment to be completed.

9/15/79 following completion of inside containment data collection people will then be assigned to complete remaining systems outside containment. All field inspections and sketches complete.

- floor response spectra containment, interior structure, and RCS being modeled now.

10/1/79 floor response spectra for containment complete.

1/1/80 spectra for other structures in program complete.

- piping analysis
piping models and support stiffness work already in progress on some systems; e.g. B-Main Steam, A-RHR.

1/1/80 analysis of systems inside containment complete.

1/1/81 analysis of systems outside containment complete.

- modifications

Spring 1981 inside containment complete.

Spring 1982 outside containment complete.

2. Pipe Support Base Plate Designs Using Concrete Expansion Anchor Bolts - IE Bulletin 79-02. RG&E presented additional information (documented by later RG&E submittal 7/26/79) to the July 6, 1979 response to IE Bulletin 79-02 which the staff concluded satisfied the intent of the bulletin.
3. Seismic Stress Algebraic Summation Error Information (later documented by RG&E letter dated July 26, 1979) provided by RG&E in addition to that provided earlier by RG&E letter to NRC dated April 25, 1979 was sufficient to satisfy the staff with respect to the requirements of Bulletin 79-07 for the three piping systems affected by the algebraic summation error, i.e. residual heat removal line - loop A, main steam line - loop B, and the charging line.
4. Cracks in Feedwater Piping - IE Bulletin 79-13. RG&E discussed the feedwater system nondestructive examination that has been performed,

OFFICE ▾						
SURNAME ▾						
DATE ▾						



Faint, illegible text covering the majority of the page, appearing as scattered black specks and noise.

metallurgical examination results to date, crack repair program, and the cause of cracking. The crack indicators at the A and B steam generator feedwater nozzle to pipe welds in the base material of the 90 degree elbows that attach to the feedwater nozzle, based on ultrasonic and radiographic examination, were described in detail. Crack indications were estimated to be 1/32 - 1/16 inch in depth originating from the inside surface of the elbow. The extent of crack indications on the "A" steam generator elbow are approximately 300 degrees around the inside circumference while the "B" steam generator elbow is exhibiting crack indications around the entire (360 degrees) inside circumference.

Additional confirmatory information relative to the depth of cracks and results from the inspection of all other (18) feedwater pipe welds inside containment was presented. No other cracks were detected. The feedwater pipe elbows that contained the cracks (both loops) were replaced. The information presented by RG&E which included preliminary results from more recent metallurgical analysis of the cracks was later documented by RG&E letter dated July 27, 1979. The staff concluded that the RG&E responses to IE Bulletin 79-07 and the corrective action, replacement of feedwater pipe elbows, satisfy the requirements of the bulletin.

151

James J. Shea, Project Manager
 Operating Reactors Branch #2
 Division of Operating Reactors

Attachments:
 As stated

cc:
 See next page

OFFICER	DOR:ORB#2	DOR:EB	IE	DOR:ORB#2	DOR:AVADREP
SURNAME	JJShea:sa	VNoonan	HJWong	DLZiemann	LShao
DATE	8/8/79	8/10/79	8/13/79	8/14/79	8/16/79



100

100

100

[The main body of the page contains several paragraphs of text that are extremely faint and illegible due to the quality of the scan. The text appears to be organized into multiple sections, possibly separated by headings or sub-sections, but the specific content cannot be discerned.]

Rochester Gas & Electric
Corporation

- 4 -

AUG 16 1979

cc

Lex K. Larson, Esquire
LeBoeuf, Lamb, Leiby & MacRae
1757 N Street, N. W.
Washington, D. C. 20036

Mr. Michael Slade
1250 Crown Point Drive
Webster, New York 14580

Rochester Committee for
Scientific Information
Robert E. Lee, Ph.D.
P. O. Box 5236 River Campus
Station
Rochester, New York 14627

Jeffrey Cohen
New York State Energy Office
Swan Street Building
Core 1, Second Floor
Empire State Plaza
Albany, New York 12223

Director, Technical Development Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Rochester Public Library
115 South Avenue
Rochester, New York 14604

Mr. Leon D. White, Jr.
Vice President
Electric and Steam Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, New York 14649

RGE Decision to Upgrade Ginna Station Seismic
Analysis of Category I Piping Systems

I 3 Year Program Commitment May 1979

- . Dynamic analysis of essential safety systems to current standards for dynamic analysis.
- . Modifications to piping as required to upgrade to new standard to extent practical.

II Basis for original Seismic Qualification

- . Housner ground response spectrums .08 BE, 0.2 SSE with 0.5% critical damping.
- . Equivalent Static Analysis of 2½" and larger Cat I piping systems.
 - . $S_{SSE}^{seismic} + S_{DW} + S_{press} \leq 1.8 S_A$
- . Field run piping 2" and less to conservative B31.1 code spacing criteria for vertical and horizontal forces.
- . Design verification by dynamic analysis of 2 piping systems inside containment A RHR, B Main Steam.
- . System walkdown by seismic Westinghouse, GAI, RGE engineers, June 1969.
- . Documentation (minimal record keeping requirements of late 1960s).

III Challenges to existing Seismic Analysis

- . Major Modification Programs (high energy backfits outside containment 1974, Standby Auxiliary System 1975, Spent Fuel Pit Cooling 1977)
- . Corporate Decision 1974 to design and construct major modification to current codes and standards - Section 3 with dynamic analysis including structural response.
- . NRC seismic SEP review program (structures, equipment, piping) Independent review of original seismic qualification using current analysis techniques.
- . Current Regulatory Seismic Concerns.

IE Bulletins 79-02 Anchor Bolts

79-04 Velan Valves

79-07 Algebraic Summation

79-14 As-Built Configuration

IV Benefits to RGE of Seismic Upgrade Analysis Upgrade Program

- . Provides a consistent design basis seismic analysis baseline for essential Cat I piping systems for future evaluation during next 10 years.
- . Provides a level of design documentation for analysis and support design consistent with current practice and record keeping requirements.
- . Permit a systematic approach to development of design and analytical data versus chaotic efforts associated with current and future bulletin concerns.
- . Provide seismic input data based on current system configuration to SEP evaluators (scheduled to maximize manpower productivity).
- . Provides consistent means of evaluation for future modification requirements (i.e. SEP, 3 Mile Island, High Energy Inside Containment, etc.).
- . Upgrades plant seismic design to current industry standards. Includes effects of soil-structure interaction, structural amplification, higher damping values, multi-mode behavior.

GINNA STATION.

SEISMIC UPGRADING PROGRAM
 RGE/NRC MEETING
 BETHESDA, MD
 JULY 24, 1979

1. Scope

- structures
 - containment and interior structure
 - turbine, auxiliary, intermediate, control, diesel generator buildings
- systems
 - seismic category I, 2 1/2" and larger, main runs critical 2" within above structures
 - initial program - main steam, main feedwater, aux. feedwater, service water, containment spray, aux. spray, safety injection, residual heat removal
 - CVCS - charging, letdown, seal water
 - expanded program - reactor coolant system, component cooling system
- downgrading
 - waste disposal system
- exclusions
 - screenhouse
 - standby aux. feedwater building and system
 - spent fuel pool cooling system
 - buried piping (principally service water)
 - LOCA and pipe break
 - No fatigue analyses being performed
 - pressurizer relief valve discharge piping

2. Structural Analysis

- method
 - original plant design utilized ground response spectra upgrading program will use floor response spectra dynamic lumped mass model
 - I. coupled - containment and internal structure (includes RCS)

2. interconnected buildings - turbine, auxiliary, intermediate, control, diesel generator
3. 2D for symmetrical buildings
4. 3D for structures with significant torsional modes
5. large equipment masses included
6. vertical amplification of floors and beams calculated separately
7. soil structure interaction will be included in model

ground response spectra based on .08g OBE, .20g SSE

artificial time histories used as input for generating floor response spectra

differential displacements to be calculated for OBE only

- criteria

Reg. Guide 1.60 - response spectra

Reg. Guide 1.61 - damping values

Reg. Guide 1.92 - combination of modal responses

3. Piping Analysis

- method

original plant design utilized equivalent static analysis

upgrading program will use response spectra modal analysis

response spectra will envelope points of piping supports

3D dynamic model

1. support stiffnesses to be included
2. eccentric masses, such as valve operators, included
3. equipment masses and stiffnesses included where necessary
4. effect of reactor coolant system included for large secondary lines
5. effect of branch lines included with main run

Loading conditions

1. normal - design pressure + deadweight S_n
2. design - OBE + design pressure + deadweight $1.25 S_n$
3. SSE - SSE + operating pressure + deadweight $1.85 S_n$
4. thermal - OBE displacements + thermal pressure + deadweight + thermal + OBE diesel $S_a + S_h$

stresses due to OBE differential motion only will be calculated

- criteria

USAS B3E-1-1973 - stress criteria
(summer 1973 addenda)

Reg. Guide 1.60 - damping values

Reg. Guide 1.92 or RESAR 41 - combination of modal responses

criteria developed for allowable loads on equipment models, valves, and branch piping

4. Supp . Analysis

method:

original plant component supports utilized manufacturers standards

fabricated supports designed and fabricated to AISC Code

upgrading program will analyze supports in 3 stages

1. calculation of stiffnesses for piping analyses
2. comparison of new loads against original
3. redesign of existing supports and design of new supports as necessary

embedments will be included in calculating support stiffnesses and evaluating integrity of existing supports

base plate flexibility will be included

loading combinations evaluated will be same as piping

- criteria

ASME III, Subsection NF - stress criteria (1974)

Reg. Guide 1.124 - service limits and loading combinations

ACI-349, App. B - embedments

5. Modifications

- existing supports:

replace load rated supports where new loads exceed existing rating

replace or modify structural steel members (base plates) and welds as required to meet stress limits

replace embedments where necessary to meet new loads and safety factors

- new supports

add new supports where necessary to maintain piping stresses and equipment nozzle loads below allowable values

- structures

local modification/reinforcement of existing structural steel and concrete where necessary for increased loads

6. Output

- isometrics

as-built isometrics containing all "seismic input" information dimensions, wall thickness, materials, valves, support location and type, etc.

- stress reports

summary and detailed stress reports for piping correspond to isometrics

stresses at each critical location in piping system support and nozzle loads

summary reports of support analyses

comparison of calculated values with code allowables

- as-built drawings

piping orthographic drawings

pipe support location and detail drawings

rated support loads

- floor response spectra

for each Category I structure included in program at locations and elevations of Category I piping systems; and mechanical and electrical equipment

1950

1950

LIST OF ATTENDEES

SEISMIC MEETING

JULY 24, 1979

NRC

- T. Wambach
- J. Shea
- H. J. Wong
- P. T. Kuo
- L. C. Shao
- H. A. Levin
- T. M. Cheng
- C. H. Hofmayer
- K. N. Jabbour
- J. C. Glynn
- D. Crutchfield
- D. Ziemann
- V. Noonan
- S. Hosford
- J. Fair

RG&E

- R. Mecredy
- J. Hutton
- R. Smith
- L. D. White, Jr.
- J. C. Noon


Gilbert Associates

- K. T. Momose
- P. C. Shah

Westinghouse

- R. J. Sero
- W. S. Lapay

OFFICE						
SURNAME						
DATE						



LIST OF ATTENDEES

PIPE SUPPORT PLATES & ANCHOR BOLTS
ALGEBRAIC SUMMATION PIPE STRESS ERROR
FEEDWATER PIPE CRACK MEETING

JULY 24, 1979

NRC

J. Shea
R. W. Klecker
W. J. Collins
R. A. Hermann
J. Strosnider
T. H. Liu
J. B. Henderson

RG&E

R. E. Smith
J. Hutton
A. Curtis

Westinghouse

D. Campbell
C. W. Hirst
R. J. Sero
W. S. Lapay
T. E. Campbell
T. R. Mager

OFFICE					
SURNAME					
DATE					



11 11 11

11 11 11

11 11 11

11 11 11

11 11 11

11 11 11

11 11 11