

Mr. Leon D. White, Jr.

- 2 -

MAR 06 1980

With respect to containment environmental conditions and systems required for accident mitigation we will request additional information, some of it prior to the dates listed in the enclosure, and provide some clarification of the guidelines.

Sincerely,

"Original Signed by  
Thomas V. Wambach"

*for*

Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

Enclosures:  
As stated

DISTRIBUTION

- Docket
- NRC-PDR
- Local PDR
- ORB #2 Reading
- NRR Reading
- DEisenhut
- RVollmer
- OELD
- QI&E (3)
- DLZiemann
- TVWambach
- HSmith
- DCrutchfield
- CHofmayer
- JShapaker
- GLainas
- RWilson
- NSIC
- TERA
- ACRS (16)

OFFICE ▶	DOR:ORB #2	DOR:ORB #2				
SURNAME ▶	TVWambach:ah	DLZiemann			8004020014	
DATE ▶	3/6/80	3/6/80				

011

Illegible text in the right margin, possibly bleed-through or a separate column of text.

March 6, 1980

cc w/enclosures:

Harry H. Voigt, Esquire  
LeBoeuf, Lamb, Leiby & MacRae  
1757 K Street, N. W.  
Washington, D. C. 20036

Mr. Michael Slade  
12 Trailwood Circle  
Rochester, New York 14618

Rochester Committee for  
Scientific Information  
Robert E. Lee, Ph.D.  
P. O. Box 5236 River Campus  
Station  
Rochester, New York 14627

Jeffrey Cohen  
New York State Energy Office  
Swan Street Building  
Core 1, Second Floor  
Empire State Plaza  
Albany, New York 12223

Director, Technical Development Programs  
State of New York Energy Office  
Agency Building 2  
Empire State Plaza  
Albany, New York 12223

Rochester Public Library  
115 South Avenue  
Rochester, New York 14604

Supervisor of the Town  
of Ontario  
107 Ridge Road West  
Ontario, New York 14519

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Region II Office  
ATTN: EIS COORDINATOR  
26 Federal Plaza  
New York, New York 10007

Herbert Grossman, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Richard F. Cole  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Emmeth A. Luebke  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Thomas B. Cochran  
Natural Resources Defense Council, Inc.  
1725 I Street, N. W.  
Suite 600  
Washington, D. C. 20006

K M C, Inc.  
ATTN: Richard E. Schaffstall  
1747 Pennsylvania Avenue, N. W.  
Suite 1050  
Washington, D. C. 20006



10  
11  
12

SEP QUALIFICATION PROGRAM SCHEDULE

<u>Plant</u>	<u>Licensee Submittal Date</u>	<u>Site Visit (week of)</u>	<u>Consultant Final Report</u>
Palisades	Currently under review	1/21	6/30
Oyster Creek	Currently under review	3/10	7/21
Ginna	4/25	5/5	8/4
Zion 2	5/1	5/19*	8/11
Indian Pt. 3	5/1	6/2	8/18
Zion 1	5/1	6/9	8/11
Indian Pt. 2	5/1	6/16	9/2
Millstone 1	6/2	6/23	9/8
Haddam Neck	6/2	7/7	9/15
Dresden 2	6/2	7/14	9/22
San Onofre	6/2	7/21	9/29
Dresden 1	6/2	7/28	10/6
Yankee Rowe	6/2	8/4	10/14
LaCrosse	7/1	8/11	10/20
Big Rock Point	7/1	8/18	10/27

\*Effort will be made to perform a significant portion of the  
Zion 1 site evaluation at this time.



SEP QUALIFICATION PROGRAM SUBMITTAL CONTENT

1. The emergency procedures and list of safety-related systems addressed in reference 2.
2. The definition of and basis for the hostile service conditions both inside and outside containment addressed in reference 1 section 4.0, Service Conditions.
3. The identification and justification of equipment considered qualified by experience in accordance with reference 1 section 4.3.3, Areas Normally Maintained at Room Conditions.
4. The tabulation of safety-related equipment located in a hostile environment, with identification of the service conditions and qualification testing for each, in the format used for either SEP Topic III-12 or IE Bulletin 79-01B submittals.
5. The list of equipment in the tabulation of item 4 that is not qualified in accordance with the specific requirements of reference 1, together with justification for the deviations from the guidelines.

---

Reference 1: Guidelines for evaluating environmental qualification of Class 1E Electrical Equipment in operating reactors.

Reference 2: Guidelines for identification of that safety equipment of SEP operating reactors for which environmental qualification is to be addressed.



Handwritten scribble or mark in the top right corner.