



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GIINNA NUCLEAR POWER PLANT

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 33
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Rochester Gas and Electric Corporation (the licensee) dated March 7, 1980 (transmitted by letter dated March 12, 1980), complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8007140 632



Handwritten scribbles and marks in the top right corner, possibly remnants of a signature or stamp.

Small handwritten mark or character on the right edge of the page.

Small handwritten mark or character on the right edge of the page.

2. Accordingly, a new Paragraph 2.C(6) is hereby incorporated in Provisional Operating License No. DPR-18 to read as follows:


2.C(6) Secondary Water Chemistry Monitoring Program

The licensee shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall be described in the plant procedures and shall include:

- a. Identification of a sampling schedule for the critical parameters and control points for these parameters;
- b. Identification of the procedures used to measure the values of the critical parameters;
- c. Identification of process sampling points;
- d. Procedure for the recording and management of data;
- e. Procedures defining corrective actions for off control point chemistry conditions; and
- f. A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

3. This license amendment is to be come effective June 30, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION


Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Date of Issuance: June 13, 1980