

APPENDIX A

NOTICE OF VIOLATION

Rochester Gas and Electric Company

Docket No. 50-244

Based on the results of an NRC inspection conducted on April 29 through May 2, 1980, it appears that one of your activities was not conducted in full compliance with NRC regulations and the conditions of your license as indicated below. This is an infraction.

Technical Specification 6.11, "Radiation Protection Program", states, in part, "Radiation control procedures shall be prepared and made available to all station personnel or other persons who may be subject to radiation exposure at the station...The radiation protection program shall be organized and maintained to meet the requirements of 10 CFR Part 20,...The program shall be adhered to for all operations involving personnel radiation exposure."

1. Procedure HP-4.3, "Work Permit Use", Revision 14, requires in Section 6.1.5 that each person working under a Radiation Work Permit (RWP) shall comply with the RWP in all respects.

Contrary to the above, on May 1, 1980, two individuals working under RWP No. 1, at Motor Control Panel 1-C, did not comply with the RWP in all respects, in that they removed their protective work gloves, which were required by the RWP.

2. Procedure A.1, "Radiation Control Manual", Revision 14, requires in Section VI.A., "Access to Controlled Areas", that smoking, chewing, or eating are strictly prohibited in controlled areas.

Contrary to the above, on May 1, 1980, four individuals were chewing gum while in controlled areas (i.e., the Auxiliary Building and the Reactor Containment).

