

EOP: FR-H.2	TITLE: RESPONSE TO STEAM GENERATOR OVERPRESSURE	REV: 2 PAGE 1 of 6
----------------	--	-----------------------

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER 23

TECHNICAL REVIEW

PORC REVIEW DATE 4/4/90

Joseph A. Widay
PLANT SUPERINTENDENT

4/9/90
EFFECTIVE DATE

QA NON-QA _____ CATEGORY 1.0

REVIEWED BY: _____

GINNA STATION	
START:	
DATE	_____
TIME	_____
COMPLETED:	
DATE	_____
TIME	_____

9004200743 900410
PDR ADDCK 05000244
PNU



EOP: FR-H.2	TITLE: RESPONSE TO STEAM GENERATOR OVERPRESSURE	REV: 2 PAGE 2 of 6
----------------	--	-----------------------

- A. PURPOSE - This procedure provides actions for an overpressure condition affecting any S/G where pressure has increased above the highest steamline safety valve setpoint.
- B. ENTRY CONDITIONS/SYMPTOMS
 - 1. ENTRY CONDITIONS - This procedure is entered from:
 - a. F-0.3, HEAT SINK Critical Safety Function Status Tree, on a YELLOW condition.



STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

NOTE: o Throughout this procedure, "affected" refers to any S/G in which pressure is greater than 1140 psig.

o Adverse CNMT values should be used whenever CNMT pressure is greater than 4 psig or CNMT radiation is greater than 10^{-05} R/hr.

1 Identify Affected S/G(s):

- | | |
|--|--|
| a. Any S/G pressure - GREATER THAN 1140 PSIG | a. Return to procedure and step in effect. |
|--|--|

2 Verify FW Isolation To Affected S/G(s):

- | | |
|---|---------------------------|
| a. MFW pumps - TRIPPED | a. Trip MFW pumps. |
| b. MFW flow control valve(s) - CLOSED

• MFW regulating valve(s)
• MFW bypass valve(s) | b. Manually close valves. |
| c. MFW pump discharge valve(s) - CLOSED | c. Manually close valves. |

3 Check Affected S/G(s) Narrow Range Level - LESS THAN 90% [85% adverse CNMT]

Go to FR-H.3, RESPONSE TO STEAM GENERATOR HIGH LEVEL, Step 1.



STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION

IF AFFECTED S/G NARROW RANGE LEVEL INCREASES TO GREATER THAN 90% [85% ADVERSE CNMT], THEN STEAM SHOULD NOT BE RELEASED FROM THE AFFECTED S/G(S).

4 Try To Dump Steam From The Affected S/G(s):	Go to Step 6.
---	---------------

- o Open S/G ARVs
- OR-
- o Open MSIV bypass valves
- OR-
- o Open steam supply valves to TDAFW pump

5 Check Affected S/G(s) Pressure:

- | | |
|---|----------------------|
| a. Pressure - DECREASING | a. Go to Step 6. |
| b. Pressure - LESS THAN 1140 PSIG | b. Return to Step 3. |
| c. Control steam release to maintain S/G pressure less than 1140 psig | |
| d. Return to procedure and step in effect | |



STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION

AFW FLOW SHOULD REMAIN ISOLATED TO AFFECTED S/G(S) UNTIL A STEAM RELEASE PATH IS ESTABLISHED.

6 Close AFW And SAFW Flow Control Valves To Affected S/G(s)

Stop pumps feeding affected S/G(s).

- o S/G A
 - MOV-4007 and AOV-4480, MDAFW pump
 - AOV-4297, TDAFW pump
 - MOV-9701A, SAFW pump

- o S/G B
 - MOV-4008 and AOV-4481, MDAFW pump
 - AOV-4298, TDAFW pump
 - MOV-9701B, SAFW pump

7 Check RCS Hot Leg Temperatures - LESS THAN 535°F

Cool down RCS to less than 535°F by dumping steam from the unaffected S/G.



STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

8 Continue Attempts To Manually Or Locally Dump Steam From Affected S/G(s):

- o Open S/G ARVs

-OR-

- o Open steam supply valves to TDAFW pump

-OR-

- o Dispatch A0 to perform the following:

- a. Open affected S/G MSIV bypass valve
- b. Open both priming air ejector steam isolation valves
 - V-3580
 - V-3581

9 Return To Procedure And Step In Effect

-END-



1 / 1