

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9109040345 DOC.DATE: 91/08/26 NOTARIZED: NO DOCKET #  
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
 AUTH.NAME AUTHOR AFFILIATION  
 MECREDY,R. Rochester Gas & Electric Corp.  
 RECIP.NAME RECIPIENT AFFILIATION  
 JOHNSON,A.R. Project Directorate I-3

SUBJECT: Discusses installation of Containment Isolation Signal to  
 AOV 745 by end of 1992 refueling outage.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

| RECIPIENT<br>ID CODE/NAME | COPIES |      | RECIPIENT<br>ID CODE/NAME | COPIES |      |
|---------------------------|--------|------|---------------------------|--------|------|
|                           | LTTR   | ENCL |                           | LTTR   | ENCL |
| PD1-3 LA                  | 1      | 1    | PD1-3 PD                  | 1      | 1    |
| JOHNSON,A                 | 2      | 2    |                           |        |      |
| INTERNAL: NRR/DET/ECMB 7D | 1      | 1    | NRR/DET/ESGB              | 1      | 1    |
| NRR/DOEA/OTSB11           | 1      | 1    | NRR/DST 8E2               | 1      | 1    |
| NRR/DST/SELB 7E           | 1      | 1    | NRR/DST/SICB8H7           | 1      | 1    |
| NRR/DST/SRXB 8E           | 1      | 1    | NUDOCS-ABSTRACT           | 1      | 1    |
| OC/LFMB                   | 1      | 0    | OGC/HDS1                  | 1      | 0    |
| <u>REG FILE</u> 01        | 1      | 1    | RES/DSIR/EIB              | 1      | 1    |
| EXTERNAL: NRC PDR         | 1      | 1    | NSIC                      | 1      | 1    |

*Cert NO*

*P729548029*

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

*MAY*



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY  
Vice President  
Ginna Nuclear Production

August 26, 1991

TELEPHONE  
AREA CODE 716 546-2700

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Attn: Allen R. Johnson  
Project Directorate I-3  
Washington, D.C. 20555

Subject: Letter from R. Mecredy, RG&E to A. Johnson, NRC, Subject: AOV  
745, dated July 10, 1990.  
Rochester Gas and Electric Corporation  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Johnson,

In the subject letter, RG&E committed to install a Containment Isolation Signal (CIS) to AOV 745 by the end of the 1992 refueling outage. This modification was to be made strictly on the basis of an earlier letter from RG&E to the NRC which indicated that a CIS would be provided to all non-essential penetrations which includes the penetration for AOV 745. The current General Design Criteria (GDC) for containment isolation valves, however, do not require an automatic CIS to AOV 745 since the process piping is a closed system inside containment.

After further review, RG&E has determined that the Emergency Operating Procedure changes which were made directing an operator to remotely manually close AOV 745 from the Control room at an appropriate time following receipt of a CIS, is an acceptable solution to this concern, and that the cost associated with installing a CIS to AOV 745 is not warranted. Therefore, RG&E does not intend to install this CIS to AOV 745.

Very truly yours,

*Robert C. Mecredy*  
Robert Mecredy

MDF\284

xc: Mr. Allen R. Johnson (Mail Stop 14D1)  
Project Directorate I-3  
Washington, D.C. 20555

Ms. Donna Ross  
New York State Energy Office

U.S. Nuclear Regulatory Commission  
Region 1  
475 Allendale Road  
King of Prussia, PA 19406

Ginna Senior Resident Inspector

*Att No* *P729548029*  
*AOO1*  
*1/0*

0207

9109040345 910826  
PDR ADOCK 05000244  
PDR

