

(5) Pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and rules, regulations and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified below:

(1) Maximum Power Level

RG&E is authorized to operate the facility at steady-state power levels up to a maximum of 1520 megawatts (thermal).

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 49, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Fire Protection

(a) The licensee shall implement and maintain in effect all fire protection features described in the licensee's submittals referenced in and as approved or modified by the NRC's Fire Protection Safety Evaluation (SE) dated February 14, 1979 and SE supplements dated December 17, 1980, February 6, 1981, June 22, 1981, February 27, 1985 and March 21, 1985 or configurations subsequently approved by the NRC, subject to provision (b) below.


(b) The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

Amendment No. 49

9306290260 930617
PDR ADOCK 05000244
P PDR



100



100