

Snubbers may be further categorized into two groups: those accessible and those inaccessible during reactor operation. Each group may be inspected independently in accordance with the above schedule.

b. Visual Inspection Acceptance Criteria

Visual inspections shall verify: (1) that there are no visible indications of damage or impaired operability, and (2) that the attachments to the foundation or supporting structure are secure. Snubbers which appear inoperable as a result of visual inspections may be determined operable for the purpose of establishing the next visual inspection interval, provided that: (1) the cause of the rejection is clearly established and remedied for that particular snubber and other snubbers, irrespective of type, that may be generically susceptible; or (2) the affected snubber is functionally tested in the as-found condition and determined operable per Specification 4.14.1.d. When a fluid port of a hydraulic snubber is found to be uncovered the snubber shall be declared inoperable and shall not be determined operable via functional testing unless the test is started with the piston in the as-found setting, extending the piston rod in the tension mode direction. All snubbers connected to an inoperable common hydraulic fluid reservoir shall be counted as inoperable snubbers.

8903240086
PDR ADOCK
890314
05000244
PDC

11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100