

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE March 15, 1989

COMPLETED BY Robert E. Dodge

REVISED

TELEPHONE 315-524-4446 x-396
GINNA Station

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: January, 1989
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470

Notes

The reactor power level was maintained at 100% for the majority of the report period with some exceptions detailed on page 3 and 4 of the report.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	744	168,168
12. Number of Hours Reactor Was Critical	732.37	732.37	132,429.98
13. Reactor Reserve Shutdown Hours	0	0	1,687.55
14. Hours Generator On-Line	723	723	129,994.88
15. Unit Reserve Shutdown Hours	0	0	8.5*
16. Gross Thermal Energy Generated (MWH)	1,061,710**	1,061,710**	183,032,124**
17. Gross Electrical Energy Generated (MWH)	359,670	359,670	60,158,999
18. Net Electrical Energy Generated (MWH)	342,095	342,095	57,086,553
19. Unit Service Factor	97.18%	97.18%	77.30%
20. Unit Availability Factor	97.18%	97.18%	77.31%
21. Unit Capacity Factor (Using MDC Net)	97.83%	97.83%	73.63**
22. Unit Capacity Factor (Using DER Net)	97.83%	97.83%	73.63**
23. Unit Forced Outage Rate	2.82%	2.82%	6.36%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Annual Refueling and Maintenance Shutdown - March 17, 1989
45 - 55 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

*Cummulative total commencing January 1, 1975

**Corrected previously submitted figure that was in error

REV 485 49-88