



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 17  
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Rochester Gas and Electric Corporation (the licensee) dated January 22, 1986 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public;  
and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. DPR-18 is hereby amended to read as follows:

8608250214 860818  
PDR ADOCK 05000244  
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.17, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*Morton B. Fairtile*

Morton B. Fairtile, Project Manager  
Project Directorate #1  
Division of PWR Licensing-A

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 18, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 17

FACILITY OPERATING LICENSE NO. DPR-18

DOCKET NO. 50-244

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

4.15-4

INSERT

4.15-4

- d. At least every 3 years by pressure testing each hose to 50 psi greater than the Maximum Working Pressure.

4.15.6 Penetration seals in fire barriers which protect a safety related area shall be verified to be intact by visual inspection:

- a. At least once per 18 months, and
- b. Prior to declaring a penetration seal in a fire barrier intact following repairs or maintenance.

4.15.7 The yard fire hydrant on the southeast corner of the yard loop and its associated hydrant hose house shall be demonstrated OPERABLE:

- a. At least once per 31 days by visual inspection of the hydrant hose house to assure all required equipment is at the hose house.
- b. At least once during March, April or May and once during September, October or November by visually inspecting the yard fire hydrant and verifying that the hydrant barrel is dry and that the hydrant is not damaged.
- c. At least once per 12 months by:
  - (i) Conducting a hose hydrostatic test at a pressure at least 50 psig greater than the maximum pressure available at the yard fire hydrant.
  - (ii) Replacement of all degraded gaskets in couplings.