

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 20 License No. DPR-18

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Rochester Gas and Electric Corporation (the licensee) dated July 19, 1985 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. DPR-18 is hereby amended to read as follows:

8610310147 861022 PDR ADOCK 05000244 P PDR



(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 20, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.


FOR THE NUCLEAR REGULATORY COMMISSION

Dominic C. Dilanni, Project Manager Project Directorate #1

Division of PWR Licensing-A

Attachment: Changes to the Technical Specifications

Date of Issuance: October 22, 1986.



ATTACHMENT TO LICENSE AMENDMENT NO. 20

FACILITY OPERATING LICENSE NO. DPR-18

DOCKET NO. 50-244

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE	INSERT
6.10-2	6.10-2

- changes shall also be periodically incorporated into the as-built file.
- b. Records of new and irradiated fuel inventory, fuel transfers, and assembly burnup histories.
- c. Records of plant radiation and contamination surveys.
- d. Records of off-site environmental monitoring surveys.
- e. Records of radiation exposure of all plant personnel, including all contractors and visitors to the plant who enter radiation control areas.
- f. Records of radioactivity in liquid and gaseous material released to the environmental and radioactive waste shipments.
- g. Records of transient or operational cycles for those facility components designed for limited number of transients or cycles.
- h. Records of training and qualification for current station technical and operations staff members.
- i. Records of in-service inspections performed pursuant to these Technical Specifications.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR Section 50.59.
- k. Records of meetings of the PORC and the NSARB.
- 1. Records of Quality Assurance activities as required by the QA Manual not listed in 6.10.1.