APPENDIX A

NOTICE OF VIOLATION

Rochester Gas and Electric Corporation
Rochester, New York 14649

Docket No. 50-244
License No. DPR-18

As a result of the inspection conducted on November 4 - 6, 1986, and in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (Enforcement Policy 1986) the following violation was identified:

A. 10 CFR 70.51(c) requires the licensee to establish, maintain, and follow written material control and accounting procedures which are sufficient to enable the licensee to account for the special nuclear material (SNM) in its possession under license.

10 CFR 70.51(d) requires the licensee to conduct physical inventories of the special nuclear material (SNM) in its possession under license at intervals not to exceed twelve months.

Contrary to the above, on November 5, 1986, it was determined that:

1. The licensee failed to establish written material control and accounting procedures to account for the SNM in neutron fission detectors.

2. The licensee failed to conduct physical inventories for the SNM in neutron fission detectors at intervals not to exceed twelve months between December 1983 and November 1986. The last physical inventory of these detectors was conducted on November 14, 1983.

This is a Severity Level IV violation. (Supplement III)

Pursuant to the provisions of 10 CFR 2.201, Rochester Gas and Electric Corporation is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8612230015 861215
PDR ADOCK 05000244
Q PDR