



**Commonwealth Edison**

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920




Regulatory

File Cy.

BBS Ltr. #77-50

January 20, 1977



Mr. James G. Keppler, Regional Director  
Directorate of Regulatory Operations - Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Enclosed please find Reportable Occurrence report number 50-249/1976-36. This report is being submitted to your office in accordance with the Dresden Nuclear Power Station Technical Specifications, Section 6.6.B.

B. B. Stephenson  
Station Superintendent  
Dresden Nuclear Power Station

BBS:jo

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
File/NRC

# LICENSEE EVENT REPORT

CONTROL BLOCK: 

--	--	--	--	--	--

PLEASE PRINT ALL REQUIRED INFORMATION

01	I L D R S 3	0 0 - 0 0 0 0 0 0 - 0 0	4 1 1 1 1 1	0 3
7 8 9	14	15 25	26 30	31 32

01	CONT		L	L	0 5 0 - 0 2 4 9	1 2 2 3 7 6	0 1 2 0 7 7
7 8	57 58	59	60	61	68	69 74	75 80

### EVENT DESCRIPTION

02 | A routine surveillance audit conducted by station personnel revealed that a number  
 03 | of surveillance intervals had been inadvertently exceeded during the six-month  
 04 | period following a Tech Spec revision which limited those intervals. Tech Spec  
 05 | section 1.0.C C (a) and (b) (which became effective in May, 1976) specified that  
 06 | (a) surveillance interval extensions were not to exceed 25% of the interval; and

07	Z Z	A	Z Z Z Z Z Z	Z	Z 9 9 9	Y	(Continued)
7 8 9 10	11	12	17	43	44 47	48	

### CAUSE DESCRIPTION

08 | Station surveillances are scheduled and updated weekly on a computer. From the  
 09 | time surveillance scheduling by computer began until December 6, 1976, surveillance  
 10 | scheduling was performed on a frequency basis. This meant that a monthly item

11	E	0 9 3	NA	B	NA	(Continued)
7 8 9	9	10 12 13	44	45	46	80

12	Z	Z	NA	NA	(Continued)
7 8 9	9	10 11	44	45	80

### PERSONNEL EXPOSURES

13	0 0 0	Z	NA
7 8 9	11	12	13

### PERSONNEL INJURIES

14	0 0 0	NA
7 8 9	11	12

### OFFSITE CONSEQUENCES

15	NA
7 8 9	

### LOSS OR DAMAGE TO FACILITY

16	Z	NA
7 8 9	10	

### PUBLICITY

17	NA
7 8 9	

### ADDITIONAL FACTORS

18	NA
7 8 9	

19	
7 8 9	

NAME: Ralph V. Nimmer PHONE: EXT. 222

EVENT DESCRIPTION (Continued)

(b) that the total combined interval of any 3 consecutive intervals was not to exceed 3.25 times the specified surveillance interval. Surveillance interval violations were identified in both categories described above. It was also noted during the audit that certain surveillance items had not been conducted. (See attached list for titles of surveillance items involved.) (50-249/1976-36)

CAUSE DESCRIPTION (Continued)

was scheduled for the same time period each month regardless of when it had been performed the previous month. Consequently, if a monthly item, for example, were performed nine days "early," by the time the item appeared on the schedule to be performed again, the interval plus 25% would have already elapsed, resulting in a Tech Spec violation.

By June, 1976, a course of action had been decided upon which would ensure that surveillance intervals did not exceed the revised limits. First, the computer was to be reprogrammed to schedule surveillances on a date-done rather than on a frequency basis. A formal request for program modifications was initiated in July, 1976. These modifications had been programmed, tested, and successfully implemented by December, 1976. Secondly, a base date (desirable surveillance date) was to be assigned to each regularly scheduled surveillance item to provide a stable reference point. This phase has been substantially completed, and final base date information is expected to be entered into the computer no later than February 28, 1977.

Successful implementation of the program described above will permit a prompt comparison to be made between a given surveillance item's scheduled date and its base date. In this manner it will be possible to determine readily whether a surveillance item has been performed within the required interval. To ensure that any discrepancy is identified in a timely manner, all surveillance items will be reviewed on a monthly basis.

The number of surveillance items involved in this event represented less than 1% of the total number of surveillances conducted during the period in question. The safety implications of this event, therefore, were considered to be minimal. Surveillance interval violations were identified concurrently for all three units at Dresden.

SURVEILLANCE FREQUENCY VIOLATIONS

UNIT #3

INSTRUMENTATION  
AREA

SURV. FREQ.	SURV. ITEM NO.	* F. Q.	DESCRIPTION	TECH. SPEC.	DATES OF EXCEEDED INTERVAL
M	007	1	APRM Upscale, Inoperative & Downscale Scram	4.2.1	8-17-76 To 9-28-76
M	007	3	APRM Upscale, Inoperative & Downscale Scram	4.2.1	7-19-76 To 10-28-76 8-17-76 To 11-29-76
M	009	1	Condenser Low Vacuum Scram	4.1.2	8-14-76 To 11-26-76
W	016	1	SRM Upscale Rod Block	4.2.1	11-3-76 To 11-13-76
M	018	3	RBM Upscale and Downscale Rod Block	4.2.1	8-7-76 To 11-17-76
M	019	1	APRM Flow Bias Upscale & Downscale Rod Block	4.2.1	8-17-76 To 9-28-76
M	019	3	APRM Flow Bias Upscale & Downscale Rod Block	4.2.1	6-18-76 To 9-28-76; 7-19-76 To 10-28-76; 8-17 To 11-29
M	023	1	Main Steam Line High Flow Isolation	4.2.1	6-19-76 To 7-30-76
M	028	1	Isolation Condenser Steam Line High Flow	4.2.1	9-15-76 To 10-24-76
M	029	1	Isolation Condenser Condensate Line Flow	4.2.1	9-15-76 To 10-24-76
M	042	1	Containment Spray Interlock ECCS (2)	4.2.1	8-17-76 To 9-30-76
M	042	3	Containment Spray Interlocks ECCS (2)	4.2.1	8-17-76 To 12-4-76
M	051	3	Rx Building CCW Radiation Monitor	4.8.C	6-14-76 To 9-29-76
M	052	1	Service Water Radiation Monitor	4.8.C	6-14-76 To 7-23-76

\*F.Q. = Type of Frequency Violation:  
 1 = 1 Frequency Interval Plus 25% Exceeded  
 3 = 3 Times Normal Interval Plus Single Interval 25% Exceeded  
 M = Missed Surveillance



