



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TELEPHONE  
(312) 858-2660

A. RO Inspection Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
RO Chief, FS&EB  
RO:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
RO Files

B. RO Inquiry Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
RO Chief, FS&EB  
RO:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ  
DR Central Files  
RO Files

C. Incident Notification From: Commonwealth Edison Company 50-249  
(Licensee & Docket No. (or License No.))

Transmittal Date : July 23, 1974

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
Licensing (4)  
DR Central Files  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
RO Files



# Telegram

VEA260(1548)(1-030676C200)PD 07/19/74 1546 1016 JUL 18 PM 2:49

ICS IPMVEIC MVN

03257 IDVE MORRIS IL 112 07-19 1137A CDT

PMS JAMES G KEPPLER REGIONAL DIRECTOR WUX TELEGRAMS (OTHER THAN MONEY ORDERS) *dk* (SEE)

DIRECTORATE OF REGULATORY OPERATIONS REGION 3

US ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD

GLEN ELLYN IL 60137

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3.

THIS WILL CONFIRM A CONVERSATION WITH F MAURA OF YOUR OFFICE AT 1050 HOURS THIS DATE CONCERNING HPCI HIGH STEAM FLOW ICELATION SWITCH DPIS 3-2352 FOUND OUT OF FLEX. AS FOUND SET POINT DURING ROUTINE CALIBRATION WAS 283 INCHES OF WATER WHICH IS GREATER THAN ALLOWED BY TABLE 3.2.1 OF THE TECHNICAL SPECICATIONS. THE SWITCH WAS IMMEDIATELY RESET TO OPERATE AT 146.5 INCHES OF WATER INCREASE. DPIS 3-2353 WAS ALSO CHECKED

SF-1201 (R5-69)

AND FOUND TO OPERATE WITH IN TECHNICAL SPECIFICATION LMITS. ADDITIONAL DETAILS ARE FORTH COMING IN THE FORM OF A 10 DAY LETTER

B B STEPHENSON  
SUPERINTENDENT DRESDEN NUCLEAR  
POWER STATION  
COMONWEALTH EDISON CO  
RT 1 MORRIS IL  
NNNN

1016 JUL 18 PM 3:00

JUL 23 1974

SF-1201 (R5-69)