



telegram

1974 JUN 17 PM 5:06

VEA251(1805)(1-03649SC153)PD 06/17/74 1720

ICS IPMVEIB MVN

02133-EDVE MORRIS IL 126 06-17 225P CDT

PMS MR JAMES G KEPPLER REGIONAL DIRECTOR

DIRECTORATE OF REGULATORY REGION 3

WUX US ATOMIC ENERGY **TELEGRAMS (OTHER THAN MONEY ORDERS)**

799 ROOSEVELT RD IS PHYSICAL DELIVERY requested? (YES-AGENT, NO-ADDRESSEE)

AGENT SECTION

ADDRESSEE SECTION

GLENN ELLYN IL 60137

Nbr. & Name

Nbr. 312-858-2660

Date dtd 6-18 Time dtd 937 To 4M By MJA

SUBJECT DPR-25

To be mailed or filed mail

Attempts to deliver (indicate DA or BY)

DRESDEN NUCLEAR POWER STATION UNIT 3.

THIS WILL CONFIRM OUR CONVERSATION WITH F. MAURA OF YOUR OFFICE AT 1315 HOURS THAT DATE CONCERNING A FAILURE TO OPERATE PROPERLY ON MAY 22, 1974 OF MAIN STEAM DRAIN VALVE M03-220-2. WHILE CLOSING THIS VALVE PRIOR TO LOCAL LEAK RATE TESTING THE BREAKER TRIPPED AND REQUIRED RESETTING SEVERAL TIMES BEFORE THE VALVE WOULD FULLY CLOSE THIS PROBLEM WAS NOT NOTED IN THE

SF-1201 (R5-69)



Telegram

1974 JUN 17 PM 5:06

SHIFT ENGINEERS LOG AT THE TIME AND AS A RESULT THIS REPORT IS SUBMITTED LATE. A 10 DAY LETTER DETAILED THE CORRECTING ACTION IS FORTH COMING IN ACCORDANCE WITH REGULATORY GUIDES 1.16.

B.B. STEPHENSON, SUPERTINDENT DRESDEN NUCLEAR POWER STATION COMMONWEALTH EDISON COMPANY RTE 1 MORRIS ILLINOIS 60450

NNNN

JUN 19 1974

1335

SF-1201 (R5-69)