



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690 - 0767

September 8, 1987

Mr. Stephen Sands
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Phillips Building
Bethesda, MD 20014

Subject: Braidwood Station Units 1 and 2
Byron Station Units 1 and 2
LaSalle County Station Units 1 and 2
Dresden Station Units 2 and 3
Zion Station Units 1 and 2
Quad Cities Station Units 1 and 2
"Commonwealth Edison Response to Safety
Issues Management System (SIMS) Update
NRC Docket Nos. 50-456/457, 50-454/455,
50-373/374, 50-237/249, 50-295/304, 50-254/265

Reference: August 6, 1987 letter from D.R. Muller
to L.D. Butterfield

Dear Mr. Sands:

Per our earlier conversation and per the request stated in the
aforementioned referenced letter, I am returning to you the reviewed,
verified and corrected dates of the SIMS printout for each of the
Commonwealth Edison Plants. Additionally I am providing you with a schedule
showing the dates when the remainder of the lists will be completed.


Mr. Sands let me assure you that every effort is being made to
complete the review of the SIMS printout in a timely manner. If you should
have any questions concerning the scheduled or submitted information, please
direct them to this office.

Very truly yours,

Wayne E. Morgan

Wayne E. Morgan
Nuclear Licensing Administrator

3556K



B021
111

PLANT BY PLANT STATUS OF SIMS PRINTOUTS

Braidwood - Completed/Attached
Byron - Completed/Attached
Dresden - Will Be Completed/Partial List Attached
By 10-15-87
LaSalle - Will Be Completed/Partial List Attached
By 9-21-87
Quad Cities - Will Be Completed/No Submittal
By 9-28-87
Zion - Completed/Attached

50-237
RESPONSE TO SAFETY ISSUES MANAGEMENT SYSTEM UP-
DATE

Docket # 50-237
Control # 8709220161
Date 9-8-87 of Document
REGULATORY DOCKET FILE

— NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE
DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN
CHARGED TO YOU FOR A LIMITED TIME PERIOD AND
MUST BE RETURNED TO THE RECORDS FACILITY
BRANCH 016. PLEASE DO NOT SEND DOCUMENTS
CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY
PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST
BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE

_____	_____
_____	_____
_____	_____
_____	_____

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM

PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
BRAIDWOOD 1	05000456	PWR	WEST	3411 MWT	COMMONWEALTH EDISON				IL	3		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL COMP	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M65501	BRAIDWOOD 1 - CONT. LEAK RATE TEST			04/87C 06/87C 03/87C	12/87					H		
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A					
67.3.3	A-17 IMPROVED ACCIDENT MONITORING			10/86C	6/88				H	H		
67.4.1	G-01 RCP TRIP			10/86C	12/87	N/A	N/A			H		
75 (B-77)	B-77 ITEM 2.1 - EQUIPMENT CLASSIFICATION & VE			10/86C	12/87					H	N	
75 (B-86)	B-86 SALEM ATWS 2.2 S-R COMPONENTS			10/86C	6/88					H	N	
75 (B-89)	B-89 SALEM ATWS 4.2.3 & 4.2.4 LIFE COMPONENTS			10/86C	6/88					H	N	
75 (B-90)	B-90 SALEM ATWS 4.3 W AND B&W T.S.			10/86C	6/88					H	N	
75 (B-93)	B-93 SALEM ATWS 4.5.2 & 4.5.3 TEST ALTERNATIV			10/86C	6/88					H	N	
B-56	D-19 DIESEL GENERATOR RELIABILITY				11/88	11/89	N/A	H			N	
HF 1.1	SHIFT STAFFING			10/83	01/84C	10/85C		H				
I.A.1.4	LONG-TERM UPGRADE OF OPERATIONS PERSONNE				04/83	04/83		M				
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING			C	C		N/A					
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M				
I.A.3.1.3.A	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C	C		N/A					
I.A.3.1.3.B	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C	C		N/A					
I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			N/A	N/A	N/A	N/A					
II.B.3.3	POSTACCIDENT SAMPLING - PROCEDURES				12/87							

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
BRAIDWOOD 1	05000456	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3					
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.F.1.2.A	F-20	ACCIDENT-MONITORING - NOBLE GAS MONITOR			C	C						
II.F.1.2.B	F-21	ACCIDENT-MONITORING - IODINE/PARTICULATE										
II.F.1.2.C	F-22	ACCIDENT-MONITORING - CONTAINMENT HIGH-R										
II.F.1.2.D	F-23	ACCIDENT-MONITORING - CONTAINMENT PRESSU										
II.F.1.2.E	F-24	ACCIDENT-MONITORING - CONTAINMENT WATER										
II.F.1.2.F	F-25	ACCIDENT-MONITORING - CONTAINMENT HYDROG										
II.F.2.1		INSTRUMENTATION FOR DETECT. OF INADEQUAT										
II.F.2.2		INSTRUMENTATION FOR DETECT. OF INADEQUAT										
II.F.2.4	F-26	INSTRUMENTATION FOR DETECT. OF INADEQUAT										
II.G.1.1		POWER SUPP. FOR PRESSURIZER RELIEF, BLOCK										
III.A.1.2.1		UPGRADE EMERGENCY SUPPORT FACILITIES - I										
III.D.3.3.1		INPLANT RAD. MONIT. - PROVIDE MEANS TO D										
III.D.3.3.2	F-69	INPLANT RADIATION MONIT. - MODIFICATIONS										
II.K.1.10		IE BULLETINS - OPERABILITY STATUS										
II.K.1.19		IE BULLETINS - TRIP PER LOW LEVEL B/S										
II.K.1.20		IE BULLETINS - PROMPT MANUAL REACTOR TRI										
II.K.1.21		IE BULLETINS - AUTO SG ANTICIPATORY REAC										
II.K.1.5		IE BULLETINS - REVIEW ESF VALVES										
II.K.2.13	F-30	ORDERS ON B&W PLANTS - THERMAL MECHANICA			N/A	N/A	N/A	N/A				

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
BRAIDWOOD 1	05000456	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3					
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.K.2.2	ORDERS ON B&W PLANTS - PROCEDURES TO CON				N/A	N/A	N/A	N/A				
II.K.3.1.B	FINAL RECOMMENDATIONS,B&O TASK FORCE - A				C	C						
II.K.3.10	F-41 FINAL RECOMMENDATIONS,B&O TASK FORCE - P				↓	↓						
II.K.3.12.B	F-42 FINAL RECOM.,B&O TASK FORCE - ANTICIPATO											
II.K.3.25.A	FINAL RECOMMENDATIONS,B&O TASK FORCE - P											
II.K.3.25.B	F-53 FINAL RECOMMENDATIONS,B&O TASK FORCE - P											
II.K.3.5.B	F-39 FINAL RECOMMENDATIONS,B&O TASK FORCE - A											
II.K.3.9	F-40 FINAL RECOMMENDATIONS,B&O TASK FORCE - P				↓	↓						
M64018	BRAIDWOOD 1 - NATURAL CIRCULATION TESTIN				10/86C	12/88					H	
M64020	BRAIDWOOD 1 - PUMPS & VALVES IST				10/86C	10/87					H	
M64024	BRAIDWOOD 1 -IODINE/PARTICULATE SAMPLING				10/86C	5/87C					H	
M64025	BRAIDWOOD 1 - REACTOR SYSTEM TECH. SPECS				10/86C	12/88					H	
M64026	BRAIDWOOD 1 - S.G. TUBE RUPTURE				10/86C	12/88					H	
M64027	BRAIDWOOD 1 - VIBRATION OF D.G. INSTRUME				10/86C	5/87C	N/A	N/A			H	
M64036	BRAIDWOOD 1 - HELB MONITORING/ISOLATION				10/86C	1/20/87C					H	
M64037	BRAIDWOOD 1 - CHECK VALVE TEST TECH. SPE				10/86C	2/17/87C					H	
M64038	BRAIDWOOD 1 - ISI PROGRAM				10/86C	12/88					H	
M64040	BRAIDWOOD 1 - FIRE PROTECTION TECH. SPEC				10/86C	5/21/87C					H	
M64041	BRAIDWOOD 1 - SAFE SHUTDOWN ANALYSIS				10/86C	5/21/87C					H	

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION		
BRAIDWOOD 1	05000456	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3				
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M64042	BRAIDWOOD 1 - SOURCE RANGE CURVE TECH. S			10/86C	7/2/87C					H	
M64043	BRAIDWOOD 1 - CHLORINE DETECTORS			10/86C	04/87C					H	
M64044	BRAIDWOOD 1 - EP EXEMPTION			10/86C	5/28/87C					H	
M64155	BRAIDWOOD 1 - INITIAL TEST PROGRAM			10/86C	5/21/87C					H	
M64156	BRAIDWOOD 1 - CHARCOAL LABORATORY TESTS			10/86C	5/21/87C					H	
M64223	BRAIDWOOD 1 - SI PUMP TECH. SPEC.			11/86C	5/21/87C					H	
M64225	BRAIDWOOD 1 - SALP			12/86C	3/87C	N/A	N/A			X	
M64413	BRAIDWOOD 1 - HELB TECH. SPEC.			09/86C	7/2/87C					H	
M64528	BRAIDWOOD 1 - SMALL BREAK LOCA, ITEM II.			10/86C	3/13/87C					H	
M64530	BRAIDWOOD 1 - INDEPENDENT TECH. SPEC. AU			10/86C	5/21/87C	N/A	N/A			H	
M64823	BRAIDWOOD 1 - FUEL OIL STORAGE TANK SEDI			02/87C	5/5/87C					H	
M64973	BRAIDWOOD 1 - HOLDING COMPANY FORMATION			02/87C	8/87C	N/A	N/A			H	
M65714	BRAIDWOOD 1 - MESAC SYSTEM			07/87	12/87	N/A	N/A				
MPA-A-20	A-20	10 CFR 50.62 OPERATING REACTOR REVIEWS		10/86C	12/87				H	H	
MPA-A-21	A-21	10 CFR 50.61, PRESSURIZED THERMAL SHOCK		10/86C	12/87	N/A	N/A			H	N
MPA-B-09	B-09	CHARGING SYSTEMS PIPE VIBRATIONS		10/86C	6/88			L	M	H	
MPA-C-16	C-16	UTILITY RESPONSES TO STAFF RECOMMENDATIO		10/86C	6/88	N/A	N/A			H	N
MPA-F-71	F-71	I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO		10/86C	12/87					H	
NMSS-2	ACCESS AUTHORIZATION			02/87C	12/87	04/88	/89	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION
BRAIDWOOD 1	05000456	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3		

APPLICABLE ISSUES	IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
NMSS-3 MISC AMEND CONCERN PHYSICAL PROTECTION	07/86C	10/86C	/87	/87	H			
NMSS-4 SEARCHES OF INDIVIDUALS AT POWER REACTOR	07/86C	10/86C	/87	/87	H			
NMSS-5 REPORTING REQUIREMENTS FOR SAFEGUARDS EV	/86C	/86C	/87	/87	H			
NMSS-7 REQUIREMENTS FOR CRIMINAL HISTORY CHECKS	/87	/87	/88	/88	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
BRAIDWOOD 2	05000457	PWR	WEST	3411 MWT	COMMONWEALTH EDISON				IL	3		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M65602	BRAIDWOOD 2 - EXCEPTIONS TO R.G. 1.52 &			03/87C	7/16/87C	N/A	N/A			H		
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A					
B-56	D-19 DIESEL GENERATOR RELIABILITY				11/88	11/89	N/A	H			N	
HF 1.1	SHIFT STAFFING			10/83	01/84C	10/85C		H				
I.A.1.4	LONG-TERM UPGRADE OF OPERATIONS PERSONNE				04/83	04/83		M				
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING			C	C		N/A					
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M				
I.A.3.1.2	REVISE SCOPE & CRITERIA FOR LICENSING EX			C	C		N/A					
I.A.3.1.3.A	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C	C		N/A					
I.A.3.1.3.B	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C	C		N/A					
I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			N/A C	N/A 12/87	N/A	N/A					
II.B.3.3	POSTACCIDENT SAMPLING - PROCEDURES			C	C							
II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI			C	C							
II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO			C	C							
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE			C	C							
II.E.1.1.2	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATION -			↓	↓							
II.E.1.1.3	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATIONS -											
II.E.1.2.1.A	AUXILIARY FEEDWATER SYSTEM INITIATION &											
II.E.1.2.1.B	F-16 AUXILIARY FEEDWATER SYSTEM INITIATION &			↓	↓							

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE					STATE	REGION	OL ISSUE	OL EXPIRATION
BRAIDWOOD 2	05000457	PWR	WEST	3411 MWT	COMMONWEALTH EDISON					IL	3		
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
II.E.1.2.2.A	AUXILIARY FEEDWATER SYSTEM INITIATION &				C	C							
II.E.1.2.2.C	F-17 AUXILIARY FEEDWATER SYSTEM INITIATION &												
II.E.3.1.1	EMERGENCY POWER FOR PRESSURIZER HEATERS												
II.E.4.1.2	DEDICATED HYDROGEN PENETRATIONS - REVIEW												
II.E.4.1.3	F-18 DEDICATED HYDROGEN PENETRATION - INSTALL												
II.E.4.2.1-4	CONTAINMENT ISOLATION DEPENDABILITY - IMP												
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN				C	C	C						
II.E.4.2.6	F-19 CONTAINMENT ISOLATION DEPENDABILITY - CN												
II.E.4.2.7	F-19 CONTAINMENT ISOLATION DEPENDABILITY - RA												
II.F.1.1	F-20 ACCIDENT-MONITORING - PROCEDURES												
II.F.1.2.A	F-20 ACCIDENT-MONITORING - NOBLE GAS MONITOR												
II.F.1.2.B	F-21 ACCIDENT-MONITORING - IODINE/PARTICULATE												
II.F.1.2.C	F-22 ACCIDENT-MONITORING - CONTAINMENT HIGH-R												
II.F.1.2.D	F-23 ACCIDENT-MONITORING - CONTAINMENT PRESSU												
II.F.1.2.E	F-24 ACCIDENT-MONITORING - CONTAINMENT WATER												
II.F.1.2.F	F-25 ACCIDENT-MONITORING - CONTAINMENT HYDROG												
II.F.2.1	INSTRUMENTATION FOR DETECT. OF INADEQUAT												
II.F.2.2	INSTRUMENTATION FOR DETECT. OF INADEQUAT												
II.F.2.4	F-26 INSTRUMENTATION FOR DETECT. OF INADEQUAT												

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
BRAIDWOOD 2	05000457	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3					
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.G.1.1	POWER SUPP. FOR PRESSURIZER RELIEF, BLOCK											
III.A.1.2.1	UPGRADE EMERGENCY SUPPORT FACILITIES - I											
III.D.3.3.1	INPLANT RAD. MONIT. - PROVIDE MEANS TO D											
III.D.3.3.2	F-69	INPLANT RADIATION MONIT. - MODIFICATIONS										
II.K.1.10	IE BULLETINS - OPERABILITY STATUS											
II.K.1.19	IE BULLETINS - TRIP PER LOW LEVEL B/S											
II.K.1.20	IE BULLETINS - PROMPT MANUAL REACTOR TRI											
II.K.1.21	IE BULLETINS - AUTO SG ANTICIPATORY REAC											
II.K.1.5	IE BULLETINS - REVIEW ESF VALVES											
II.K.2.13	F-30	ORDERS ON B&W PLANTS - THERMAL MECHANICA			N/A	N/A	N/A	N/A				
II.K.2.2	ORDERS ON B&W PLANTS - PROCEDURES TO CON				N/A	N/A	N/A	N/A				
II.K.3.1.B	FINAL RECOMMENDATIONS, B&O TASK FORCE - A				C	C						
II.K.3.10	F-41	FINAL RECOMMENDATIONS, B&O TASK FORCE - P										
II.K.3.12.B	F-42	FINAL RECOM., B&O TASK FORCE - ANTICIPATO										
II.K.3.25.A	FINAL RECOMMENDATIONS, B&O TASK FORCE - P											
II.K.3.25.B	F-53	FINAL RECOMMENDATIONS, B&O TASK FORCE - P										
II.K.3.5.B	F-39	FINAL RECOMMENDATIONS, B&O TASK FORCE - A										
II.K.3.9	F-40	FINAL RECOMMENDATIONS, B&O TASK FORCE - P										
M64226	BRAIDWOOD 2 - SALP				12/86C	3/87C	N/A	N/A				

H

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
BRAIDWOOD 2	05000457	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3					
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M64414	BRAIDWOOD 2 - HELB TECH. SPEC.				09/86C	7/2/87C						H
M64529	BRAIDWOOD 2 - SMALL BREAK LOCA, ITEM II.				10/86C	3/13/87C						H
M64531	BRAIDWOOD 2 - INDEPENDENT TECH. SPEC. AU				10/86C	5/21/87C	N/A	N/A				H
M64974	BRAIDWOOD 2 - HOLDING COMPANY FORMATION				02/87C	8/87C	N/A	N/A				H
NMSS-2	ACCESS AUTHORIZATION				02/87C	12/87	04/88	/89	H			
NMSS-3	MISC AMEND CONCERN PHYSICAL PROTECTION O				07/86C	10/86C	/87	/87	H			
NMSS-4	SEARCHES OF INDIVIDUALS AT POWER REACTOR				07/86C	10/86C	/87	/87	H			
NMSS-5	REPORTING REQUIREMENTS FOR SAFEGUARDS EV				/86C	/86C	/87	/87	H			
NMSS-7	REQUIREMENTS FOR CRIMINAL HISTORY CHECKS				/87	/87	/88	/88	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON				IL	3	02/85C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M65362	BYRON 1 - WATER HAMMER FOLLOW-UP			05/87C 05/87C	10/87	N/A				H M		
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A					
67.3.3	A-17 IMPROVED ACCIDENT MONITORING			03/85C	06/87 ⁸⁸	10/87			H			
67.4.1	G-01 RCP TRIP			09/85C	12/87	00/87 ^{12/86}	C					
75 (B-76)	B-76 ITEM 1.1 - POST TRIP REVIEW; PROGRAM DES			10/84C	07/85C	10/84C					N	
75 (B-77)	B-77 ITEM 2.1 - EQUIPMENT CLASSIFICATION & VE			10/84C	01/87C	11/84C					N	
75 (B-78)	B-78 ITEMS 3.1.1 & 3.1.2 -POST MAINTENANCE TE			10/84C	09/85C	10/84C					N	
75 (B-79)	B-79 ITEM 3.1.3 - POST MAINTENANCE TESTING -			10/84C	11/85C	10/84C					N	
75 (B-80)	B-80 ITEM 4.1 - REACTOR TRIP SYSTEM RELIABILI			10/84C	09/85C	11/85C			H			
75 (B-81)	B-81 ITEMS 4.2.1 & 4.2.2 -PREVENTATIVE MAINT			10/84C	04/86C	08/85C					N	
75 (B-82)	B-82 ITEM 4.3 - AUTOMATIC ACTUATION OF SHUNT			10/84C	03/85C	11/85C			M			
75 (B-85)	B-85 SALEM ATWS 1.2 DATA CAPABILITY			10/84C	05/86C	12/87					N	
75 (B-86)	B-86 SALEM ATWS 2.2 S-R COMPONENTS			10/84C	06/87	11/84C					N	
75 (B-87)	B-87 SALEM ATWS 3.2.1 & 3.2.2 S-R COMPONENTS			10/84C	09/85C	10/84C					N	
75 (B-88)	B-88 SALEM ATWS 3.2.3 T.S. S-R COMPONENTS			10/84C	11/85C	10/84C					N	
75 (B-89)	B-89 SALEM ATWS 4.2.3 & 4.2.4 LIFE COMPONENTS			10/84C	06/87	04/86C					N	
75 (B-90)	B-90 SALEM ATWS 4.3 W AND B&W T.S.			10/84C	6/88	10/87 ^{10/87}	6/88				N	
75 (B-92)	B-92 SALEM ATWS 4.5.1 DIVERSE TRIP FEATURES			10/84C	09/85C	11/85C					N	
75 (B-93)	B-93 SALEM ATWS 4.5.2 & 4.5.3 TEST ALTERNATIV			10/84C	6/88	11/85C					N	

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON			IL	3	02/85C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
B-56	D-19 DIESEL GENERATOR RELIABILITY			C	11/88	11/89	N/A	H			N
HF 1.1	SHIFT STAFFING			10/83	01/84C	10/85C		H			
I.A.1.1.1	SHIFT TECHNICAL ADVISOR - ON DUTY			C	C	C	07/86C				
I.A.1.1.4	SHIFT TECHNICAL ADVISOR - DESCRIBE LONG			C	C	C	07/86C				
I.A.1.2	SHIFT SUPERVISOR RESPONSIBILITIES			C	C	C	07/86C				
I.A.1.3.1	F-02 SHIFT MANNING - LIMIT OVERTIME			C	C	C	07/86C				
I.A.1.3.2	F-02 SHIFT MANNING - MIN SHIFT CREW			C	C	C	07/86C				
I.A.1.4	LONG-TERM UPGRADE OF OPERATIONS PERSONNE				04/83	04/83C		M			
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING			C		C	N/A				
I.A.2.1.4	F-03 IMMEDIATE UPGRADING OF RO & SRO TRAINING			C	C	C	07/86C				
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M			
I.A.3.1.3.A	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C		C	N/A				
I.A.3.1.3.B	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C		C	N/A				
I.B.1.2	EVALUATION OF ORGANIZATION & MANAGEMENT			C	C	C	07/86C				
I.C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW			C	C	C	07/86C				
I.C.1.2.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - IN			03/85C	11/86C	12/85C					
I.C.1.3.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - TR			03/85C	11/86C	12/85C					
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES			C	C	C	07/86C				
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY			C	C	C	07/86C				

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM

PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE					STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON					IL	3	02/85C	
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
I.C.4	CONTROL-ROOM ACCESS				C	C	C	07/86C					
I.C.5	F-06 FEEDBACK OF OPERATING EXPERIENCE				C	C	C	07/86C					
I.C.6	F-07 VERIFY CORRECT PERFORMANCE OF OPERATING				C	C	C	07/86C					
I.C.7.1	NSSS VENDOR REV. OF PROC - LOW POWER TES				C	C	C	07/86C					
I.C.7.2	NSSS VENDOR REV. OF PROC - POWER ASCENSI				C	C	C	07/86C					
I.C.8	PILOT MON OF SELECTED EMERGENCY PROC FOR				C	C	C	07/86C					
I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE - 03/85C					12/87	03/85C						
I.D.2.2	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE - 03/85C					12/87	03/85C						
I.D.2.3	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE - 03/85C					12/87	03/85C						
I.G.1.3	TRAINING DURING LOW-POWER TESTING - TRAI				C	C	C	07/86C					
II.B.1.2	F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V				C	C	C	07/86C					
II.B.1.3	F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE				C	C	C	07/86C					
II.B.2.2	PLANT SHIELDING - CORRECTIVE ACTIONS TO				C		N/A	N/A					
II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L				C	C	C	07/86C					
II.B.3.2	POSTACCIDENT SAMPLING - CORRECTIVE ACTIO				C		N/A	N/A					
II.B.3.3	POSTACCIDENT SAMPLING - PROCEDURES				C	C	C	07/86C					
II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI				C	C	C	07/86C					
II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO				C	C	C	07/86C					
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	12/87	N/A	N/A					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3	02/85C				
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.D.1.2.A	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	12/87	N/A	N/A				
II.D.1.2.B	F-14	RELIEF & SAFETY VALVE TEST REQUIREMENTS			C	12/87	N/A	N/A				
II.D.1.3	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	12/87	N/A	N/A				
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE				C	C	C	07/86C				
II.E.1.1.2	F-15	AUXILIARY FEEDWATER SYSTEM EVALUATION -			C	C	C	07/86C				
II.E.1.1.3	F-15	AUXILIARY FEEDWATER SYSTEM EVALUATIONS -			C	C	C	07/86C				
II.E.1.2.1.A	AUXILIARY FEEDWATER SYSTEM INITIATION &				C	C	C	07/86C				
II.E.1.2.1.B	F-16	AUXILIARY FEEDWATER SYSTEM INITIATION &			C	C	C	07/86C				
II.E.1.2.2.A	AUXILIARY FEEDWATER SYSTEM INITIATION &				C	C	C	07/86C				
II.E.1.2.2.C	F-17	AUXILIARY FEEDWATER SYSTEM INITIATION &			C	C	C	07/86C				
II.E.3.1.1	EMERGENCY POWER FOR PRESSURIZER HEATERS				C	C	C	07/86C				
II.E.4.1.2	DEDICATED HYDROGEN PENETRATIONS - REVIEW				C	C	C	07/86C				
II.E.4.1.3	F-18	DEDICATED HYDROGEN PENETRATION - INSTALL			C	N/A	C	07/86C				
II.E.4.2.1-4	CONTAINMENT ISOLATION DEPENDABILITY - IMP				C	C	C	04/85C				
II.E.4.2.5.A	CONTAINMENT ISOLAT. DEPENDABILITY - CNM				C		C	N/A				
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN				C	C	C	07/86C				
II.E.4.2.6	F-19	CONTAINMENT ISOLATION DEPENDABILITY - CN			C	C	C	07/86C				
II.E.4.2.7	F-19	CONTAINMENT ISOLATION DEPENDABILITY - RA			C	C	C	07/86C				
II.F.1.1	F-20	ACCIDENT-MONITORING - PROCEDURES			C	C	C	07/86C				

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM

PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE					STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON					IL	3	02/85C	
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
II.F.1.2.A	F-20	ACCIDENT-MONITORING - NOBLE GAS MONITOR			C	C	C	07/86C					
II.F.1.2.B	F-21	ACCIDENT-MONITORING - IODINE/PARTICULATE			C	C	C	07/86C					
II.F.1.2.C	F-22	ACCIDENT-MONITORING - CONTAINMENT HIGH-R			C	C	C	07/86C					
II.F.1.2.D	F-23	ACCIDENT-MONITORING - CONTAINMENT PRESSU			C	C	C	07/86C					
II.F.1.2.E	F-24	ACCIDENT-MONITORING - CONTAINMENT WATER			C	C	C	07/86C					
II.F.1.2.F	F-25	ACCIDENT-MONITORING - CONTAINMENT HYDROG			C	C	C	07/86C					
II.F.2.1		INSTRUMENTATION FOR DETECT. OF INADEQUAT			C	C	C	07/86C					
II.F.2.2		INSTRUMENTATION FOR DETECT. OF INADEQUAT			C	C	C	07/86C					
II.F.2.4	F-26	INSTRUMENTATION FOR DETECT. OF INADEQUAT			C	C	C	07/86C					
II.G.1.1		POWER SUPP. FOR PRESSURIZER RELIEF,BLOCK			C	C	C	07/86C					
III.A.1.2.1		UPGRADE EMERGENCY SUPPORT FACILITIES - I			C C	C C	C C	07/86C 07/86C					
III.D.3.3.1		INPLANT RAD. MONIT. - PROVIDE MEANS TO D			C	C	C	07/86C					
III.D.3.3.2	F-69	INPLANT RADIATION MONIT. - MODIFICATIONS			C	C	C	07/86C					
II.K.1.10		IE BULLETINS - OPERABILITY STATUS			C	C	C	07/86C					
II.K.1.19		IE BULLETINS - TRIP PER LOW LEVEL B/S			C	C	C	07/86C					
II.K.1.20		IE BULLETINS - PROMPT MANUAL REACTOR TRI			C	C	C	07/86C					
II.K.1.21		IE BULLETINS - AUTO SG ANTICIPATORY REAC			C	C	C	07/86C					
II.K.1.5		IE BULLETINS - REVIEW ESF VALVES			C	C	C	07/86C					
II.K.2.13	F-30	ORDERS ON B&W PLANTS - THERMAL MECHANICA			C	C	C	07/86C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON				IL	3	02/85C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
II.K.2.2	ORDERS ON B&W PLANTS - PROCEDURES TO CON			C	C	C	07/86C					
II.K.3.1.B	FINAL RECOMMENDATIONS,B&O TASK FORCE - A			C	C	C	07/86C					
II.K.3.10	F-41 FINAL RECOMMENDATIONS,B&O TASK FORCE - P			C	C	C	07/86C					
II.K.3.12.A	FINAL RECOM.,B&O TASK FORCE - ANTICIP. T			C		N/A	N/A					
II.K.3.12.B	F-42 FINAL RECOM.,B&O TASK FORCE - ANTICIPATO			C	C	N/A	07/86C					
II.K.3.25.A	FINAL RECOMMENDATIONS,B&O TASK FORCE - P			C	C	C	07/86C					
II.K.3.25.B	F-53 FINAL RECOMMENDATIONS,B&O TASK FORCE - P			C	C	C	07/86C					
II.K.3.31	F-58 FINAL RECOMMENDATIONS,B&O TASK FORCE - C			12/86C	02/87C	2/87C				M		
II.K.3.46	F-61 RESPONSE TO LIST OF CONCERNS FROM ACRS C			C		N/A	N/A					
II.K.3.5.B	F-39 FINAL RECOMMENDATIONS,B&O TASK FORCE - A			C	C	C	07/86C					
II.K.3.9	F-40 FINAL RECOMMENDATIONS,B&O TASK FORCE - P			C	C	C	07/86C					
M56199	BYRON 1 - NATURAL CIRCULATION TESTING			10/84C	12/88 06/87	3/89						
M56200	BYRON 1 - SV & RV (TMI ITEM II.D.1)			10/84C	12/88 06/87	12/88						
M56201	BYRON 1 - PUMP & VALVE IST			10/84C	10/87	10/87						
M56202	BYRON 1 - TURBINE MAINTENANCE PROGRAM			10/84C	05/85C	2/85C						
M56346	BYRON 1 - TECH SPECS FOR FULL POWER			10/84C	02/85C	2/85C						
M56375	BYRON 1 - LEAK BEFORE BREAK			09/84C	08/85C	5/87C						
M57075	BYRON 1 - VENTURE FOULING			10/84C	02/85C	12/85C						
M57076	BYRON 1 - IODINE/PARTICULATE SAMPLING			10/84C	01/87C	5/87C						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION		
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3	02/85C			
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M57077	BYRON 1 - RELOCATION OF CONTROLS FOR NIS			10/84C	11/86C	5/87C					
M57078	BYRON 1 - SEISMIC QUALI. OF WESTINGHOUSE			10/84C	04/87C	5/87C					
M57079	BYRON 1 - REACTOR SYSTEM TECH. SPECS.			10/84C	12/88 06/87	12/88					
M57080	BYRON 1 - STEAM GENERATOR TUBE RUPTURE			10/84C	12/88 06/87	12/88					
M57081	BYRON 1 - POST FUEL LOAD INITIAL TEST PR			10/84C	09/85C	9/85C					
M57082	BYRON 1 - TRENDING FOR BACKUP SMM			10/84C	05/86C	N/A					
M57083	BYRON 1 - CHARGING PUMP DEADHEADING			10/84C	05/86C	5/87C					
M57084	BYRON 1 - CONTROL ROOM VENTILATION SYSTE			10/84C	02/85C	7/85C					
M57085	BYRON 1 - JET IMPINGEMENT EFFECTS			10/84C	02/85C	N/A					
M57086	BYRON 1 - VIBRATION OF D.G. INSTRUMENTAT			10/84C	01/87C	N/A					
M57087	BYRON 1 - CONTROL OF HEAVY LOADS (PHASE			10/84C	02/85C	7/85C					
M57088	BYRON 1 - JIO FOR HELB (SUPERHEAT)			10/84C	02/85C	N/A					
M57089	BYRON 1 - VOLUME REDUCTION SYSTEM			10/84C	02/85C	9/87					
M57090	BYRON 1 - RIVER SCREENHOUSE SEISMIC RESP			10/84C	02/85C	N/A					
M57242	BYRON 1 - LCO RELAXATION			05/84C	12/88	12/88					
M57572	BYRON 1 - REVIEW OF REVISED LICENSED OPE			08/85C	01/86C						
M59027	BYRON 1 - HIGH RAD. AREA ADMIN. CONTROLS			06/85C	10/85C	10/85C					
M59255	BYRON 1 - UPDATED FSAR			04/85C	08/85C	12/88					
M59441	BYRON 1 - HELB MONITORING/ISOLATION			08/85C	02/87C	4/87C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON				IL	3	02/85C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M59599	BYRON 1 - EMERGENCY RELIEF FROM PSI			08/85C	09/85C	N/A						
M59827	BYRON 1 - TECH. SPEC. TYPOGRAPHICAL ERRO			09/85C	02/86C	2/86C						
M60240	BYRON 1 - CHECK VALVE TEST			11/85C	03/87C	3/87C						
M60703	BYRON 1 - INSERVICE INSPECTION PROGRAM			02/86C	6/88	11/87						
M60956	BYRON 1 - RHR PUMP CURVE			03/86C	06/86C	4/86C						
M61093	BYRON 1 - SEISMIC MONITORING INSTRUMENTA			03/86C	04/87C	N/A						
M61547	BYRON 1 - NUREG 0737, I.A.1.1 - SHIFT TE			04/86C	10/86C	10/86C						
M62105	BYRON 1 - 07-03-86 AMENDMENT REQUEST			07/86C	10/86C	10/86C						
M62106	BYRON 1 - 8-5-86 AMENDMENT REQUEST			08/86C	10/86C	10/86C						
M62112	BYRON 1 - SPENT FUEL POOL EXPANSION			08/86C	01/87	12/87	6/88					
M62184	BYRON 1 - ESW TECH. SPECS.			08/86C	6/88	6/88						
M62185	BYRON 1 - COOLING TOWER BASIN LEVEL			08/86C	12/86C	12/86C						
M62730	BYRON 1 - FIRE PROTECTION TECH. SPEC.			08/86C	10/87	11/87						
M62766	BYRON 1 - D.C. ELECTRICAL SOURCES TECH.			08/86C	12/86C	12/86C						
M62791	BYRON 1 - REORGANIZAITON OF STATION MANA			09/86C	7/23/87C	7/87C						
M62830	BYRON 1 - 2.206 ON ILRT			08/86C	02/87C	N/A						
M62865	BYRON 1 - SOURCE RANGE CURVE			09/86C	10/87	10/87						
M63155	BYRON 1 - CRANE STOPS			10/86C	03/87C	N/A	N/A			M		
M63347	BYRON 1 - SALP			10/86C	01/87C	N/A	N/A			M		

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 1	05000454	PWR	WEST	3411 MWT	COMMONWEALTH EDISON			IL	3	02/85C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M63434	BYRON 1 - MATERIAL FALSE STATEMENT ASSIS			11/86C	5/87C	N/A	N/A			M	
M63435	BYRON 1 - D.G. BREAKER			10/86C	6/88	5/87C				M	
M63436	BYRON 2 - D.G. BREAKER			10/86C	6/88	1/87C				M	
M63965	BYRON 1 - CCW SYSTEM VUNERABILITY			11/86C	02/87C	N/A				H	
M63966	BYRON 2 - CCW SYSTEM VUNERABILITY			11/86C	02/87C	N/A				H	
M64206	BYRON 1 - RTD BYPASS MANIFOLD			12/86C	12/87	12/88				M	
M64364	BYRON 1 - FUEL ASSEMBLY RECONSTITUTION			01/87C	05/87C	5/87C				M	
M64719	BYRON 1 - TWO RAD MONITORING INSTRUMENT			02/87C	12/87	6/88				M	
M64799	BYRON 1 - USE OF OPTPIPE			03/87C	8/87C	8/87C				M	
M64876	BYRON 1 - FAN COOLER PERFORMANCE			03/87C	12/87	12/87				M	
M64884	BYRON 1 - HELB TECH. SPECS.			03/87C	7/23/87C	7/87C				M	
M64885	BYRON 2 - HELP TECH. SPECS.			03/87C	7/23/87C	7/87C				M	
M64944	BYRON 1 - COOLING TOWER FANS			03/87C	05/87C	5/87C				M	
MPA-A-20	A-20 10 CFR 50.62 OPERATING REACTOR REVIEWS			06/84C	12/87	6/88			H		
MPA-A-21	A-21 10 CFR 50.61, PRESSURIZED THERMAL SHOCK			10/85C	11/86C	01/86C N/A					N
MPA-C-16	C-16 UTILITY RESPONSES TO STAFF RECOMMENDATIO			06/85C	6/88	02/85C					N
MPA-F-71	F-71 I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO			03/85C	12/87	9/90					
NMSS-2	ACCESS AUTHORIZATION			02/87	12/87	04/88	/89	H			
NMSS-3	MISC AMEND CONCERN PHYSICAL PROTECTION O			07/86	10/86	/87	/87	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE		STATE	REGION	OL ISSUE	OL EXPIRATION	
BYRON 1	05000454	PWR	WEST	3411 MW	COMMONWEALTH EDISON		IL	3	02/85C		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
NMSS-4	SEARCHES OF INDIVIDUALS AT POWER REACTOR			07/86	10/86	/87	/87	H			
NMSS-5	REPORTING REQUIREMENTS FOR SAFEGUARDS EV			/86	/86	/87	/87	H			
NMSS-7	REQUIREMENTS FOR CRIMINAL HISTORY CHECKS			/87	/87	/88	/88	H			
NRR-3	SEVERE ACCIDENT POLICY IMPLEMENTATION ON			09/87	/89		/89	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 2	05000455	PWR	WEST	3411 MWT	COMMONWEALTH EDISON				J'	3		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
MPA-F-77				10/86C 10/86C 10/86C 05/87C	01/87C					H H H M		
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A					
67.3.3	A-17	IMPROVED ACCIDENT MONITORING		10/86C	6/88	2/89			H	H		
67.4.1	G-01	RCP TRIP		10/86C	12/87	12/86C				H		
75 (B-90)	B-90	SALEM ATWS 4.3 W AND B&W T.S.		10/86C	6/88	6/88				H	N	
75 (B-93)	B-93	SALEM ATWS 4.5.2 & 4.5.3 TEST ALTERNATIV		10/86C		11/86C				H	N	
B-56	D-19	DIESEL GENERATOR RELIABILITY		C	11/88	11/89	N/A	H			N	
HF 1.1	SHIFT STAFFING			10/83	01/84C	10/85C		H				
I.A.1.1.1	SHIFT TECHNICAL ADVISOR - ON DUTY			C	C	C	04/85C					
I.A.1.1.4	SHIFT TECHNICAL ADVISOR - DESCRIBE LONG			C C	C C	C C	04/85C 04/85C					
I.A.1.2	SHIFT SUPERVISOR RESPONSIBILITIES			C	C	C	04/85C					
I.A.1.3.1	F-02	SHIFT MANNING - LIMIT OVERTIME		C	C	C	04/85C					
I.A.1.3.2	F-02	SHIFT MANNING - MIN SHIFT CREW		C C	C C	C C	04/85C 04/85C					
I.A.1.4	LONG-TERM UPGRADE OF OPERATIONS PERSONNE				04/83	04/83		M				
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING			C		C	N/A					
I.A.2.1.4	F-03	IMMEDIATE UPGRADING OF RO & SRO TRAINING		C	C	C	04/85C					
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M				

08/03/87

R-1216320-SPC

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 2	05000455	PWR	WEST	3411 MWT	COMMONWEALTH EDISON			IL	3		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
I.A.3.1.3.A	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C		C	N/A				
I.A.3.1.3.B	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C		C	N/A				
I.B.1.2	EVALUATION OF ORGANIZATION & MANAGEMENT			C	C	C	04/85C				
I.C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW			C	C	C	04/85C				
I.C.1.2.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - IN 10/86C				11/86C	12/85C				H	
I.C.1.3.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - TR 10/86C				11/86C	12/85C				H	
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES			C	C	C	04/85C				
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY			C	C	C	04/85C				
I.C.4	CONTROL-ROOM ACCESS			C	C	C	04/85C				
I.C.5	F-06 FEEDBACK OF OPERATING EXPERIENCE			C	C	C	04/85C				
I.C.6	F-07 VERIFY CORRECT PERFORMANCE OF OPERATING			C	C	C	04/85C				
I.C.7.1	NSSS VENDOR REV. OF PROC - LOW POWER TES			C	C	C	04/85C				
I.C.7.2	NSSS VENDOR REV. OF PROC - POWER ASCENSI			C	C	C	04/85C				
I.C.8	PILOT MON OF SELECTED EMERGENCY PROC FOR			C	C	C	04/85C				
I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			N/A	N/A	N/A	N/A				
I.G.1.3	TRAINING DURING LOW-POWER TESTING - TRAI			C	C	C	04/85C				
II.B.1.2	F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V			C	C	C	04/85C				
II.B.1.3	F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE			C	C	C	04/85C				
II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L			C	C	C	04/85C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
BYRON 2	05000455	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3					
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.B.3.3	POSTACCIDENT SAMPLING - PROCEDURES				C	C	C	04/85C				
II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI						C	04/85C				
II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO				C	C	C	04/85C				
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	12/87	N/A	N/A				
II.D.1.2.B	F-14 RELIEF & SAFETY VALVE TEST REQUIREMENTS				10/86C	12/87	N/A				H	
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE				C	C	C	04/85C				
II.E.1.1.2	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATION -				C	C	C	04/85C				
II.E.1.1.3	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATIONS -				C	C	C	04/85C				
II.E.1.2.1.A	AUXILIARY FEEDWATER SYSTEM INITIATION &				C	C	C	04/85C				
II.E.1.2.1.B	F-16 AUXILIARY FEEDWATER SYSTEM INITIATION &				C	C	C	04/85C				
II.E.1.2.2.A	AUXILIARY FEEDWATER SYSTEM INITIATION &				C	C	C	04/85C				
II.E.1.2.2.C	F-17 AUXILIARY FEEDWATER SYSTEM INITIATION &				C	C	C	04/85C				
II.E.3.1.1	EMERGENCY POWER FOR PRESSURIZER HEATERS				C	C	C	04/85C				
II.E.4.1.2	DEDICATED HYDROGEN PENETRATIONS - REVIEW				C	C	C	04/85C				
II.E.4.1.3	F-18 DEDICATED HYDROGEN PENETRATION - INSTALL				C	N/A	C	04/85C				
II.E.4.2.1-4	CONTAIMENT ISOLATION DEPENDABILITY - IMP				C	C	C	04/85C				
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN				C	C	C	04/85C				
II.E.4.2.6	F-19 CONTAINMENT ISOLATION DEPENDABILITY - CN				C	C	C	04/85C				
II.E.4.2.7	F-19 CONTAINMENT ISOLATION DEPENDABILITY - RA				C	C	C	04/85C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 2	05000455	PWR	WEST	3411 MWT	COMMONWEALTH EDISON			IL	3		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.F.1.1	F-20 ACCIDENT-MONITORING - PROCEDURES			C	C	C	04/85C				
II.F.1.2.A	F-20 ACCIDENT-MONITORING - NOBLE GAS MONITOR			C	C	C	04/85C				
II.F.1.2.B	F-21 ACCIDENT-MONITORING - IODINE/PARTICULATE			C	C	C	04/85C				
II.F.1.2.C	F-22 ACCIDENT-MONITORING - CONTAINMENT HIGH-R			C	C	C	04/85C				
II.F.1.2.D	F-23 ACCIDENT-MONITORING - CONTAINMENT PRESSU			C	C	C	04/85C				
II.F.1.2.E	F-24 ACCIDENT-MONITORING - CONTAINMENT WATER			C	C	C	04/85C				
II.F.1.2.F	F-25 ACCIDENT-MONITORING - CONTAINMENT HYDROG			C	C	C	04/85C				
II.F.2.1	INSTRUMENTATION FOR DETECT. OF INADEQUAT			C	C	C	04/85C				
II.F.2.2	INSTRUMENTATION FOR DETECT OF INADEQUAT			C	C	C	04/85C				
II.F.2.4	F-26 INSTRUMENTATION FOR DETECT. OF INADEQUAT			C	C	C	04/85C				
II.G.1.1	POWER SUPP. FOR PRESSURIZER RELIEF, BLOCK			C	C	C	04/85C				
III.A.1.2.1	UPGRADE EMERGENCY SUPPORT FACILITIES - I			C	C	C	04/85C				
III.D.3.3.1	INPLANT RAD. MONIT. - PROVIDE MEANS TO D			C	C	C	04/85C				
III.D.3.3.2	F-69 INPLANT RADIATION MONIT. - MODIFICATIONS			C	C	C	04/85C				
II.K.1.10	IE BULLETINS - OPERABILITY STATUS			C	C	C	04/85C				
II.K.1.19	IE BULLETINS - TRIP PER LOW LEVEL B/S			C	C	C	04/85C				
II.K.1.20	IE BULLETINS - PROMPT MANUAL REACTOR TRI			C	C	C	04/85C				
II.K.1.21	IE BULLETINS - AUTO SG ANTICIPATORY REAC			C	C	C	04/85C				
II.K.1.5	IE BULLETINS - REVIEW ESF VALVES			C	C	C	04/85C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
BYRON 2	05000455	PWR	WEST	3411 MWT	COMMONWEALTH EDISON	IL	3					
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.K.2.13	F-30 ORDERS ON B&W PLANTS - THERMAL MECHANICA				C	C	C	04/85C				
II.K.2.2	ORDERS ON B&W PLANTS - PROCEDURES TO CON				C	C	C	04/85C				
II.K.3.1.B	FINAL RECOMMENDATIONS,B&O TASK FORCE - A				C	C	C	04/85C				
II.K.3.10	F-41 FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C	C	C	04/85C				
II.K.3.12.B	F-42 FINAL RECOM.,B&O TASK FORCE - ANTICIPATO				C	C	C	04/85C				
II.K.3.25.A	FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C	C	C	04/85C				
II.K.3.25.B	F-53 FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C	C	C	04/85C				
II.K.3.31	F-58 FINAL RECOMMENDATIONS,B&O TASK FORCE - C				12/86C	02/87C	2/87C				M	
II.K.3.46	F-61 RESPONSE TO LIST OF CONCERNS FROM ACRS C				C		N/A	N/A				
II.K.3.5.B	F-39 FINAL RECOMMENDATIONS,B&O TASK FORCE - A				C	C	C	04/85C				
II.K.3.9	F-40 FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C	C	C	04/85C				
M57828	BYRON 2 - ALLEGATIONS AND INVESTIGATIONS				06/85C		N/A					
M63156	BYRON 2 - CRANE STOPS				10/86C	03/87C	N/A	N/A			M	
M63239	BYRON 2 - NATURAL CIRCULATION TESTING				10/86C	12/88	3/89				H	
M63241	BYRON 2 - PUMP & VALVE IST				10/86C	10/87	10/87				H	
M63245	BYRON 2 - IODINE/PARTICULATE SAMPLING				10/86C	01/87C	1/97C				H	
M63246	BYRON 2 - REACTOR SYSTEMS TECH. SPECS.				10/86C	12/88	12/88				H	
M63247	BYRON 2 - S.G. TUBE RUPTURE				10/86C	12/88	12/88				H	
M63248	BYRON 2 - VIBRATION OF RG INSTRUMENTATIO				10/86C	01/87C	N/A	N/A			H	

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM

PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 2	05000455	PWR	WEST	3411 MWT	COMMONWEALTH EDISON				IL	3		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M63256	BYRON 2 - LCO RELAXATION			10/86C	12/88	12/88				H		
M63259	BYRON 2 - HELB MONITORING/ISOLATION			10/86C	02/87C	11/86C				H		
M63260	BYRON 2 - CHECK VALVE TEST TECH. SPEC.			10/86C	03/87C	3/87C				H		
M63261	BYRON 2 - ISI PROGRAM			10/86C	6/88	11/87				H		
M63263	BYRON 2 - SEISMIC MONITORING INSTRUMENTA			10/86C	04/87C	N/A	N/A			H		
M63264	BYRON 2 - 7-30-86 AMENDMENT REQUEST			10/86C	10/86C	10/86C				H		
M63265	BYRON 2 - 8/5/86 AMENDMENT REQUEST			10/86C	10/86C	10/86C				H		
M63266	BYRON 2 - SPENT FUEL POOL EXPANSION			10/86C	6/88	6/88				H		
M63267	BYRON 2 - ESW TECH. SPECS			10/86C	6/88	6/88				H		
M63268	BYRON 2 - COOLING TOWER BASIN LEVEL			10/86C	12/86C	12/86C				H		
M63269	BYRON 2 - FIRE PROTECTION TECH. SPEC.			10/86C	10/87	11/87				H		
M63270	BYRON 2 - D.C. ELETRICAL SOURCES TECH. S			10/86C	12/86C	12/86C				H		
M63271	BYRON 2 - PSI RELIEF REQUEST			10/86C	11/86C	N/A				H		
M63272	BYRON 2 - HEATUP & COOLDOWN CURVES			10/86C	11/86C	11/86C				H		
M63273	BYRON 2 - S.G. & PRZR. INDICATIONS			10/86C	11/86C	N/A				H		
M63274	BYRON 2 - SAFE SHUTDOWN ANALYSIS			10/86C	01/87C	11/86C				H		
M63275	BYRON 2 - TEST DEFERRALS			10/86C	01/87C	8/87C				H		
M63276	BYRON 2 - EQ SUPERHEAT STEAM			10/86C	11/86C	N/A				H		
M63277	BYRON 2 - PM ADMINISTRATION			10/86C	C	N/A	N/A			H		

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
BYRON 2	05000455	PWR	WEST	3411 MWT	COMMONWEALTH EDISON			IL	3		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M63348	BYRON 2 - SALP			10/86C	01/87C	N/A	N/A			M	
M63350	BYRON 2 - COOLING TOWER OPERATION			11/86C	6/88	6/88				H	
M63531	BYRON 2 - FIRE PROTECTION REVIEW			11/86C	01/87C	1/87C				M	
M64127	BYRON 2 - INITIAL TEST PROGRAM			12/86C	9/87	11/87				M	
M64207	BYRON 2 - RTD BYPASS MANIFOLD			12/86C	12/87	12/87				M	
M64365	BYRON 2 - FUEL ASSEMBLY RECONSTITUTION			01/87C	05/87C	5/87C				M	
M64720	BYRON 2 - TWO RAD MONITORING INSTRUMENT			02/87C	12/87	6/88				M	
M64945	BYRON 2 - COOLING TOWER FANS			03/87C	05/87C	5/87C				M	
M64975	BYRON 2 - HOLDING COMPANY FORMATION			04/87C	7/87C	N/A	N/A			H	
MPA-A-20	A-20 10 CFR 50.62 OPERATING REACTOR REVIEWS			10/86C	12/87	2/89			H	H	
MPA-A-21	A-21 10 CFR 50.61, PRESSURIZED THERMAL SHOCK			10/86C	6/88	N/A				H	N
MPA-B-09	B-09 CHARGING SYSTEMS PIPE VIBRATIONS			10/86C	6/88			L	M	H	
MPA-C-16	C-16 UTILITY RESPONSES TO STAFF RECOMMENDATIO			10/86C						H	N
MPA-F-71	F-71 I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO			10/86C	12/87	11/90				H	
NMSS-2	ACCESS AUTHORIZATION			02/87	12/87	04/88	/89	H			
NMSS-3	MISC AMEND CONCERN PHYSICAL PROTECTION O			07/86	10/86	/87	/87	H			
NMSS-4	SEARCHES OF INDIVIDUALS AT POWER REACTOR			07/86	10/86	/87	/87	H			
NMSS-5	REPORTING REQUIREMENTS FOR SAFEGUARDS EV			/86	/86	/87	/87	H			
NMSS-7	REQUIREMENTS FOR CRIMINAL HISTORY CHECKS			/87	/87	/88	/88	H			

R-1216320-SPC

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

08/03/87

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	DL ISSUE	OL EXPIRATION
DRESDEN 2	Q5000237	BWR	GE	2527 MW	COMMONWEALTH EDISON				IL	3	12/69C	
APPLICABLE ISSUES				IMPO INIT	IMPO COMP	IMPL COMP	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
A-36 (C-10)	C-10 CONTROL OF HEAVY LOADS OVER SPENT FUEL P			11/82C	07/83C	07/83C			M			
A-36 (C-15)	C-15 CONTROL OF HEAVY LOADS - PHASE II (FOLLO			05/83C	06/85C	06/85C						
A 42	B-05 PIPE CRACKS IN BOILING WATER REACTORS			07/81C	06/84C	N/A				M	N	
B-56	D-19 DIESEL GENERATOR RELIABILITY			09/84C	09/85C	00/87		H			N	
B-59 (E-04)	E-04 BWR SINGLE LOOP OPERATION			09/78C	05/81C	07/81C				L	N	
HF 1.1	SHIFT STAFFING			10/83	01/84C	10/85C		H				
I.A.1.1.1	SHIFT TECHNICAL ADVISOR - ON DUTY			C	11/80C	11/80C	07/81C					
I.A.1.1.3	F-01 SHIFT TECHNICAL ADVISOR - TRAINED PER LL			11/80C	01/82C	01/82C	✓			H		
I.A.1.1.4	SHIFT TECHNICAL ADVISOR - DESCRIBE LONG			C	/81C	181C	03/81C					
I.A.1.2	SHIFT SUPERVISOR RESPONSIBILITIES			C	11/80C	11/80C	07/81C					
I.A.1.3.1	F-02 SHIFT MANNING - LIMIT OVERTIME			04/81C	06/83C	01/84C	✓					
I.A.1.3.2	F-02 SHIFT MANNING - MIN SHIFT CREW			04/81C	06/83C	01/84C						
I.A.1.4	LONG-TERM UPGRADE OF OPERATIONS PERSONNE				04/83			M				
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING			C	11/80C	11/80C						
I.A.2.1.2	IMMEDIATE UPGRADING OF RO & SRO TRAINING				11/80C	11/80C						
I.A.2.1.3	IMMEDIATE UPGRADING OF RO & SRO TRAINING				11/80C	11/80C						
I.A.2.1.4	F-03 IMMEDIATE UPGRADING OF RO & SRO TRAINING			04/81C	01/85C	01/85C	01/85C			H		
I.A.2.1.5	IMMEDIATE UPGRADING OF RO & SRO TRAINING				11/80C	11/80C						
I.A.2.3	ADMINISTRATION OF TRAINING PROGRAMS				11/80C	11/80C						

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 2	05000237	BWR	GE	2527 MWT	COMMONWEALTH	EDISON		IL	3	12/69C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	08/85	03/87	M			
I.A.3.1.1	REVISE SCOPE & CRITERIA FOR LICENSING EX.				11/80C	11/80C					
I.A.3.1.2	REVISE SCOPE & CRITERIA FOR LICENSING EX				11/80C	11/80C					
I.C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW			C	11/80C	11/80C	07/81C				
-I.C.1.2.A	F-04 SHORT-TERM ACCID. & PROCEDURES REV. - IN			04/81C	06/84C	10/85C	✓			H	
-I.C.1.2.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - IN			12/82C	10/87	10/85C	✓			H	
-I.C.1.3.A	F-04 SHORT-TERM ACCID. & PROCEDURES REV - TRA			04/81C	06/84C	10/85C	✓			H	
-I.C.1.3.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - TR			12/82C	10/87	10/85C	✓			H	
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES			C	11/80C	11/80C	07/81C				
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY			C	11/80C	11/80C	07/81C				
I.C.4	CONTROL-ROOM ACCESS			C	11/80C	11/80C	07/81C				
-I.C.5	F-06 FEEDBACK OF OPERATING EXPERIENCE			11/81C	11/81C	11/81C					
I.C.6	F-07 VERIFY CORRECT PERFORMANCE OF OPERATING			11/81C	11/81C	11/81C					
-I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	10/84C	08/86C	12/84C				
-I.D.2.2	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	10/84C	08/86C	12/84C				
-I.D.2.3	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	10/84C	08/86C	12/84C				
II.B.1.1	REACTOR-COOLANT SYSTEM VENTS - DESIGN VE			C	11/80C	11/80C	N/A				
-II.B.1.2	F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V			04/81C	10/83C	10/85C	✓			H	
-II.B.1.3	F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE			04/81C	10/83C	10/85C	✓			H	

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
DRESDEN 2	05000237	BWR	GE	2527 MWT	COMMONWEALTH EDISON	IL	3	12/69C				
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.B.2.1	PLANT SHIELDING - REVIEW DESIGNS				C	11/80C	11/80C	N/A				
- II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L				02/82C	04/83C	04/83C				H	
II.B.2.4	PLANT SHIELDING - EQUIPMENT QUALIFICATIO				C	N/A	N/A	03/83C				
- II.B.3.1	POSTACCIDENT SAMPLING - INTERIM SYSTEM				C	11/80C	11/80C	07/81C				
- II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI				04/81C	01/85C	07/85C				H	
- II.B.4.1	F-13 TRAINING FOR MITIGATING CORE DAMAGE - DE				04/81C	01/85C	01/85C				H	
- II.B.4.2.A	F-13 TRAINING FOR MITIGATING CORE DAMAGE - IN				04/81C	01/85C	01/85C				H	
- II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO				04/81C	01/85C	01/85C				H	
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	11/80C	11/80C	N/A				
II.D.1.2.A	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	12/83C	12/83C	N/A				
- II.D.1.2.B	F-14 RELIEF & SAFETY VALVE TEST REQUIREMENTS				04/81C	08/83C	08/83C	✓			H	
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE				C	11/80C	11/80C					
II.E.4.1.1	DEDICATED HYDROGEN PENETRATIONS - DESIGN				C	11/80C	11/80C	N/A				
- II.E.4.1.3	F-18 DEDICATED HYDROGEN PENETRATION - INSTALL				04/81C	12/81C	12/81C	3/80C				
II.E.4.2.1-4	CONTAINMENT ISOLATION DEPENDABILITY - IMP				C	11/80C	11/80C	07/81C				
II.E.4.2.5.A	CONTAINMENT ISOLAT. DEPENDABILITY - CNM				C	10/82C	10/82C	N/A				
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN				C	10/82C	10/82C	07/81C				
- II.E.4.2.6	F-19 CONTAINMENT ISOLATION DEPENDABILITY - CN				04/81C	10/82C	10/82C	✓			H	
- II.E.4.2.7	F-19 CONTAINMENT ISOLATION DEPENDABILITY - RA				04/81C	10/82C	10/82C	✓			H	

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 2	05000237	BWR	GE	2527 MWT	COMMONWEALTH EDISON				IL	3	12/69C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
II.F.1.2.A	F-20	ACCIDENT-MONITORING	- NOBLE GAS MONITOR	04/81C	10/81C	03/85C	7/83C					
II.F.1.2.B	F-21	ACCIDENT-MONITORING	- IODINE/PARTICULATE	04/81C	10/81C	03/85C	7/84C					
II.F.1.2.C	F-22	ACCIDENT-MONITORING	- CONTAINMENT HIGH-R	04/81C	01/82C	05/85C	5/82C					
-II.F.1.2.D	F-23	ACCIDENT-MONITORING	- CONTAINMENT PRESSU	01/82C	05/83C	05/85C	5/83C			H		
-II.F.1.2.E	F-24	ACCIDENT-MONITORING	- CONTAINMENT WATER	01/82C	05/83C	05/85C	5/83C			H		
-II.F.1.2.F	F-25	ACCIDENT-MONITORING	- CONTAINMENT HYDROG	01/82C	05/83C	05/85C	5/83C			H		
II.F.2.2		INSTRUMENTATION FOR DETECT. OF INADEQUAT			N/A	N/A	N/A					
II.F.2.4	F-26	INSTRUMENTATION FOR DETECT. OF INADEQUAT			04/81C	12/84C	12/84C			H		
III.A.1.1		EMERGENCY PREPAREDNESS, SHORT TERM				11/80C	11/80C					
III.A.1.2.1		UPGRADE EMERGENCY SUPPORT FACILITIES - I			C	11/80C	11/80C	01/83C				
-III.A.2.1	F-67	UPGRADE PREPAREDNESS	- UPGRADE EMERGENCY	04/81C	05/83C	05/83C	✓			H		
III.A.2.2	F-68	UPGRADE PREPAREDNESS	- METEOROLOGICAL D	12/82C	03/86C	03/86C				H		
III.D.1.1.1		PRIMARY COOLANT OUTSIDE CONTAINMENT - LEA			C	11/80C	11/80C	07/81C				
III.D.3.3.1		INPLANT RAD. MONIT. - PROVIDE MEANS TO D			C	11/80C	11/80C	07/81C				
-III.D.3.3.2	F-69	INPLANT RADIATION MONIT.	- MODIFICATIONS	04/81C	02/82C	02/87C	2/82C					
-III.D.3.4.1	F-70	CONTROL ROOM HABITABILITY	- REVIEW	04/81C	05/83C	03/85C	✓			H		
-III.D.3.4.2	F-70	CONTROL ROOM HABITABILITY	- SCHEDULE MOD	04/81C	05/83C	03/85C	✓			H		
II.K.1.4		IE BULLETINS - 79-08			C	C	C	05/79C				
II.K.3.13.A	F-43	FINAL RECOMMENDATIONS, B&O TASK FORCE - H			04/81C	02/82C	02/82C					

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION		
DRESDEN 2	05000237	BWR	GE	2527 MWT	COMMONWEALTH EDISON	IL	3	12/69C			
APPLICABLE ISSUES				IMPO INIT	IMPO COMP	IMPL COMP	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
- II.K.3.13.B	F-43	FINAL RECOMMENDATIONS, B&O TASK FORCE - H	04/81C	02/82C	02/82C	✓					
- II.K.3.14	F-44	FINAL RECOMMENDATIONS, B&O TASK FORCE - I	04/81C	12/81C	12/81C	✓					
- II.K.3.15	F-45	FINAL RECOMMENDATIONS, B&O TASK FORCE - I	04/81C	06/82C	07/82C	✓				H	
- II.K.3.16.A	F-46	FINAL RECOM. B&O TASK FORCE - CHALLENGE	04/81C	10/84C	10/84C	✓				H	
- II.K.3.16.B	F-46	FINAL RECOM. B&O TASK FORCE - CHALLENGE	04/81C	10/84C	10/84C	✓				H	
- II.K.3.17	F-47	FINAL RECOMMENDATIONS, B&O TASK FORCE - E	04/81C	12/83C	12/83C	✓				H	
- II.K.3.18.A	F-48	FINAL RECOMMENDATIONS, B&O TASK FORCE - A	04/81C	12/84C	04/85C	✓				H	
- II.K.3.18.B	F-48	FINAL RECOMMENDATIONS, B&O TASK FORCE - A	04/81C	12/84C	04/85C	✓				H	
- II.K.3.18.C	F-48	FINAL RECOMMENDATIONS, B&O TASK FORCE - A	04/81C	12/84C	04/85C	✓				H	
- II.K.3.19	F-49	FINAL RECOMMENDATIONS, B&O TASK FORCE - I	04/81C	07/81C							
- II.K.3.21.A	F-50	FINAL RECOMMENDATIONS, B&O TASK FORCE - R	04/81C	10/82C	10/82C	✓				H	
- II.K.3.21.B	F-50	FINAL RECOMMENDATIONS, B&O TASK FORCE - R	04/81C	10/82C	10/82C	✓				H	
- II.K.3.24	F-52	FINAL RECOMMENDATIONS, B&O TASK FORCE - S	07/81C	06/82C	06/82C	✓				H	
II.K.3.25.A		FINAL RECOMMENDATIONS, B&O TASK FORCE - P			C						
- II.K.3.25.B	F-53	FINAL RECOMMENDATIONS, B&O TASK FORCE - P	04/81C	10/82C	10/82C	✓				H	
- II.K.3.27	F-54	FINAL RECOMMENDATIONS, B&O TASK FORCE - C	04/81C	11/81C	04/82C 11/81C						
- II.K.3.28	F-55	FINAL RECOMMENDATIONS, B&O TASK FORCE - Q	11/80C	06/86C	06/86C					H	
- II.K.3.29	F-56	FINAL RECOMMENDATIONS, B&O TASK FORCE - P	04/81C	09/81C	01/82C	✓					
- II.K.3.3	F-38	FINAL RECOMMENDATIONS, B&O TASK FORCE - R	04/81C	04/82C	04/82C	✓				H	

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
DRESDEN 2	05000237	BWR	GE	2527 MWT	COMMONWEALTH EDISON	IL	3	12/69C				
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
1 II.K.3.30.A	FINAL RECOMMENDATIONS,B&O TASK FORCE - S				C	01/84C	06/84C	✓	N/A			
- II.K.3.30.B	F-57 FINAL RECOMMENDATIONS,B&O TASK FORCE - S				04/81C	01/84C	06/84C	✓			H	
-II.K.3.31	F-58 FINAL RECOMMENDATIONS,B&O TASK FORCE - C				04/82C	01/84C	01/84C	✓			H	
-II.K.3.44	F-59 FINAL RECOM.,B&O TASK FORCE - EVAL. TRAN				04/81C	12/81C	12/81C	✓				
- II.K.3.45	F-60 FINAL RECOM.,B&O TASK FORCE - MANUAL DEP				04/81C	01/84C	01/84C	✓			H	
1 II.K.3.46	F-61 RESPONSE TO LIST OF CONCERNS FROM ACRS C					11/80C	11/80C	7/81C	C			
II.K.3.57	F-62 IDENTIFY WATER SOURCES PRIOR TO MANUAL A				C			02/86C				
M07644	DRESDEN 2 - CONTROL ROD COUPLING VERIFIC				06/78C	11/83C			L		L	
M11222	DRESDEN 2 - CONVERSION POL TO FTOL				01/79C	05/88			L		L	
M47033	DRESDEN 2 - ISI PROGRAM, SECOND 10 YEARS				10/81C	04/84C			H		H	
M48258	DRESDEN 2 - PROSPOSED TS CHANGE RE SAFET				01/82C	02/84C			L		L	
M48299	DRESDEN 2 - PROPOSED TS CHANGES RE APPEN				03/82C	12/86C			L		L	
M48858	DRESDEN 2 - REVIEW CECO POSITION RE 10CF				10/82C	05/84C						
M49083	DRESDEN 2 - IST PROGRAM, SECOND 10 YRS				10/81C	07/87						
M49361	DRESDEN UNIT 2- DESIGN CODES, LOAD COMBI				01/83C	08/87						
M49363	DRESDEN UNIT 2 -CAPABILITY WITHSTAND WIN				12/82C	10/87						
M49364	DRESDEN UNIT 2 - HIGH ENERGY PIPE BREAK				12/82C	10/83C						
M49365	DRESDEN UNIT 2 - SEISMIC QUALIFICATION [				12/82C	08/87						
M49366	DRESDEN UNIT 2 - THERMAL OVERLOADS				12/82C	07/85C						

R-1216320-SPC

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

08/03/87

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 2	05000237	BWR	GE	2527 MWT	COMMONWEALTH EDISON			IL	3	12/69C	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
MPA-B-63	B-63	INTERIM PROCEDURES FOR SHORT TERM BLACKO		05/81C	03/82C	03/82C		M	H		
MPA-B-70	B-70	FATIGUE TRANSIENT LIMIT TS		07/81C	05/82C	N/A		L		L	N
MPA-B-72	B-72	NUREG 0737 TECH SPECS (GENERIC LETTER 82		05/83C	03/84C	N/A					N
MPA-B-83	B-83	TECH SPECIFICATIONS COVERED BY GENERIC L		03/84C	06/85C	00/87		H			N
MPA-C-02	C-02	BWR-RECIRC. PUMP TRIP (ATWS)		08/76C	08/79C	08/79C			M		
MPA-C-08	C-08	BWR POST LOCA H2 CONTROL		09/75C	01/70C	00/87		L		L	N
MPA-C-11	C-11	RPS POWER SUPPLY		08/78C	06/83C	02/84C		H	L	H	
MPA-D-11	D-11	FISSION GAS RELEASE		11/76C	10/78C	N/A					N
MPA-D-15	D-15	HIGH ENERGY LINE BREAK & CONSEQUENTIAL S		09/78C	02/81C	00/83C		L		L	N
MPA-D-17	D-17	DEFINITION OF OPERABLE		10/80C	06/81C	06/81C		M		M	N
MPA-D-20	D-20	MARK I DRYWELL VACUUM BREAKERS - LICENSE		03/85C	12/86C	10/88			M		
MPA-E-01	E-01	SPENT FUEL POOL EXPANSIONS		05/78C	05/79C	08/82C		H	L	H	
MPA-E-03	E-03	CORE RELOADS REQUIRING PRIOR NRC APPROVA		11/78C	01/70C	N/A		H		H	N
MPA-F-08	F-08	I.D.1.1 DETAILED CONTROL ROOM DESIGN REV		04/83C	10/84C	06/89 P					
MPA-F-63	F-63	III.A.1.2 TECHNICAL SUPPORT CENTER		04/81C	03/86C	03/86C 3/86C				H	
MPA-F-64	F-64	III.A.1.2 OPERATIONAL SUPPORT CENTER		12/82C	03/86C	03/86C 3/86C				H	
MPA-F-65	F-65	III.A.1.2 EMERGENCY OPERATIONS FACILITY		12/82C	03/86C	03/86C 3/86C				H	
MPA-F-66	F-66	III.A.1.2 NUCLEAR DATA LINK		04/81C	07/82C	05/83C 8/85C				H	
MPA-F-71	F-71	I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO		10/84C	12/86C	03/86C 4/89 P					

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM

PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 3	05000249	BWR	GE	2527 MW	COMMONWEALTH EDISON			IL	3	03/71C	10/06
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
A-36 (C-10)	C-10	CONTROL OF HEAVY LOADS OVER SPENT FUEL P		08/81C	07/83C	07/83C			M	M	
A-36 (C-15)	C-15	CONTROL OF HEAVY LOADS - PHASE II (FOLLO		05/83C	06/85C	06/85C					
A-42	B-05	PIPE CRACKS IN BOILING WATER REACTORS		07/81C	06/84C	N/A				M	N
B-56	D-19	DIESEL GENERATOR RELIABILITY		09/84C	08/85C	02/88		H			N
B-58 (E-04)	E-04	BWR SINGLE LOOP OPERATION		09/76C	07/81C	07/81C				L	N
HF 1.1		SHIFT STAFFING		10/83	01/84C	10/85C		H			
I.A.1.1.1		SHIFT TECHNICAL ADVISOR - ON DUTY		C	11/80C	11/80C	07/81C				
I.A.1.1.3	F-01	SHIFT TECHNICAL ADVISOR - TRAINED PER LL		11/80C	01/82C	01/82C				H	
I.A.1.1.4		SHIFT TECHNICAL ADVISOR - DESCRIBE LONG		C	/81C	1/81C 3/81C					
I.A.1.2		SHIFT SUPERVISOR RESPONSIBILITIES		C	11/80C	11/80C	07/81C				
I.A.1.3.1	F-02	SHIFT MANNING - LIMIT OVERTIME		04/81C	06/83C	01/84C					
I.A.1.3.2	F-02	SHIFT MANNING - MIN SHIFT CREW		04/81C	06/83C	01/84C					
I.A.1.4		LONG-TERM UPGRADE OF OPERATIONS PERSONNE			04/83	04/83		M			
I.A.2.1.1		IMMEDIATE UPGRADING OF RO & SRO TRAINING		C	11/80C	11/80C					
I.A.2.1.2		IMMEDIATE UPGRADING OF RO & SRO TRAINING			11/80C	11/80C					
I.A.2.1.3		IMMEDIATE UPGRADING OF RO & SRO TRAINING			11/80C	11/80C					
I.A.2.1.4	F-03	IMMEDIATE UPGRADING OF RO & SRO TRAINING		04/81C	01/85C	01/86C 01/85C				H	
I.A.2.1.5		IMMEDIATE UPGRADING OF RO & SRO TRAINING			11/80C	11/80C					
I.A.2.3		ADMINISTRATION OF TRAINING PROGRAMS			11/80C	11/80C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE					STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 3	05000249	BWR	GE	2527 MWT	COMMONWEALTH EDISON					IL	3	03/71C	10/06
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY		
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M					
I.A.3.1.1	REVISE SCOPE & CRITERIA FOR LICENSING EX				11/80C	11/80C							
I.A.3.1.2	REVISE SCOPE & CRITERIA FOR LICENSING EX				11/80C	11/80C							
I.C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW			C	11/80C	11/80C	07/81C						
- I.C.1.2.A	- F-04 SHORT-TERM ACCID. & PROCEDURES REV. - IN			04/81C	06/84C	10/85C				H			
- I.C.1.2.B	- F-05 SHORT-TERM ACCID. & PROCEDURES REV. - IN			04/81C	10/87	10/85C				H			
- I.C.1.3.A	- F-04 SHORT-TERM ACCID. & PROCEDURES REV - TRA			04/81C	06/84C	10/85C				H			
- I.C.1.3.B	- F-05 SHORT-TERM ACCID. & PROCEDURES REV. - TR			04/81C	10/87	10/85C				H			
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES			C	11/80C	11/80C	07/81C						
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY			C	11/80C	11/80C	07/81C						
I.C.4	CONTROL-ROOM ACCESS			C	11/80C	11/80C	07/81C						
- I.C.5	- F-06 FEEDBACK OF OPERATING EXPERIENCE			11/81C	11/81C	11/81C							
- I.C.6	- F-07 VERIFY CORRECT PERFORMANCE OF OPERATING			11/81C	11/81C	11/81C							
I.D.2.1	- F-08 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	10/84C	08/80C	12/84C						
I.D.2.2	- F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	10/84C	08/80C	12/84C						
I.D.2.3	- F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	10/84C	08/80C	12/84C						
II.B.1.1	REACTOR-COOLANT SYSTEM VENTS - DESIGN VE			C	11/80C	11/80C	N/A						
- II.B.1.2	- F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V			04/81C	10/83C	10/85C				H			
- II.B.1.3	- F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE			04/81C	10/83C	10/85C				H			

R-1216320-SPC

08/05/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 3	05000249	BWR	GE	2527 MWT	COMMONWEALTH EDISON			IL	3	03/71C	10/06
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.B.2.1	PLANT SHIELDING - REVIEW DESIGNS			C	11/80C	11/80C	N/A				
-II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L			02/82C	04/83C	04/83C				H	
II.B.2.4	PLANT SHIELDING - EQUIPMENT QUALIFICATIO			C	N/A	N/A	03/83C				
II.B.3.1	POSTACCIDENT SAMPLING - INTERIM SYSTEM			C	11/80C	11/80C	07/81C				
-II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI			04/81C	01/85C	07/85C				H	
-II.B.4.1	F-13 TRAINING FOR MITIGATING CORE DAMAGE - DE			04/81C	01/85C	01/85C				H	
-II.B.4.2.A	F-13 TRAINING FOR MITIGATING CORE DAMAGE - IM			04/81C	01/85C	01/85C				H	
-II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO			04/81C	01/85C	01/85C				H	
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS			C	11/80C	11/80C	N/A				
II.D.1.2.A	RELIEF & SAFETY VALVE TEST REQUIREMENTS			C	12/83C	12/83C	N/A				
-II.D.1.2.B	F-14 RELIEF & SAFETY VALVE TEST REQUIREMENTS			04/81C	08/83C	08/83C				H	
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE			C	11/80C	11/80C					
II.E.4.1.1	DEDICATED HYDROGEN PENETRATIONS - DESIGN			C	11/80C	11/80C	N/A				
-II.E.4.1.3	F-18 DEDICATED HYDROGEN PENETRATION - INSTALL			04/81C	12/81C	12/81C 7/80C					
II.E.4.2.1-4	CONTAINMENT ISOLATION DEPENDABILITY - IMP			C	11/80C	11/80C	07/81C				
II.E.4.2.5.A	CONTAINMENT ISOLAT. DEPENDABILITY - CNM			C	10/82C	10/82C	N/A				
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN			C	10/82C	10/82C	07/81C				
-II.E.4.2.6	F-19 CONTAINMENT ISOLATION DEPENDABILITY - CN			04/81C	10/82C	10/82C				H	
-II.E.4.2.7	F-18 CONTAINMENT ISOLATION DEPENDABILITY - RA			04/81C	10/82C	10/82C				H	

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 3	05000249	BWR	GE	2527 MWT	COMMONWEALTH EDISON				IL	3	03/71C	10/06
APPLICABLE ISSUES				IMPD. INIT.	IMPD. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
-II.F.1.2.A	F-20	ACCIDENT-MONITORING	- NOBLE GAS MONITOR	04/81C	10/81C	03/85C	7/83c					
-II.F.1.2.B	F-21	ACCIDENT-MONITORING	- IODINE/PARTICULATE	04/81C	10/81C	03/85C	7/84c					
-II.F.1.2.C	F-22	ACCIDENT-MONITORING	- CONTAINMENT HIGH-R	04/81C	01/82C	08/85C	6/82c					
-II.F.1.2.D	F-23	ACCIDENT-MONITORING	- CONTAINMENT PRESSU	01/82C	05/83C	08/85C	5/83c			H		
-II.F.1.2.E	F-24	ACCIDENT-MONITORING	- CONTAINMENT WATER	01/82C	05/83C	08/85C	5/83c			H		
-II.F.1.2.F	F-25	ACCIDENT-MONITORING	- CONTAINMENT HYDROG	01/82C	05/83C	06/85C	5/83c			H		
II.F.2.2	INSTRUMENTATION FOR DETECT. OF INADEQUAT				N/A	N/A	N/A					
-II.F.2.4	F-26	INSTRUMENTATION FOR DETECT. OF INADEQUAT		04/81C	12/84C	12/84C				H		
III.A.1.1	EMERGENCY PREPAREDNESS, SHORT TERM				11/80C	11/80C						
III.A.1.2.1	UPGRADE EMERGENCY SUPPORT FACILITIES - I				C	11/80C	11/80C	01/83C				
-III.A.2.1	F-67	UPGRADE PREPAREDNESS	- UPGRADE EMERGENCY	04/81C	05/83C	05/83C				H		
-III.A.2.2	F-68	UPGRADE PREPAREDNESS	- METEROROLOGICAL D	04/81C	03/86C	02/86C				H		
III.D.1.1.1	PRIMARY COOLANT OUTSIDE CONTAINMENT - LEA				C	11/80C	11/80C	07/81C				
III.D.3.3.1	INPLANT RAD. MONIT. - PROVIDE MEANS TO D				C	11/80C	11/80C	07/81C				
-III.D.3.3.2	F-69	INPLANT RADIATION MONIT.	- MODIFICATIONS	04/81C	02/82C	08/82C						
-III.D.3.4.1	F-70	CONTROL ROOM HABITABILITY	- REVIEW	04/81C	05/83C	02/87C	3/85c			H		
-III.D.3.4.2	F-70	CONTROL ROOM HABITABILITY	- SCHEDULE MOD	04/81C	05/83C	02/87C	3/85c			H		
II.K.1.4	IE BULLETINS - 79-08				C	C	C	05/79C				
-II.K.3.13.A	F-43	FINAL RECOMMENDATIONS, B&O TASK FORCE	- H	04/81C	02/82C	02/82C				H		

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
DRESDEN 3	05000249	BWR	GE	2527 MWT	COMMONWEALTH EDISON	IL	3	03/71C	10/06			
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
-II.K.3.13.B	F-43 FINAL RECOMMENDATIONS, B&O TASK FORCE	- H	04/81C	02/82C	02/82C						H	
-II.K.3.14	F-44 FINAL RECOMMENDATIONS, B&O TASK FORCE	- I	04/81C	12/81C	12/81C							
-II.K.3.15	F-45 FINAL RECOMMENDATIONS, B&O TASK FORCE	- I	04/81C	06/82C	07/82C						H	
-II.K.3.16.A	F-46 FINAL RECOM., B&O TASK FORCE - CHALLENGE	04/81C	10/84C	10/84C							H	
-II.K.3.16.B	F-46 FINAL RECOM., B&O TASK FORCE - CHALLENGE	04/81C	10/84C	10/84C							H	
-II.K.3.17	F-47 FINAL RECOMMENDATIONS, B&O TASK FORCE	- E	04/81C	12/83C	12/83C						H	
II.K.3.18.A	F-48 FINAL RECOMMENDATIONS, B&O TASK FORCE	- A	04/81C	12/84C	12/84C 4/85C						H	
II.K.3.18.B	F-48 FINAL RECOMMENDATIONS, B&O TASK FORCE	- A	04/81C	12/84C	12/84C 4/85C						H	
II.K.3.18.C	F-48 FINAL RECOMMENDATIONS, B&O TASK FORCE	- A	04/81C	12/84C	12/84C 4/85C						H	
II.K.3.19	F-49 FINAL RECOMMENDATIONS, B&O TASK FORCE	- I	04/81C	07/81C	N/A							
-II.K.3.21.A	F-50 FINAL RECOMMENDATIONS, B&O TASK FORCE	- R	04/81C	10/82C	10/82C						H	
-II.K.3.21.B	F-50 FINAL RECOMMENDATIONS, B&O TASK FORCE	- R	04/81C	10/82C	10/82C						H	
-II.K.3.24	F-52 FINAL RECOMMENDATIONS, B&O TASK FORCE	- S	07/81C	06/82C	06/82C						H	
II.K.3.25.A	FINAL RECOMMENDATIONS, B&O TASK FORCE	- P		C	C							
-II.K.3.25.B	F-53 FINAL RECOMMENDATIONS, B&O TASK FORCE	- P	04/81C	10/82C	10/82C						H	
-II.K.3.27	F-54 FINAL RECOMMENDATIONS, B&O TASK FORCE	- C	04/81C	11/81C	04/82C 11/81C							
4 II.K.3.28	F-55 FINAL RECOMMENDATIONS, B&O TASK FORCE	- Q	11/80C	06/86C	06/86C						H	
-II.K.3.29	F-56 FINAL RECOMMENDATIONS, B&O TASK FORCE	- P	04/81C	09/81C	01/82C							
-II.K.3.3	F-38 FINAL RECOMMENDATIONS, B&O TASK FORCE	- R	04/81C	04/82C	04/82C						H	

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
DRESDEN 3	05000249	BWR	GE	2527 MWT	COMMONWEALTH EDISON	IL	3	03/71C	10/06			
APPLICABLE ISSUES					IMPO INIT.	IMPO COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.K.3.30.A	FINAL RECOMMENDATIONS,B&O TASK FORCE - S				C	01/84C	01/84C	04/84N/A				
- II.K.3.30.B	F-57 FINAL RECOMMENDATIONS,B&O TASK FORCE - S				04/81C	01/84C	01/84C	06/84C			H	
- II.K.3.31	F-58 FINAL RECOMMENDATIONS,B&O TASK FORCE - C				04/82C	01/84C	01/84C				H	
- II.K.3.44	F-59 FINAL RECOM.,B&O TASK FORCE - EVAL. TRAN				04/81C	12/81C	12/81C					
- II.K.3.45	F-60 FINAL RECOM.,B&O TASK FORCE - MANUAL DEP				04/81C	01/84C	01/84C				H	
II.K.3.46	F-61 RESPONSE TO LIST OF CONCERNS FROM ACRS C					11/80C	11/80C	7/81C				
II.K.3.57	F-62 IDENTIFY WATER SOURCES PRIOR TO MANUAL A				C		C	7/81C	02/86C			
M08586	DRESDEN 3 - CONTROL ROD COUPLING VERIFIC				06/78C	11/83C			H		H	
M47095	DRESDEN 3-ISI PROGRAM, SECOND 10 YRS				10/81C	04/84C			H		H	
M47096	DRESDEN 3 - IST PROGRAM, SECOND 10 YRS				10/81C	07/87			H		H	
M48259	DRESDEN 3 - PROPOSED TS CHANGE RE SAFETY				01/82C	02/84C			L		L	
M48300	DRESDEN 3 - PROPOSED TS CHANGES RE APPEN				03/82C	12/86C			L		L	
M48321	DRESDEN 3 - ANALYSIS FOR REDUCED FLOW OP				01/82C	03/84C			M		M	
M48857	DRESDEN 3 - REVIEW CECO POSITION RE 10CF				09/82C	05/84C						
M51067	DRESDEN UNIT 3- MULTIPLE CHANGES TO ADMI				02/83C	03/85C						
M51517	DRESDEN 3 - ECONOMIC GENERATION CONTROL				05/83C	05/85C						
M51519	DRESDEN 3 - LIMIT REQUIREMENT TO VERIFY				05/83C	11/83C						
M51524	DRESDEN 3 - NUREG 0737 - ITEM III.K.3.15				04/83C	12/83C						
M51546	DRESDEN 3 - CONTROL ROD DRIVE SCRAM TEST				05/83C	12/83C						

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
DRESDEN 3	05000249	BWR	GE	2527 MWT	COMMONWEALTH EDISON			IL	3	03/71C	10/06
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
MPA-E-01	E-01 SPENT FUEL POOL EXPANSIONS			08/78C	01/78C	08/82C		H	L	H	
MPA-F-08	F-08 I.D.1.1 DETAILED CONTROL ROOM DESIGN REV			04/83C	10/84C	08/88 P					
- MPA-F-63	F-63 III.A.1.2 TECHNICAL SUPPORT CENTER			04/81C	03/86C	03/86C				H	
- MPA-F-64	F-64 III.A.1.2 OPERATIONAL SUPPORT CENTER			04/81C	03/86C	03/86C				H	
- MPA-F-65	F-65 III.A.1.2 EMERGENCY OPERATIONS FACILITY			04/81C	03/86C	03/86C				H	
- MPA-F-66	F-66 III.A.1.2 NUCLEAR DATA LINK			04/81C	07/82C	05/83C <u>8/85C</u>				H	
MPA-F-71	F-71 I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO			10/84C	12/86C	10/86C <u>6/88P</u>					
NMSS-2	ACCESS AUTHORIZATION			02/87	12/87	04/88	/89	H			
NMSS-3	MISC AMEND CONCERN PHYSICAL PROTECTION O			07/86	10/86	/87	/87	H			
NMSS-4	SEARCHES OF INDIVIDUALS AT POWER REACTOR			07/86	10/86	/87	/87	H			
NMSS-5	REPORTING REQUIREMENTS FOR SAFEGUARDS EV			/86	/86	/87	/87	H			
NMSS-7	REQUIREMENTS FOR CRIMINAL HISTORY CHECKS			/87	/87	/88	/88	H			
NRR-3	SEVERE ACCIDENT POLICY IMPLEMENTATION ON			09/87	/89		/89	H			

List Appears to Be Missing The Following MPAs

- 1) A-07
- 2) A-14
- 3) A-15
- 4) B-17
- 5) E-03
- 6) F-51
- 7) A-01

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM

PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION		
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON	IL	3	04/82C	04/22		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A				
67.3.3 ✓✓	A-17 IMPROVED ACCIDENT MONITORING			04/83C	12/87	00/87	8/87		H	L 51102	
75 (B-76)	B-76 ITEM 1.1 - POST TRIP REVIEW; PROGRAM DES			11/83C	07/85C	11/83C				L	N
75 (B-77) ✓✓	B-77 ITEM 2.1 - EQUIPMENT CLASSIFICATION & VE			11/83C	10/87 4/88	00/87	GL 83-28			L 52850	N
75 (B-78)	B-78 ITEMS 3.1.1 & 3.1.2 -POST MAINTENANCE TE			11/83C	05/85C	11/83C				L	N
75 (B-79)	B-79 ITEM 3.1.3 - POST MAINTENANCE TESTING -			11/83C	08/85C	11/83C				M	N
75 (B-85)	B-85 SALEM ATWS 1.2 DATA CAPABILITY			11/84C	05/85C	04/82C				L	N
75 (B-86) ✓✓	B-86 SALEM ATWS 2.2 S-R COMPONENTS			11/84C	11/87 4/88	00/87				L 53684	N
5 (B-87)	B-87 SALEM ATWS 3.2.1 & 3.2.2 S-R COMPONENTS			11/84C	05/85C	02/84C				L	N
75 (B-88)	B-88 SALEM ATWS 3.2.3 T.S. S-R COMPONENTS			11/84C	08/85C	02/84C				L	N
75 (B-92)	B-92 SALEM ATWS 4.5.1 DIVERSE TRIP FEATURES			11/84C	05/85C	06/84C				L	N
75 (B-93) ✓✓	B-93 SALEM ATWS 4.5.2 & 4.5.3 TEST ALTERNATIV			11/84C	12/87 4/88	00/87				L 53714	N
75 (B-94) ✓✓	B-60 QUALIFICATION OF CLASS IE SAFETY-RELATED			08/80C	09/86C	09/86 C			H	H	
A-36 (C-15)	C-15 CONTROL OF HEAVY LOADS - PHASE II (FOLLO			05/83C	03/85C	12/83C				L	
A-42 ✓	B-05 PIPE CRACKS IN BOILING WATER REACTORS			07/82C	06/84C	1784C	GL 84-11			L	N
B-56 ✓	D-19 DIESEL GENERATOR RELIABILITY			09/84C	08/84C	03/84C		H		L	N
HF 1.1	SHIFT STAFFING			10/83	01/84C	10/85C		H			
I.A.1.1.1	SHIFT TECHNICAL ADVISOR - ON DUTY			C	C	C	02/82C				
I.A.1.1.4	SHIFT TECHNICAL ADVISOR - DESCRIBE LONG			C	C	C	02/82C				
				C	C	C	02/82C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON				IL	3	04/82C	04/22
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
I.A.1.2	SHIFT SUPERVISOR RESPONSIBILITIES				C	C	C	11/81C				
I A 1.3.1	F-02 SHIFT MANNING - LIMIT OVERTIME				C	C	C	10/81C				
I A.1.3.2	F-02 SHIFT MANNING - MIN SHIFT CREW				C	C	C	10/81C				
I.A.1.4 ✓	LONG-TERM UPGRADE OF OPERATIONS PERSONNE					04/83	04/83		M			
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING				C			N/A				
I.A.2.1.4	F-03 IMMEDIATE UPGRADING OF RO & SRO TRAINING				C	C	C	03/86C				
I.A.2.7 ✓	ACCREDITATION OF TRAINING INSTITUTIONS				03/85	12/86	03/85	03/87	M			
I.A.3.1.3.A	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI				C			N/A				
I.A.3.1.3.B	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI				C			N/A				
I.B.1.2	EVALUATION OF ORGANIZATION & MANAGEMENT				C	C	C	10/81C				
I C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW				C	C	C	10/81C				
I.C.1.2.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - IN 07/84C					10/85C	09/85C				L	
I.C.1.3.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV - TR 07/84C					10/85C	09/85C				L	
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES				C	C	C	03/86C				
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY				C	C	C	11/81C				
I.C.4	CONTROL-ROOM ACCESS				C	C	C	04/81C				
I.C.5	F-06 FEEDBACK OF OPERATING EXPERIENCE				C	C	C	04/81C				
I.C.6	F-07 VERIFY CORRECT PERFORMANCE OF OPERATING				C	C	C	10/81C				
I.C.7.1	NSSS VENDOR REV. OF PROC - LOW POWER TES				C	C	C	07/82C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON			IL	3	04/82C	04/22
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
I.C.7.2	NSSS VENDOR REV. OF PROC - POWER ASCENSI			C	C	C	07/82C				
I.C.8	PILOT MON OF SELECTED EMERGENCY PROC FOR			C	C	C	02/82C				
I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE - 04/83C				06/84C	12/82C				L	
I.D.2.2	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE - 04/83C				06/84C	12/82C				L	
I.D.2.3	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE - 04/83C				06/84C	12/82C				L	
I.G.1.3	TRAINING DURING LOW-POWER TESTING - TRAI			C	C	C	12/83C				
II.B.1.2	F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V			C	C	C	03/86C				
II.B.1.3	F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE			C	C	C	03/86C				
II.B.2.2	PLANT SHIELDING - CORRECTIVE ACTIONS TO			C			N/A				
II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L			C	C	C	04/86C				
II.B.3.2	POSTACCIDENT SAMPLING - CORRECTIVE ACTIO			C			N/A				
II.B.3.3	POSTACCIDENT SAMPLING - PROCEDURES			C	C	C	01/82C				
II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI			C			01/82C				
II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO			C	C	C	11/81C				
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	04/82C	N/A				
II.D.1.2.A	RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	04/82C	N/A				
II.D.1.2.B	F-14 RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	04/82C				L	
II.D.1.3	RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	04/82C	N/A				
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE			C	C	C	04/84C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON			IL	3	04/82C	04/22
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.E.4.1.2	DEDICATED HYDROGEN PENETRATIONS - REVIEW			C			03/86C				
II.E.4.1.3	F-18 DEDICATED HYDROGEN PENETRATION - INSTALL			C			03/86C				
II.E.4.2.1-4	CONTAINMENT ISOLATION DEPENDABILITY - IMP			C			02/84C				
II.E.4.2.5.A	CONTAINMENT ISOLAT. DEPENDABILITY - CNM			C			N/A				
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN			C			N/A				
II.E.4.2.6	F-19 CONTAINMENT ISOLATION DEPENDABILITY - CN			C			00/86C				
II.E.4.2.7	F-19 CONTAINMENT ISOLATION DEPENDABILITY - RA			C			02/84C				
II.F.1.1	F-20 ACCIDENT-MONITORING - PROCEDURES			C	C	C	01/82C				
II.F.1.2.A	F-20 ACCIDENT-MONITORING - NOBLE GAS MONITOR			C	C	C	01/82C				
II.F.1.2.B	F-21 ACCIDENT-MONITORING - IODINE/PARTICULATE			C	C	C	01/82C				
II.F.1.2.C	F-22 ACCIDENT-MONITORING - CONTAINMENT HIGH-R			C	C	C	01/82C				
II.F.1.2.D	F-23 ACCIDENT-MONITORING - CONTAINMENT PRESSU			C	C	C	01/82C				
II.F.1.2.E	F-24 ACCIDENT-MONITORING - CONTAINMENT WATER			C	C	C	01/82C				
II.F.1.2.F	F-25 ACCIDENT-MONITORING - CONTAINMENT HYDROG			C	C	C	01/82C				
II.F.2.4	F-26 INSTRUMENTATION FOR DETECT. OF INADEQUAT			12/82C	03/87C	00/87					
III.A.1.2.1	UPGRADE EMERGENCY SUPPORT FACILITIES - I			C	C	C	06/83C				
				C	C	C	06/83C				
III.D.1.1.1	PRIMARY COOLANT OUTSIDE CONTAINMENT - LEA			C	C	C	01/82C				
III.D.3.3.1	INPLANT RAD. MONIT. - PROVIDE MEANS TO D			C	C	C	06/82C				
III.D.3.3.2	F-69 INPLANT RADIATION MONIT. - MODIFICATIONS			C	C	C	06/82C				

0737

RVWLIS ?
date to submit

L RVWLIS

0737 RVWLIS ?
date to outage

L RVWLIS

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON				IL	3	04/82C	04/22
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.K.1.10	IE BULLETINS - OPERABILITY STATUS				C	C	C	02/81C				
II.K.1.22	IE BULLETINS - AUX. HEAT REM SYSTM, PROC				C	C	C	00/83C				
II.K.1.23	IE BULLETINS - RV LEVEL, PROCEDURES				C	C	C	04/86C				
II.K.1.5	IE BULLETINS - REVIEW ESF VALVES				C	C	C	04/83C				
II.K.3.13.B	F-43 FINAL RECOMMENDATIONS,B&O TASK FORCE - H				C	C	C	02/84C				
II.K.3.15	F-45 FINAL RECOMMENDATIONS,B&O TASK FORCE - I				C	C	C	02/84C				
II.K.3.16.B	F-46 FINAL RECOM.,B&O TASK FORCE - CHALLENGE				C							?
II.K.3.18.A	F-48 FINAL RECOMMENDATIONS,B&O TASK FORCE - A				04/83C	04/83C	05/86C					
II.K.3.18.B	F-48 FINAL RECOMMENDATIONS,B&O TASK FORCE - A				04/83C	04/83C	05/86C					
II.K.3.18.C	F-48 FINAL RECOMMENDATIONS,B&O TASK FORCE - A				04/83C	04/83C	05/86C					
II.K.3.21.B	F-50 FINAL RECOMMENDATIONS,B&O TASK FORCE - R				C	C	C	02/84C				
II.K.3.22.A	F-51 FINAL RECOMMENDATIONS,B&O TASK FORCE - R				C	C	C	11/81C				
II.K.3.22.B	F-51 FINAL RECOMMENDATIONS,B&O TASK FORCE - R				C	C	C	11/81C				
II.K.3.24	F-52 FINAL RECOMMENDATIONS,B&O TASK FORCE - S				C	C	C	04/86C				
II.K.3.25.A	FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C	C	C	07/86C				
II.K.3.25.B	F-53 FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C	C	C	07/86C				
II.K.3.27	F-54 FINAL RECOMMENDATIONS,B&O TASK FORCE - C				C	C	C	11/81C				?
II.K.3.28	F-55 FINAL RECOMMENDATIONS,B&O TASK FORCE - Q				C							
M52073	LA SALLE UNIT 1 - REVIEW OF SEISMIC & LO				07/83C	11/83C	8/83	H			H	

M52073

LA SALLE UNIT 1 - REVIEW OF SEISMIC & LO 07/83C

11/83C

8/83

H

H

10/01/83 closed as L.C. 2.C.(12)

Heavy Loads GL 85-11

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON	IL	3	04/82C	04/22			
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M52297	LA SALLE UNIT 1- REVIEW OF EXTENDED BLOW				09/83C	05/86C	<u>5/19/86</u>		L		L	
M52716	LASALLE 1 - REACTOR FEEDWATER INBOARD CH				11/83C	<u>5/19/86</u> 12/83C			H		H	<i>AS Ch. No. 64-11-000</i>
M53303	LA SALLE UNIT 1 - EXIGENT TECH SPEC CHAN				12/83C	03/84C	<u>3/19/84</u>		H		H	
M53382	LA SALLE UNIT 1 - TECH SPEC CHANGES FOR				01/84C	01/84C	<u>1/17/84</u>		H		H	
M53466	LA SALLE UNIT 1 - 2.206 REQUEST FROM GOG				12/84C	03/84C			H		H	<i>Responded to delegation</i>
M53480	LASALLE UINT 1 UPGRADE THE TECH SPEC TO				01/84C	08/84C	<u>8/08/84</u>		L		L	
M54308	LASALLE 1 - CONTROL RAD. CONT. MATERIALS				03/84C	04/84C			L		L	
M54970	LASALLE 2 - ITEM 1.1 - POST TRIP REVIEW				04/85C	07/85C	<u>11/83C</u>		L		L	<i>See page 376</i>
M54971	LA SALLE UNIT 1 - MEETING TO DISCUSS FI				05/84C	06/84C	<u>6/84C</u>		H		H	
M54995	LA SALLE UNIT 1 - REVIEW INSERVICE TESTI				05/84C	05/86C	6/84C		L		L	<i>IST</i>
M55081	LASALLE UNIT 1 - EXIGENT T/S CHANGE TO T				05/84C	07/84C	<u>7/03/84C</u>		H		H	
M55564	LA SALLE UNIT 1 - USE OF ASME CODE CASE				08/84C	08/84C						<i>FSAR</i>
M55580	LA SALLE UNIT 1 - CHANGE ACTION STATEMEN				07/84C	11/84C	<u>11/09/84</u>		M		M	
M55649	LA SALLE UNIT 1 - REVIEW FIRE DAMPER SUR				09/84C	05/85C			M		M	
M55773	LA SALLE 1 - REVISE TECH. SPECS FOR REAC				09/84C	01/85C	<u>1/08/85</u>		M		M	
M56087	LA SALLE 1 - CONFIRMATORY REVIEW OF ELE				08/84C	<u>1/88</u> 10/87			L		L	<i>NOT CLOSED</i>
M56457	LA SALLE 1 - LOSS OF FEEDWATER HEATING A				12/84C	12/84C	<u>12/15/84</u>					<i>Meeting</i>
M56626	LA SALLE UNIT 1 - EXTENSION OF DEADLINE				01/85C	03/85C	<u>3/29/85</u>					<i>Letter 86?</i>
M56675	LA SALLE UNIT 1 - MEETING TO DISCUSS SLE				01/85C	10/85C						

R-1216320-SPC

SAFETY ISSUES MANAGEMENT SYSTEM
PLANT DATA

08/03/87

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH	EDISON	IL	3	04/82C	04/22	
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M56734	LA SALLE UNIT 1 - T/S/ CHANGE FOR SBGTS			01/85C	04/85C	4/29/85					
M56908	LA SALLE 1 - CHANNEL CHECK REQUIREMENTS			02/85C	04/85C						
M57475	LA SALLE 1 - ADDITION OF SUPPRESSION POO			04/85C	10/22/85						
M57523	LA SALLE 1 - REVIEW OF REVISED LICENSED			08/83C	10/85C						
M57548	LA SALLE 1 - SPECIFICATION 3.0.4 DOES NO			06/85C	10/85C	10/02/85					
M57550	LA SALLE 1 - DECAY CORRECTION OF LIQUID			04/85C	10/02/85						
M57552	LA SALLE 1 - CONTROL ROOM EMERGENCY MAKE ^{up}			04/85C	10/85C						
M57560	LA SALLE 1 - RCJC PUMP ROOM DIFFERENTIAL			04/85C	10/85C	10/02/85					
M57562	LA SALLE 1 - RPIS INDICATION AND SURVEIL			04/85C	10/85C	10/02/85					
M57564	LA SALLE 1 - CORRECTION OF TYPOGRAPHICAL			04/85C	10/85C	10/02/85					
M57593	LA SALLE 1 - PROPOSED ELIMINATION OF PIP			04/85C	09/85C						
M57766	LA SALLE 1 -DISPOSAL OF LOW LEVEL RADIOA			05/85C	01/87C				L	sludge	
M57770	LA SALLE 1 - FINE MOTION CONTROL ROD DRI			05/85C	08/85C	8/09/85					
M57782	LA SALLE 1 - ACCEPTANCE CRITERIA FOR FIR			05/85C	07/85C					Fire steps	
M59210	LA SALLE 1 - MODIFICATION OF ADS LOGIC T			07/85C	11/85C	11/01/85					
M59211	LA SALLE 1 - WAIVER OF 18-MONTH SURVEILL			07/85C	09/85C	9/20/85					
M59462	LA SALLE 1 - REVISION TO SRV SETPOINTS A			08/85C	10/85C	10/31/85					
M59575	LA SALLE 1 - APPLICATION OF MECHANICAL S			07/85C	11/85C	11/13/85			MSIP letter		
M59627	LA SALLE 1 - APRM CALIBRATION GAIN ADJUS			08/85C	11/85C	11/20/85					

MSIP letter

L sludge

Fire steps

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH	EDISON		IL	3	04/82C	04/22
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M59628	LASALLE 1 - CONTROL ROD DRIVE SCRAM ALAR			08/85C	05/86C	5/06/86					
M59703	LA SALLE 1 - EXTENSION OF SURVEILLANCE I			09/85C	10/85C	10/01/85					
M59766	LA SALLE 1 - COMPISP, INC. HYDROGEN OXYG			09/85C	11/06/85			50.49 issue			
M59837	LA SALLE 1 - REPLACEMENT OF VENT AND PUR			10/85C	04/86C	4/02/86					
M59915	LA SALLE 1 - REMOVE ECCS/RCIC TESTABLE C			10/85C	12/85C	12/06/85					
M59916	LA SALLE 1 - SOURCE RANGE MONITOR OPERAB			10/85C	01/86C	1/07/86					
M60033	LA SALLE 1 - CYCLE 2 - RELOAD LICENSING			10/85C	04/86C	04/18/86					
M60124	LA SALLE 1 - LOW AND DEGRADED GRID VOLTA			11/85C	05/86C	5/09/86					
M60126	LA SALLE 1 - TECH. SPEC. CHANGE TO INCOR			11/85C	02/86C	2/04/86					
M60127	LA SALLE 1 - ADDITION OF AN EXCESS FLOW			11/85C	02/86C	2/10/86					
M60258	LA SALLE 1 - ADMINISTRATIVE CONTROL OF H			12/85C	03/86C	3/12/86					
M60260	LA SALLE 1 - REMOVAL OF UNQUALIFIED INST			12/85C	03/86C	3/19/86					
M60407	LA SALLE 1 - MANAGEMENT ORGANIZATIONAL C			12/85C	12/86C	11/21/86					
M60496	LA SALLE 1 - CHANGE THE MAIN STEAM LINE			01/86C	03/86C	3/13/86					
M60644	LA SALLE 1 - REMOVAL OF CHLORINE DETECTO			02/86C	04/86C	4/11/86					
M60669	LA SALLE 1 - USE OF ASME CODE CASE N-411			02/86C	04/86C	4/01/86					
M60749	LA SALLE 1 - REQUEST TO EXEMPT GRUNDY CO			01/86C	03/86C	3/26/86					
M60859	LA SALLE 1 - CABLE SEPARATION CONCERNS			02/86C	05/86C	5/15/86					
M60916	LA SALLE 1 - REMOVE TWO REPORTING REQUIR			03/86C	06/86C	6/18/86					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON			IL	3	04/82C	04/22
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M60990	LA SALLE 1 - REVIEW THE IHSS AND UT EXAM			03/86C	04/86C	4/30/86					
M60991	LA SALLE 1 - FIRE PROTECTION INSTRUMENTA			03/86C	07/86C	7/16/86					
M61011	LA SALLE 1 - OVERCURRENT PROTECTIVE DEVI			03/86C	05/86C	5/09/86					
M61268	LASALLE 1 - SNUBBER REDUCTION PROGRAM TO			04/86C	07/86C	7/18/86					
M61324	LA SALLE 1 - TO RESOLVE FIRE DOORS TESTI			04/86C	09/86C	9/16/86		H		H	
M61325	LA SALLE 1 - REVISION OF APPENDIX "B" FO			05/86C	09/86C	9/15/86		L		L	
M61543	LASALLE 1 - NUREG 0737, I.A.1.1 - SHIFT			04/86C	10/86C	10/01/86		L		L	
M61655	LA SALLE 1 - ADDITIONS TO THE RELOAD LIC			06/86C	07/86C	7/25/86					
M61733	LA SALLE 1 - SALP REPORT			06/86C	10/86C	10/24/86		H		H	
M61772	LASALLE 1 - MECHANICAL STRESS IMPROVEMEN			05/86C	03/87C	3/16/87		L		L	
M61888	LA SALLE 1 - REPORTING REQUIREMENTS FOR			06/86C	10/86C	10/23/86		L		L	
M61906	LA SALLE 1 - REVIEW OF BULK-TO-LOCAL POO			08/86C	11/86C			L		L	became cond?
M62093	LA SALLE 1 - REVIEW OF LICENSE REVISION			03/86C	10/86C	10/21/86					
M62095	LA SALLE 1 - REVIEW OF LICENSE REVISIION			03/86C	10/86C	10/16/86					
M62246	LA SALLE 1 - STATIC-O-RING SWITCH-ANALYS			08/86C	04/87C	4/01/87					
M62970	LA SALLE 1 - SER FIRE PROTECTION ERRATA			09/86C	09/87						
M63064	LA SALLE 1 - TOPICAL REPORT ON OPERABILI			10/86C	12/87					H	
M63090	LA SALLE 1 - REVISE TECH. SPEC. ON A ONE			10/86C	02/87C	2/11/87				H	
M63124	LA SALLE 1 - SURVEILLANCE OF CONTROL BLA			10/86C	12/86C	12/04/86				M	L.C \$GL

R-1216320-SPC

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

08/03/87

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATF	REGION	OL ISSUE	OL EXPIRATION
LASALLE 1	05000373	BWR	GE	3323 MWT	COMMONWEALTH EDISON				IL	3	04/82C	04/22
APPLICABLE ISSUES				IMPO INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M63164	LA SALLE 1 - REACTOR WATER LEVEL INSTRUM II.F.2			06/86C	03/87C					M		
M63315	LA SALLE 1 - MSIV GROUP I ISOLATION SIGN			10/86C	05/87C	5/06/87				M		
M63777	LA SALLE 1 - REVIEW OF INSERVICE TESTING			09/86C	10/87					M		
M6414	LA SALLE 1 - ALLOW OPERATION WITH 1 CRD			12/86C	02/87C	2/05/87				H		
M64461	LA SALLE 1 - ALLOW 1 UNIT OPERATION WITH			01/87C	07/87					M	"O" D/G spec	
M64611	LA SALLE 1 - ISI RELIEF REQUEST RI-20 AN			01/87C	12/87					M		
M64849	LA SALLE 1 - REMOVAL OF AMMONIA DETECTOR			03/87C	08/87					M		
M65659	LASALLE UNIT 1 - REVISE SNUBBEN INTERVAL			06/87C	10/87							
MPA-A-18	A-18 TECH SPECS AFFECTED BY 50.72 AND 50.73 (			09/84C	05/85C	05/85C		H		L	N	
MPA-A-20 ✓✓	A 20 10 CFR 50.62 OPERATING REACTOR REVIEWS			06/84C	10/87	00/87	9/87	CMA	H	L	59107	
MPA-B-72	B-72 NUREG 0737 TECH SPECS (GENERIC LETTER 82			05/83C	02/84C	02/84C				L	N	
MPA-F-71	F-71 I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO			04/83C	12/87	00/89		CMA		L		
NMSS-2 ✓	ACCESS AUTHORIZATION			02/87	12/87	04/88	/89	H				
NMSS-3 ✓	MISC AMEND CONCERN PHYSICAL PROTECTION O			07/86	10/86	/87	/87	H				
NMSS-4 ✓	SEARCHES OF INDIVIDUALS AT POWER REACTOR			07/86	10/86	/87	/87	H				
NMSS-5 ✓	REPORTING REQUIREMENTS FOR SAFEGUARDS EV			/86	/86	/87	/87	H				
NMSS-7 ✓	REQUIREMENTS FOR CRIMINAL HISTORY CHECKS			/87	/87	/88	/88	H				
NRR-3	SEVERE ACCIDENT POLICY IMPLEMENTATION ON			09/87	/89		/89	H				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON			IL	3	12/83C	12/23
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A				
67.3 3	A-17 IMPROVED ACCIDENT MONITORING			12/84C	12/87	00/88			H	L	
75 (B-77)	B-77 ITEM 2.1 - EQUIPMENT CLASSIFICATION & VE			05/85C	^{4/88} 10/87	00/86	GL 83-28			L	N
75 (B-78)	B-78 ITEMS 3 1.1 & 3.1.2 -POST MAINTENANCE TE			03/85C	05/85C	02/84C					N
75 (B-79)	B-79 ITEM 3.1.3 - POST MAINTENANCE TESTING -			05/85C	08/85C	02/84C					N
75 (B-85)	B-85 SALEM ATWS 1.2 DATA CAPABILITY			11/84C	05/85C	12/83C				L	N
75 (B-86)	B-86 SALEM ATWS 2.2 S-R COMPONENTS			11/84C	^{4/88} 11/87	00/87	GL 83-28			L	N
75 (B-87)	B-87 SALEM ATWS 3.2.1 & 3.2.2 S-R COMPONENTS			11/84C	05/85C	05/85C				L	N
75 (B-88)	B-88 SALEM ATWS 3.2.3 T.S. S-R COMPONENTS			11/84C	08/85C	08/85C				L	N
75 (B-92)	B-92 SALEM ATWS 4.5.1 DIVERSE TRIP FEATURES			11/84C	05/85C	05/85C				L	N
75 (B-93)	B-93 SALEM ATWS 4.5.2 & 4.5.3 TEST ALTERNATIV			11/84C	^{4/88} 12/87	00/87	GL 83-28			L	N
A-24	B-60 QUALIFICATION OF CLASS IE SAFETY-RELATED			08/80C	11/85C	01/84C			H	H	
B-56	D-19 DIESEL GENERATOR RELIABILITY			09/84C	12/83C	12/83C		H		L	N
HF 1.1	SHIFT STAFFING			10/83	01/84C	10/85C		H			
I.A.1.1.1	SHIFT TECHNICAL ADVISOR - ON DUTY			C	C	C	02/82C				
I.A.1.1.4	SHIFT TECHNICAL ADVISOR - DESCRIBE LONG			C	C	C	02/82C				
I.A.1.2	SHIFT SUPERVISOR RESPONSIBILITIES			C	C	C	11/81C				
I.A.1.3.1	F-02 SHIFT MANNING - LIMIT OVERTIME			C	C	C	10/81C				
I.A.1.3.2	F-02 SHIFT MANNING - MIN SHIFT CREW			C	C	C	10/81C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON				IL	3	12/83C	12/23
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
I.A.1.4	LONG-TERM UPGRADE OF OPERATIONS PERSONNE				04/83	04/83		M				
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING			N/A				N/A				
I.A.2.1.4	F-03	IMMEDIATE UPGRADING OF RO & SRO TRAINING		C	C	C	03/86C					
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M				
I.A.3.1.3.A	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C			N/A					
I.A.3.1.3.B	REVISE SCOPE & CRIT. FOR LIC. EXAMS - SI			C			N/A					
I.B.1.2	EVALUATION OF ORGANIZATION & MANAGEMENT			C	C	C	10/81C					
I.C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW			C	C	C	10/81C					
I.C.1.2.B	F-05	SHORT-TERM ACCID. & PROCEDURES REV. - IN		C	C	C	10/81C					
I.C.1.3.B	F-05	SHORT-TERM ACCID. & PROCEDURES REV. - TR		C	C	C	10/81C					
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES			C	C	C	03/86C					
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY			C	C	C	11/81C					
I.C.4	CONTROL-ROOM ACCESS			C	C	C	04/81C					
I.C.5	F-06	FEEDBACK OF OPERATING EXPERIENCE		C	C	C	04/81C					
I.C.6	F-07	VERIFY CORRECT PERFORMANCE OF OPERATING		C	C	C	10/81C					
I.C.8	PILOT MON OF SELECTED EMERGENCY PROC FOR			C	C	C	07/82C					
I.D.2.1	F-09	PLANT-SAFETY PARAMETER DISPLAY CONSOLE -		N/A	N/A	N/A	N/A					
I.D.2.2	F-09	PLANT-SAFETY PARAMETER DISPLAY CONSOLE -		C	C	C	06/83C					
I.D.2.3	F-09	PLANT-SAFETY PARAMETER DISPLAY CONSOLE -		C	C	C	06/83C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE					STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON					IL	3	12/83C	12/23
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY		
I.G.1.3	TRAINING DURING LOW-POWER TESTING - TRAI			C	C	C	12/83C						
II.B.1.2	F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V			C	C	C	03/86C						
II.B.1.3	F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE			C	C	C	03/86C						
II.B.2.2	PLANT SHIELDING - CORRECTIVE ACTIONS TO			C			N/A						
II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L			C	C	C	04/86C						
II.B.3.2	POSTACCIDENT SAMPLING - CORRECTIVE ACTIO			C			N/A						
II.B.3.3	POSTACCIDENT SAMPLING - PROCEDURES			C	C	C	01/82C						
II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI			C			01/82C						
II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO			C	C	C	11/81C						
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	12/83C	N/A						
II.D.1.2.A	RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	12/83C	N/A						
II.D.1.2.B	F-14 RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	12/83C				L			
II.D.1.3	RELIEF & SAFETY VALVE TEST REQUIREMENTS			03/84C	05/85C	12/83C	N/A						
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE			C	C	C	00/84C						
II.E.4.1.2	DEDICATED HYDROGEN PENETRATIONS - REVIEW			C			03/86C						
II.E.4.1.3	F-18 DEDICATED HYDROGEN PENETRATION - INSTALL			C			03/86C						
II.E.4.2.1-4	CONTAIMENT ISOLATION DEPENDABILITY - IMP			C			02/84C						
II.E.4.2.5.A	CONTAINMENT ISOLAT. DEPENDABILITY - CNM			C			N/A						
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN			C			02/84C						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON	IL	3	12/83C	12/23			
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL COMP	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.E.4.2.6	F-19 CONTAINMENT ISOLATION DEPENDABILITY - CN				C							
II.E.4.2.7	F-19 CONTAINMENT ISOLATION DEPENDABILITY - RA				C			02/84C				
II.F.1.1	F-20 ACCIDENT-MONITORING - PROCEDURES				C	C	C	01/82C				
II.F.1.2.A	F-20 ACCIDENT-MONITORING - NOBLE GAS MONITOR				C	C	C	01/82C				
II.F.1.2.B	F-21 ACCIDENT-MONITORING - IODINE/PARTICULATE				C	C	C	01/82C				
II.F.1.2.C	F-22 ACCIDENT-MONITORING - CONTAINMENT HIGH-R				C	C	C	01/82C				
II.F.1.2.D	F-23 ACCIDENT-MONITORING - CONTAINMENT PRESSU				C	C	C	01/82C				
II.F.1.2.E	F-24 ACCIDENT-MONITORING - CONTAINMENT WATER				C	C	C	01/82C				
II.F.1.2.F	F-25 ACCIDENT-MONITORING - CONTAINMENT HYDROG				C	C	C	01/82C				
II.F.2.4	F-26 INSTRUMENTATION FOR DETECT OF INADEQUAT				C							
III.A.1.2.1	UPGRADE EMERGENCY SUPPORT FACILITIES - I				C	C	C	06/83C				
					C	C	C	06/83C				
III.D.1.1.1	PRIMARY COOLANT OUTSIDE CONTAINMENT - LEA				C	C	C	01/82C				
III.D.3.3.1	INPLANT RAD. MONIT. - PROVIDE MEANS TO D				C	C	C	06/82C				
III.D.3.3.2	F-69 INPLANT RADIATION MONIT. - MODIFICATIONS				C	C	C	06/82C				
II.K.1.10	IE BULLETINS - OPERABILITY STATUS				C			03/82C				
II.K.1.22	IE BULLETINS - AUX. HEAT REM SYSTM, PROC				C	C	C	00/83C				
II.K.1.23	IE BULLETINS - RV LEVEL, PROCEDURES				C	C	C	04/86C				
II.K.1.5	IE BULLETINS - REVIEW ESF VALVES				C			06/82C				
II.K.3.13.B	F-43 FINAL RECOMMENDATIONS, B&O TASK FORCE - H				C			10/83C				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON				IL	3	12/83C	12/23
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.K.3.15	F-45 FINAL RECOMMENDATIONS,B&O TASK FORCE - I				C			10/83C				
II.K.3.16.B	F-46 FINAL RECOM. ,B&O TASK FORCE - CHALLENGE				C							
II.K.3.18.C	F-48 FINAL RECOMMENDATIONS,B&O TASK FORCE - A				C							
II.K.3.21.B	F-50 FINAL RECOMMENDATIONS,B&O TASK FORCE - R				C							
II.K.3.22.A	F-51 FINAL RECOMMENDATIONS,B&O TASK FORCE - R				C			12/84C				
II.K.3.22.B	F-51 FINAL RECOMMENDATIONS,B&O TASK FORCE - R				C			12/84C				
II.K.3.24	F-52 FINAL RECOMMENDATIONS,B&O TASK FORCE - S				C			04/86C				
II.K.3.25.A	FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C			07/86C				
II.K.3.25.B	F-53 FINAL RECOMMENDATIONS,B&O TASK FORCE - P				C			07/86C				
II.K.3.27	F-54 FINAL RECOMMENDATIONS,B&O TASK FORCE - C				C	C	C	01/81C				
II.K.3.28	F-55 FINAL RECOMMENDATIONS,B&O TASK FORCE - Q				C							
M53467	LASALLE UNIT 2 2.206 REQUEST FROM GOGOL				01/83C	03/84C	3/16/84		H			
M54178	LA SALLE UNIT 2 - RESPOND TO APPEAL LETT				02/84C	03/84C			H			Fire Protect
M54184	LA-SALLE 2 - TECH SPEC AUDIT				02/84C	03/84C			M			Grand Gully
M54248	LA SALLE 2 - REVIEW OF FIRE PROTECTION S				02/84C	03/84C			H			
M54309	LASALLE 2 - CONTROL RAD. CONT. MATERIALS				03/84C	04/84C			L			Sludge?
M54996	LASALLE 1 & 2 IST				05/84C	12/87			L			?
M55055	LASALLE 2 - LICENSE CONDITION				05/84C	07/84C	7/24/84		L			
M55062	LA SALLE UNIT2 - EXIGENT TECH SPEC CHANG				05/84C	07/84C	7/03/84		H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON			IL	3	12/83C	12/23
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M55339	LA SALLE 2 - PROCEDURES GENERATION PACKA			07/84C	10/85C	10/18/85					
M55563	LA SALLE UNIT 2 - CHANGE ACTION STATEMEN			08/84C	11/84C	11/09/84	M			M	
M55565	LA SALLE UNIT 2 - USE OF ASME CODE CASE			08/84C	08/84C	8/28/84	L			L	
M55650	LA SALLE UNIT 2 - REVIEW FIRE DAMPER SUR			09/84C	05/85C	5/03/85	M	SSER 48		M	2. C. (15)h
M55774	LA SALLE 2 - REVISE TECH. SPECS FOR REAC			09/84C	01/85C	1/08/85	M			M	
M55775	LA SALLE 2 - NEW TECH. SPEC. CHANGES TO			09/84C	12/84C	12/17/84	M			M	
M55776	LA SALLE 2 - INDICATION OF BYPASS REACTO			09/84C	09/84C	9/26/84	M			M	
M56088	LA SALLE 2 - CONFIRMATORY REVIEW OF ELEC			08/84C	05/87		L		EQ	L	
M56627	LA SALLE UNIT 2 - EXTENSION OF DEADLINE			01/85C	03/85C	3/28/85					
M56735	LA SALLE UNIT 2 - TS CHANGE FOR SBGTS HE			01/85C	04/85C	4/29/85					
M56909	LA SALLE 2 - CHANNEL CHECK REQUIREMENTS			02/85C	04/85C	4/30/85					
M57476	LA SALLE 2 - ADDITION OF SUPPRESSION POO			04/85C	08/86C	8/29/86	L				
M57539	LA SALLE 2 - REVIEW OF REVISED LICENSED			08/83C	01/86C						
M57549	LA SALLE 2 - SPECIFICATION 3.0.4 DOES NO			04/85C	10/85C	10/02/85					
M57551	LA SALLE 2 - DECAY CORRECTION OF LIQUID			04/85C	10/85C	10/02/85					
M57553	LA SALLE 2 - CONTROL ROOM EMERGENCY MAKE			04/85C	10/85C	10/02/85					
M57561	LA SALLE 2 - RCJC PUMP ROOM DIFFERENTIAL			04/85C	10/85C	10/02/85					
M57563	LA SALLE 2 - RPIS INDICATION			04/85C	10/85C	10/02/85					
M57565	LA SALLE 2 - CORRECTION OF TYPOGRAPHICAL			04/85C	09/85C	9/27/85					

Regual Topical Report

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON	IL	3	12/83C	12/23			
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M57594	LA SALLE 2 - PROPOSED ELIMINATION OF PIP				04/85C	09/85C	9/27/85					
M57767	LA SALLE 2 -DISPOSAL OF LOW LEVEL RADIOA				05/85C	01/87C				L	SLUOGL	L
M57783	LA SALLE 2 - ACCEPTANCE CRITERIA FOR FIR				05/85C	07/85C	7/16/85					
M57939	LA SALLE 2 - EMERGENCY TECH. SPEC. TO CH				06/85C	07/85C	7/01/85					
M59463	LA SALLE 2 - REVISION TO SRV SETPOINTS A				08/85C	10/85C	10/31/85					
M59534	LA SALLE 2 - REVISE TECH. SPEC. ON A ONE				08/85C	11/85C	11/13/85					
M59626	LA SALLE 2 - APRM CALIBRATION GAIN ADJUS				08/85C	11/85C	11/20/85					
M59629	LASALLE 2 - CONTROL ROD DRIVE SCRAM ALAR				08/85C	05/86C	5/06/86					
M59704	LA SALLE 2 - EXTENSION OF SURVEILLANCE I				09/85C	10/85C	10/01/85					
M59767	LA SALLE 2 - COMSIP, INC. HYDROGEN OXYGE				09/85C	11/85C						
M59922	LA SALLE 2 - SOURCE RANGE MONITOR OPERAB				10/85C	01/86C	01/17/86					
M60125	LA SALLE 2 - LOW AND DEGRADED GRID VOLTA				11/85C	05/86C	5/09/86					
M60259	LA SALLE 2 - ADMINISTRATIVE CONTROL OF H				12/85C	03/86C	3/12/86)					
M60261	LA SALLE 2 - REMOVAL OF UNQUALIFIED INST				12/85C	03/86C	3/19/86				LC	
M60408	LA SALLE 2 - MANAGEMENT ORGANIZATIONAL C				12/85C	11/86C	11/21/86			L		L
M60645	LA SALLE 2 - REMOVAL OF CHLORINE DETECTO				02/86C	04/86C	4/11/86					
M60670	LA SALLE 2 - USE OF ASME CODE CASE N-411				02/86C	04/86C	4/01/86					
M60750	LA SALLE 2 - REQUEST TO EXEMPT GRUNDY CO				01/86C	03/86C	3/26/86					
M60860	LA SALLE 2 - FINE MOTION CONTROL DRIVE D				02/86C	08/86C	8/15/86			H		H

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION		
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON	IL	3	12/83C	12/23		
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M60861	LA SALLE 2 - CABLE SEPARATION CONCERNS			02/86C	05/86C	5/15/86					
M60917	LA SALLE 2 - REMOVE TWO REPORTING REQUIR			03/86C	06/86C	6/12/86					
M60992	LA SALLE 2 - FIRE PROTECTION INSTRUMENTA			03/86C	07/86C	7/16/86					
M61012	LA SALLE 2 - OVERCURRENT PROTECTIVE DEVI			03/86C	05/86C	5/09/86					
M61269	LASALLE 2 - SNUBBER REDUCTION PROGRAM TO			04/86C	07/86C	7/18/86					
M61326	LA SALLE 2 - REVISION OF APPENDIX "B" FO			05/86C	09/86C	9/15/86		L		L	
M61431	LA SALLE 2 - EXIGENT CHANGE TON THE TIP			05/86C	06/87			L		L	
M61544	LASALLE 2 - NUREG 0737, I.A.1.1 - SHIFT			04/86C	10/86C	10/01/86		L		L	
M61650	LA SALLE 2 - "STATIC-O-RING" SWITCHES ER			07/86C	08/86C	8/07/86		H		H	
M61734	LA SALLE 2 - SALP REPORT			06/86C	03/87C	3/13/87		H		H	
M61744	LA SALLE 2 - REPLACEMENT OF VENT. AND PU			06/86C	08/86C	8/29/86		L		L	
M61773	LASALLE 2 - MECHANICAL STRESS IMPROVEMEN			05/86C	03/87C	3/16/87		L	MSIA	L	
M61887	LA SALLE 2 - MODIFICATION OF ADS LOGIC T			07/86C	08/86C	8/29/86			LC 2 C (18) (d)		
M61889	LA SALLE 2 - REPORTING REQUIREMENTS FOR			06/86C	10/86C	10/23/86		L		L	
M61890	LA SALLE 2 - CABLE SEPARATION CONCERNS			06/86C	12/86C	12/02/86		L		L	
M62094	LA SALLE 2 - REVIEW OF LICENSE REVISION			03/86C	10/86C	10/16/86			PCP		
M62096	LA SALLE 2 - REVIEW OF LICENSE REVISION			03/86C	10/86C	10/21/86			ODCA		
M62832	LA SALLE 2 - HIGH DENSITY SPENT FUEL RAC			09/86C	10/87- 2/88				ODSN		
M63036	LA SALLE 2 - STAINLESS STEEL PIPING INSP			09/86C	12/86C	12/16/86				H	

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON			IL	3	12/83C	12/23
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M63065	LA SALLE 2 - TOPICAL REPORT ON OPERABILI			10/86C	12/87			OPEN		H	
M63125	LA SALLE 2 - FINE MOTION CONTROL ROD DRI			10/86C	02/87C		2/09/87			H	
M63165	LA SALLE 2 - REACTOR WATER LEVEL INSTRUM			06/86C	03/87C				II, F.2.	M	
M63316	LA SALLE 2 - MSIV GROUP I ISOLATION SIGN			10/86C	05/87C		5/06/87			M	
M64112	LA SALLE 2 - CYCLE 2 RELOAD LICENSING PA			12/86C	04/87C		4/10/87			M	
M64462	LA SALLE 2 - ALLOW 1 UNIT OPERATION WITH			01/87C	07/87				"O" D/G	M	
M64612	LA SALLE 2 - ISI RELIEF REQUEST RI-20 AN			01/87C	12/87					M	
M64613	LA SALLE 2 - PIPING INSPECTION PLAN			01/87C	03/87C		4/06/87			M	
M64765	LA SALLE 2 - LOW AND DEGRADED GRID VOLTA			02/87C	04/87C		4/14/87			H	
M64850	LA SALLE 2 - REMOVAL OF AMMONIA DETECTOR			03/87C	08/87					M	
M65661	LASALLE UNIT 2 - UNIT 2 FUEL IN UNIT 1 P			06/87C	1/88						
MPA-A-18	A-18 TECH SPECS AFFECTED BY 50.72 AND 50.73 (			09/84C	05/85C	01/84C		H			N
MPA-A-20	A-20 10 CFR 50.62 OPERATING REACTOR REVIEWS			06/84C	4/88 10/87	00/88			H	L	
MPA-F-08	F-08 I.D.1.1 DETAILED CONTROL ROOM DESIGN REV			04/85C	03/87	00/89					
MPA-F-71	F-71 I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO			04/85C	12/87	00/89				L	
NMSS-2	ACCESS AUTHORIZATION			02/87	12/87	04/88	/89	H			
NMSS-3	MISC AMEND CONCERN PHYSICAL PROTECTION O			07/86	10/86	/87	/87	H			
NMSS-4	SEARCHES OF INDIVIDUALS AT POWER REACTOR			07/86	10/86	/87	/87	H			
NMSS-5	REPORTING REQUIREMENTS FOR SAFEGUARDS EV			/86	/86	/87	/87	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
LASALLE 2	05000374	BWR	GE	3323 MWT	COMMONWEALTH EDISON	IL	3	12/83C	12/23			
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
NMSS-7	REQUIREMENTS FOR CRIMINAL HISTORY CHECKS				/87	/87	/88	/88	H			
NRR-3	SEVERE ACCIDENT POLICY IMPLEMENTATION ON 09/87					/89		/89	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	0/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL COMP	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M65487	ZION 1 - LOW TEMPERATURE OVERPRESSURE PR			05/87C		04/87C				H		
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A					
67.3.3	A-17 IMPROVED ACCIDENT MONITORING			04/83C	12/87	00/87	89		H			
67.4.1	G-01 RCP TRIP			02/83C	12/87	00/85C						
75 (B-76)	B-76 ITEM 1.1 - POST TRIP REVIEW; PROGRAM DES			11/83C	07/85C	00/87					N	
75 (B-77)	B-77 ITEM 2.1 - EQUIPMENT CLASSIFICATION & VE			11/83C	09/87	00/87					N	
75 (B-78)	B-78 ITEMS 3.1.1 & 3.1.2 -POST MAINTENANCE TE			11/83C	07/85C	00/87					N	
75 (B-79)	B-79 ITEM 3 1.3 - POST MAINTENANCE TESTING -			11/83C	12/87	00/89					N	
75 (B-80)	B-80 ITEM 4 1 - REACTOR TRIP SYSTEM RELIABILI			11/83C		00/89			H			
75 (B-81)	B-81 ITEMS 4.2.1 & 4.2.2 -PREVENTATIVE MAINT			11/83C	06/85C	00/87					N	
75 (B-82)	B-82 ITEM 4 3 - AUTOMATIC ACTUATION OF SHUNT			11/83C	01/85C	00/87			M			
75 (B-85)	B-85 SALEM ATWS 1.2 DATA CAPABILITY			11/84C	12/87	00/87					N	
75 (B-86)	B-86 SALEM ATWS 2.2 S-R COMPONENTS			11/84C	09/87	00/89					N	
75 (B-87)	B-87 SALEM ATWS 3.2.1 & 3.2.2 S-R COMPONENTS			11/84C	07/85C	00/87					N	
75 (B-88)	B-88 SALEM ATWS 3.2.3 T.S. S-R COMPONENTS			11/84C	12/87	00/87					N	
75 (B-89)	B-89 SALEM ATWS 4.2.3 & 4.2.4 LIFE COMPONENTS			11/84C	12/87	00/89					N	
75 (B-90)	B-90 SALEM ATWS 4.3 W AND B&W T.S.			07/84C	12/87	10/86					N	
75 (B-92)	B-92 SALEM ATWS 4.5.1 DIVERSE TRIP FEATURES			11/84C	07/85C	00/87					N	
75 (B-93)	B-93 SALEM ATWS 4.5.2 & 4.5.3 TEST ALTERNATIV			11/84C	12/87	00/90					N	

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
A-2	D-10 ASYMMETRIC BLOWDOWN LOADS ON REACTOR PRI			03/79C	02/84C	02/84C				M	N	
A-24	B-60 QUALIFICATION OF CLASS IE SAFETY-RELATED			08/80C	11/84C	00/85C			H	H		
A-26	B-04 REACTOR VESSEL PRESSURE TRANSIENT PROTEC			08/76C	04/80C	00/80C			H	M		
A-36 (C-10)	C-10 CONTROL OF HEAVY LOADS OVER SPENT FUEL P			08/77C	03/84C	09/85C			M	M		
36 (C-15)	C-15 CONTROL OF HEAVY LOADS - PHASE II (FOLLO			05/83C	06/85C	09/85C						
B-56	D-19 DIESEL GENERATOR RELIABILITY			09/84C	02/86C	00/87		H			N	
B-59 (E-05)	E-05 W N-1 LOOP OPERATION			12/76C	11/84C	00/80C N/A				L	N	
HF 1.1	SHIFT STAFFING			10/83C	01/84C	10/85C		H				
I.A.1.1.1	SHIFT TECHNICAL ADVISOR - ON DUTY			C	11/80C	11/80C	05/81C					
I.A.1.1.3	F-0. SHIFT TECHNICAL ADVISOR - TRAINED PER LL			10/80C	01/82C	09/86						
I.A.1.1.4	SHIFT TECHNICAL ADVISOR - DESCRIBE LONG			C	/81C	/81C						
I.A.1.2	SHIFT SUPERVISOR RESPONSIBILITIES			C	11/80C	11/80C	05/81C					
I.A.1.3.1	F-02 SHIFT MANNING - LIMIT OVERTIME			04/81C	06/83C	00/83C						
I.A.1.3.2	F-02 SHIFT MANNING - MIN SHIFT CREW			04/81C	06/83C	00/83C						
I.A.1.4	LONG-TERM UPGRADE OF OPERATIONS PERSONNE				04/83	04/83		M				
I.A.2.1.1	IMMEDIATE UPGRADING OF RO & SRO TRAINING			C	11/80C	11/80C						
I.A.2.1.2	IMMEDIATE UPGRADING OF RO & SRO TRAINING				11/80C	11/80C						
I.A.2.1.3	IMMEDIATE UPGRADING OF RO & SRO TRAINING				11/80C	11/80C						
I.A.2.1.4	F-03 IMMEDIATE UPGRADING OF RO & SRO TRAINING			04/81C	03/82C	00/82C						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
I.A.2.1.5	IMMEDIATE UPGRADING OF RO & SRO TRAINING				11/80C	11/80C						
I.A.2.3	ADMINISTRATION OF TRAINING PROGRAMS				11/80C	11/80C						
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M				
I.A.3.1.1	REVISE SCOPE & CRITERIA FOR LICENSING EX				11/80C	11/80C						
I.A.3.1.2	REVISE SCOPE & CRITERIA FOR LICENSING EX				11/80C	11/80C						
I.C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW			C	11/80C	11/80C	04/80C					
I.C.1.2.A	F-04 SHORT-TERM ACCID. & PROCEDURES REV. - IN			04/81C	02/85C	12/85C				H		
I.C.1.2.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - IN			04/81C	01/88	00/87				H		
I.C.1.3.A	F-04 SHORT-TERM ACCID. & PROCEDURES REV - TRA			04/81C	02/85C	12/85C				H		
I.C.1.3.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - TR			04/81C	01/88	00/87				H		
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES			C	11/80C	11/80C	05/81C					
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY			C	11/80C	11/80C	05/81C					
I.C.4	CONTROL-ROOM ACCESS			C	11/80C	11/80C	05/81C					
I.C.5	F-06 FEEDBACK OF OPERATING EXPERIENCE			11/81C	01/82C	00/82C						
I.C.6	F-07 VERIFY CORRECT PERFORMANCE OF OPERATING			11/81C	01/82C	00/82C						
I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	06/84C	00/82C						
I.D.2.2	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	06/84C	00/82C						
I.D.2.3	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	06/84C	00/82C						
II.B.1.1	REACTOR-COOLANT SYSTEM VENTS - DESIGN VE			C	11/80C	11/80C	N/A					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	10/73C	12/08
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.B.1.2	F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V				04/81C	09/83C	00/83C				H	
II.B.1.3	F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE				04/81C	09/83C	00/83C				H	
II.B.2.1	PLANT SHIELDING - REVIEW DESIGNS				C	11/80C	11/80C	N/A				
II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L				02/82C	04/83C	00/83C				H	
II.B.3.1	POSTACCIDENT SAMPLING - INTERIM SYSTEM				C	11/80C	11/80C	05/81C				
II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI				04/81C	06/84C	09/85C				H	
II.B.4.1	F-13 TRAINING FOR MITIGATING CORE DAMAGE - DE				04/81C	05/82C	00/82C				H	
II.B.4.2.A	F-13 TRAINING FOR MITIGATING CORE DAMAGE - IN				04/81C	05/82C	00/82C				H	
II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO				04/81C	05/82C	00/82C				H	
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	11/80C	11/80C	N/A				
II.D.1.2.A	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	12/83C	12/83C	N/A				
II.D.1.2.B	F-14 RELIEF & SAFETY VALVE TEST REQUIREMENTS				04/81C	12/87	01/86C				H	
II.D.1.3	RELIEF & SAFETY VALVE TEST REQUIREMENTS				C	12/83C	12/83C	N/A				
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE				C	11/80C	11/80C	05/81C				
II.E.1.1.1	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATION -				06/81C	01/83C	00/84C				H	
II.E.1.1.2	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATION -				06/81C	01/83C	00/84C				H	
II.E.1.1.3	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATIONS -				06/81C	01/83C	00/84C				H	
II.E.1.2.1.A	AUXILIARY FEEDWATER SYSTEM INITIATION &				C	11/80C	11/80C					
II.E.1.2.1.B	F-16 AUXILIARY FEEDWATER SYSTEM INITIATION &				04/81C	04/81C	00/82C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
II.E.1.2.2.A	AUXILIARY FEEDWATER SYSTEM INITIATION &			C	11/80C	11/80C						
II.E.1.2.2.B	AUXILIARY FEEDWATER SYSTEM INITIATION &			C	N/A	N/A	N/A					
II.E.1.2.2.C	F-17	AUXILIARY FEEDWATER SYSTEM INITIATION &		04/81C	04/81C	00/82C						
II.E.3.1.1	EMERGENCY POWER FOR PRESSURIZER HEATERS			C	11/80C	11/80C	05/81C					
II.E.4.1.1	DEDICATED HYDROGEN PENETRATIONS - DESIGN			C	11/80C	11/80C	05/81C					
II.E.4.1.3	F-18	DEDICATED HYDROGEN PENETRATION - INSTALL		04/81C	09/81C	02/85C						
II.E.4.2.1-4	CONTAINMENT ISOLATION DEPENDABILITY - IMP			C	11/80C	11/80C	05/81C					
II.E.4.2.5.A	CONTAINMENT ISOLAT. DEPENDABILITY - CNM			C	09/82C	00/82C	N/A					
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN			C	09/82C	00/82C						
II.E.4.2.6	F-19	CONTAINMENT ISOLATION DEPENDABILITY - CN		04/81C	09/82C	00/82C				H		
II.E.4.2.7	F-19	CONTAINMENT ISOLATION DEPENDABILITY - RA		04/81C	09/82C	00/82C				H		
II.F.1.2.A	F-20	ACCIDENT-MONITORING - NOBLE GAS MONITOR		04/81C	09/81C	00/87	C ab					
II.F.1.2.B	F-21	ACCIDENT-MONITORING - IODINE/PARTICULATE		04/81C	09/81C	00/87	C ab					
II.F.1.2.C	F-22	ACCIDENT-MONITORING - CONTAINMENT HIGH-R		04/81C	01/82C	00/85C	L					
II.F.1.2.D	F-23	ACCIDENT-MONITORING - CONTAINMENT PRESSU		01/82C	09/83C	00/87	C ab			H		
II.F.1.2.E	F-24	ACCIDENT-MONITORING - CONTAINMENT WATER		01/82C	09/83C	00/85C				H		
II.F.1.2.F	F-25	ACCIDENT-MONITORING - CONTAINMENT HYDROG		01/82C	09/83C	00/85C				H		
II.F.2.1	INSTRUMENTATION FOR DETECT. OF INADEQUAT				11/80C	11/80C						
II.F.2.2	INSTRUMENTATION FOR DETECT. OF INADEQUAT			C	N/A	N/A	05/81C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.F.2.4	F-26	INSTRUMENTATION FOR DETECT. OF INADEQUAT		04/81C	08/86C	00/88				H	
II.G.1.1		POWER SUPP. FOR PRESSURIZER RELIEF BLOCK		C	11/80C	11/80C	05/81C				
III.A.1.1		EMERGENCY PREPAREDNESS, SHORT TERM			11/80C	11/80C					
III.A.1.2.1		UPGRADE EMERGENCY SUPPORT FACILITIES - I		C	11/80C	11/80C	09/81C				
III.A.2.1	F-67	UPGRADE PREPAREDNESS - UPGRADE EMERGENCY		04/81C	05/83C	00/83C				H	
III.A.2.2	F-68	UPGRADE PREPAREDNESS - METEOROLOGICAL D		04/81C	12/87	00/87				H	
III.C.1.1.1		PRIMARY COOLANT OUTSIDE CONTAINMENT - LEA		C	11/80C	11/80C	05/81C				
III.D.3.3.1		INPLANT RAD. MONIT - PROVIDE MEANS TO D		C	11/80C	11/80C	05/81C				
III.D.3.3.2	F-69	INPLANT RADIATION MONIT. - MODIFICATIONS		04/81C	02/82C	00/82C				H	
III.D.3.4.1	F-70	CONTROL ROOM HABITABILITY - REVIEW		06/81C	06/82C	00/87C				H	
III.D.3.4.2	F-70	CONTROL ROOM HABITABILITY - SCHEDULE MOD		06/81C	06/82C	00/87C				H	
II.K.1.3		IE BULLETINS - 79-06, 79-06A, 79-06A REV		C		C	06/79C				
II.K.2.13	F-30	ORDERS ON B&W PLANTS - THERMAL MECHANICA		12/81C	10/83C	00/84C				H	
II.K.2.17	F-33	ORDERS ON B&W PLANTS - VOIDING IN RCS (C		01/82C	01/84C	00/84C				H	
II.K.2.19		BENCHMARK ANALYSIS OF SEQUENTIAL AFW FLO				C	C				
II.K.3.1.A	F-36	FINAL RECOMMENDATIONS, B&O TASK FORCE - A		04/81C	09/83C	00/83C				H	
II.K.3.1.B		FINAL RECOMMENDATIONS, B&O TASK FORCE - A		C							
II.K.3.10	F-41	FINAL RECOMMENDATIONS, B&O TASK FORCE - P		04/81C	09/81C	08/82C					
II.K.3.12.A		FINAL RECOM. B&O TASK FORCE - ANTICIP. T			/81C	/81C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	050J0295	PWR	WEST.	3250 MWT	COMMONWEALTH EDISON				IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
II.K.3.12.B	F-42	FINAL RECOM.	B&O TASK FORCE - ANTICIPATO	04/81C	09/81C	00/81C						
II.K.3.17	F-47	FINAL RECOMMENDATIONS	B&O TASK FORCE - E	04/81C	08/83C	00/83C				H		
II.K.3.2	F-37	FINAL RECOMMENDATIONS	B&O TASK FORCE - R	04/81C	09/83C	00/83C				H		
II.K.3.25.A		FINAL RECOMMENDATIONS	B&O TASK FORCE - P			C	C					
II.K.3.25.B	F-53	FINAL RECOMMENDATIONS	B&O TASK FORCE - P	11/80C	05/82C	00/82C						
II.K.3.3	F-38	FINAL RECOMMENDATIONS	B&O TASK FORCE - R	04/81C	09/82C	00/82C				H		
II.K.3.30.A		FINAL RECOMMENDATIONS	B&O TASK FORCE - S	C	06/85C	06/85C	N/A					
II.K.3.30.B	F-57	FINAL RECOMMENDATIONS	B&O TASK FORCE - S	04/81C	06/85C	06/85C				H		
II.K.3.31	F-58	FINAL RECOMMENDATIONS	B&O TASK FORCE - C	04/82C	02/87C	07/86C				H		
II.K.3.5.A	F-39	FINAL RECOMMENDATIONS	B&O TASK FORCE - A	04/81C	02/83C	09/88C	08			H		
II.K.3.5.B	F-39	FINAL RECOMMENDATIONS	B&O TASK FORCE - A	04/81C	02/83C	09/88C	08			H		
II.K.3.9	F-40	FINAL RECOMMENDATIONS	B&O TASK FORCE - P	04/81C	09/81C	00/81C						
M13021	ZION 1 -	STANDARD TECH SPEC	LCO'S FOR TA	03/80C	8/87C	N/A			H			
M41044	ZION 1 -	RESIDUAL RISKS		07/81C	08/85C	N/A			H			
M42146	ZION 1 -	ATWS INSTRUMENTATION MODIFICATI		02/80C	12/85C	00/89			H			
M42306	ZION 1 -	CONTROL ROOM - HUMAN FACTORS EN		02/80C	11/83C	00/90			H			
M42836	ZION 1 -	FAILURE MODE EFFECTS ANALYSIS (		08/80C	12/85C	C			H			
M48103	ZION 1 -	BORATION FLOW PATHS HEAT TRACIN		07/81C	12/85C	N/A			L			
M48692	ZION 1 -	LICENSE CONDITION FOR TECH SPEC		08/82C	02/85C	N/A						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M49601	ZION 1 - MOD TO 1980 ORDER - AFWS			12/82C	12/85C	C					
M51306	ZION 1 - OPERABILITY OF VENT/PURGE VALVE			02/83C	04/84C	00/88					
M51901	ZION 1 - 6/27/83 ISI REQUEST			06/83C	12/84C	00/C					
M52100	ZION 1 - ISI ANALYSIS PROGRAM, SECOND INT			06/83C	02/86C	C					
M52116	ZION 1 - REVIEW AND APPROVE OR DISAPPROV			07/83C	12/83C	N/A					
M52118	ZION 1 - T.S. CHANGE TO CONT. LEAKAGE TE			08/83C	04/84C	C					
M52185	ZION 1 - T.S. CHANGES RE AUXILIARY ELECT			08/83C	12/85C						
M52288	ZION 1 - T.S. CHANGE FOR OPTIMIZED FUEL			08/83C	12/83C						
M52380	ZION 1 - TS CHANGE RE COOLANT CHEMISTRY			09/83C	04/84C						
M52525	ZION 1 - T.S. CHANGE RE PREVENTIVE MAINT			10/83C	03/84C						
M52620	ZION 1 - ROD SWAP ANALYSIS METHOD			10/83C	12/83C						
M53464	ZION 1 TS CHANGE REPREVENTIVE MAINTENANC			01/84C	03/84C						
M54160	ZION 1 - ITEM B.6 OF 1980 ORDER			01/84C	12/85C	02/86C N/A					
M54162	ZION 1 - REVIEW OF REVISED LICENSED OPER			08/83C	01/86C	N/A					
M54176	ZION 1 - RECONSIDERATION OF FEB. 29, 198			01/84C	06/85C	N/A					
M54203	ZION 1 - SCHEDULAR EXEMPTION FROM 10CFR			11/83C	12/87	00/87					
M54306	ZION 1 - CONTROL RAD. CONT. MATERIALS -			03/84C	04/84C	N/A			M		M
M54365	ZION - 1 ONE TIME EXEMPTION FROM STATE A			01/84C	04/84C	N/A					
M54426	ZION 1- RCS VENTS TECHNICAL SPECIFICATIO			03/84C	02/85C	00/88					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION				
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON	IL	3	10/73C	12/08				
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M54901	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C	N/A						
M54903	ZION 1 - RECONSIDERATION OF FEB. 20, 198				01/84C	10/84C							
M54905	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54907	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54909	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54911	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54913	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54915	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54917	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54919	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54921	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54923	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54925	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54927	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54929	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54931	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54933	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54935	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C							
M54937	ZION 1 - RECONSIDERATION OF FEB. 29, 198				01/84C	10/84C	N/A						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M54939	ZION 1 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C	N/A					
M54941	ZION 1 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54943	ZION 1 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M55267	ZION 1 - LEAK RATE TESTING - 2.206 PETIT			06/84C	01/85C	N/A					
M55417	ZION 1 - TECH. SPECS. FOR PURGE/VENT OPE			07/84C	12/87	00/87					
M55439	ZION 1 - EXEMPTITON FROM 10 CFR 50 APPEN			07/84C	08/84C	00/87					
M55582	ZION 1 - MODS TO MEET 10CFR50 APPENDIX R			07/84C	12/87	C					
M55674	ZION 1 - AFW CHECK VALVES - PRA			08/84C	12/84C	C					
M55926	ZION 1 - ASME CODE CASE N-401			09/84C	11/84C	00/87					
M55940	ZION 1 - CORE DAMAGE ASSESSMENT			08/84C	12/84C	C					
M56622	ZION 1 - REVISION 1 TO FIRST 10-YR ISI P			11/84C	06/85C	C					
M56624	ZION 1 - REVISION 2 TO FIRST 10-YR IST-I			11/84C	12/84C	C					
M56625	ZION 1 - REVISION 3 TO THE FIRST 10-YR I			01/85C	06/85C	C					
M56838	ZION 1 - ROD URGENT FAILURE			02/85C	05/85C	C					
M56854	ZION 1 - CONTAINMENT INTEPRITY			01/85C	08/85C	C					
M56856	ZION 1 - ASSISTANCE ON APPENDIX R INSPEC			01/85C	03/85C	N/A					
M56968	ZION 1 - D.G. TESTING			02/85C	12/85C	N/A C					
✓M57028	ZION 1 - HYDROGEN MONITORS (II.F.1.6)			10/84C	03/85C	C 8/87					
M57047	ZION 1 - ECCS ANALYSIS			10/84C	05/85C	C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M57091	ZION 1 - SPDS EVALUATION			09/84C	12/87	C per D. Beckman 8/87 af					
M57659	ZION 1 - REV. 4 TO FIRST 10-YR ISI-IST P			05/85C	07/85C	C					
M57806	ZION 1 - LETTER FROM WARREN WILSON COLLE			05/85C	08/85C	C					
M59035	ZION 1 - ITEMS A.1 AND A.2 OF 1980 ORDER			06/85C	12/85C	C					
M59297	ZION 1 - TECH. SPEC. CHANGE FUEL ENRICH.			07/85C	02/86C	C					
M59485	ZION 1 - DEGRADED GRID VOLTAGE PROTECTIO			08/85C	03/86C	C					
M59492	ZION 1 - MATERIALS IRRADIATION SPECIMEN			08/85C	01/86C	C					
M60311	ZION 1 - RESCINDING 1980 ORDER			11/85C	00/87						
M60312	ZION 2 - RESCINDING 1980 ORDER			11/85C	12/86C	00/87					
M60794	ZION 1 - NIS FLUX RATE SETPOINTS			02/86C	02/86C	C					
M61366	ZION 1 - STEAM GENERATOR TUBE SLEEVING			04/86C	11/86C	C					
M61545	ZION 1 - NUREG 0737, I.A.1.1 - SHIFT TEC			04/86C	09/86C	C					
M61747	ZION 1 - S. G. TUBE SLEEVING METHODOLOGY			06/86C	11/86C	C					
M61855	ZION 1 - REV. 2 TOE AND IST SECOND INTER			06/86C	12/87	00/88					
M62834	ZION 1 - BATTERY CHARGER			09/86C	12/86C	C					
M62986	ZION 1 - 40-YEAR OPERATING LICENSE			09/86C	00/88						
M63169	ZION 1 - BASE LINE INSERVICE INSP. AND A			10/86C	12/87	C					H
M63171	ZION 1 - NUMBER OF RCP'S IN MODE 3			10/86C	03/87C	C					H
M63173	ZION 1 - TECH. SPEC. CHANGES - G.L.85-19			10/86C	03/87C	C					H

R-1216320-SPC

08/03/87

SAFETY ISSUES MANAGEMENT SYSTEM

PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M63306	ZION 1 - HOT CHANNEL FACTOR			10/86C	02/87C	C				H	
M63345	ZION 1 - 1986 SALP			11/86C	01/87C	N/A					
M63989	ZION 1 - ESF RESET CONTROLS			11/86C	01/87C	N/A				H	
M64185	ZION 1 - CONTAINMENT FAN COOLERS			12/86C	08/87	C				H	
M64187	ZION 1 - HEATUPS & COOLDOWN CURVES			12/86C	03/87C	C				H	
M64215	ZION 1 - MODS TO RETS			12/86C	08/87	C				H	
M64362	ZION 1 - RE-EVALUATE ISI PROGRAM			01/87C	05/87C	00/87				H	
M64651	ZION 1 - "O" DIESEL GENERATOR OUTAGE TIM			02/87C	5/87C	C				H	
M65094	ZION 1 - REVISED CAPSULE WITHDRAWAL SCHE			04/87C	06/87	C				H	
M65096	ZION 1 - CONTAINMENT ISOLATION SYSTEM			04/87C	05/87	C				H	
MPA-A-01	A-01 10 CFR 50.55 A(G) - ISI			07/77C	08/80C	00/00C		H		H	N
MPA-A-02	A-02 APPENDIX I - ALARA			07/78C	03/86C	09/86C		H		L	N
MPA-A-03	A-03 SECURITY REVIEWS-MODIFIED AMENDMENT PLAN			05/77C	03/79C	C					N
MPA-A-04	A-04 APPENDIX J - CONTAINMENT LEAK TESTING			08/75C	09/81C	08/85C		M		M	N
MPA-A-07	A-07 APPENDIX G - FRACTURE TOUGHNESS			03/76C	06/79C	12/85C		L			N
MPA-A-09	A-09 PRESSURE VESSEL BELTLINE MATERIAL SURVEI			02/78C	04/80C	01/86C		L		L	N
MPA-A-10	A-10 CONTINGENCY PLANNING			03/79C	11/80C	00/86C		H		H	N
MPA-A-11	A-11 GUARD TRAINING PLANS			08/79C	01/81C	00/86C		H		H	N
MPA-A-12	A-12 VITAL AREA ANALYSIS			02/78C	04/82C	N/A		H		H	N

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
MPA-A-18	A-18 TECH SPECS AFFECTED BY 50.72 AND 50.73 (			09/84C	12/87	03/86C		H			N
MPA-A-20	A-20 10 CFR 50.62 OPERATING REACTOR REVIEWS			06/84C	01/88	00/88			H		
MPA-A-21	A-21 10 CFR 50.61, PRESSURIZED THERMAL SHOCK			01/86C	08/86C	01/86C 2 00/88					N
MPA-B-01	B-01 DIESEL GENERATOR LOCKOUT			09/78C	09/78C	00/80C		L	M	L	
MPA-B-02	B-02 FIRE PROTECTION			05/76C	03/78C	00/87		H		H	N
MPA-B-03	B-03 PWR MODERATOR DILUTION			09/77C	02/79C	00/79C		L	M	L	
MPA-B-07	B-07 STEAM GENERATOR FEEDWATER FLOW INSTABILI			09/77C	10/79C	10/79C		M	M	M	
MPA-B-08	B-08 PWR HPSI-LPSI FLOW RESISTANCE			07/77C	10/84C	04/81C		L		L	N
MPA-B-09	B-09 CHARGING SYSTEMS PIPE VIBRATIONS			08/78C	02/80C	N/A		L	M	L	
MPA-B-14	B-14 CEA GUIDE TUBE WEAR			12/77C	10/80C			L		L	N
MPA-B-16	B-16 EMERGENCY PLANNING AND REVISIONS			09/79C	05/81C	12/84C		H		H	N
MPA-B-17	B-17 TECH SPEC SURVEILLANCE FOR HYDRAULIC SNU			08/78C	01/86C	01/86C		L		L	N
MPA-B-20	B-20 CONTAINMENT LEAKAGE DUE TO SEAL DETERIOR			12/78C	08/80C	08/80C		L		L	N
MPA-B-21	B-21 LOSS OF 125-V DC BUS VOLTAGE WITH LOSS O			12/78C	07/77C	N/A		L		L	N
MPA-B-22	B-22 TECH SPEC SURVEILLANCE REQUIREMENTS FOR			08/78C	01/86C	01/86C		M		M	N
MPA-B-23	B-23 DEGRADED GRID VOLTAGE			08/76C	06/82C	03/86C		M	M	M	
MPA-B-24	B-24 VENTING AND PURGING CONTAINMENTS WHILE A			11/79C	08/80C	00/87		H	M	H	
MPA-B-26	B-26 INADVERTANT SAFETY INJECTION DURING COOL			12/78C	12/79C	N/A		M		M	N
MPA-B-39	B-39 PWR PRESSURE - TEMPERATURE LIMIT TECH SP			08/78C	04/80C	N/A		H		H	N

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
MPA-B-41	B-41 FIRE PROTECTION - FINAL TECH SPECS (INCL			03/78C	03/83C	00/81C		H	H	H		
MPA-B-42	B-42 TMI FOLLOW UP - ALL PLANTS			05/79C	03/81C	N/A		H		H	N	
MPA-B-43	B-43 PWR FEEDWATER LINE CRACKS			10/80C	05/82C	05/80C		M		M	N	
MPA-B-44	B-44 LESSONS LEARNED IMPLEMENTATION			09/79C	03/80C	02/80C		H		H	N	
MPA-B-45	B-45 WASH 1400 EVENT V, "PRIMARY COOLANT SYST			02/80C	04/81C	02/80C		H	H	H		
MPA-B-46	B-46 ANALYSIS OF TURBINE DISC CRACKS			12/79C	08/81C	00/87	C	M		M	N	
MPA-B-47	B-47 ECCS; CLAD SWELLING AND RUPTURE			11/79C	09/80C	00/81C		M		M	N	
MPA-B-48	B-48 ADEQUACY OF STATION ELECTRIC DISTRIBUTIO			08/79C	04/81C	00/81C		M	M	M		
MPA-B-52	B-52 REVIEW OF SAFETY ASPECT OF INADVERTENT S			06/79C	10/80C	01/82C		M		M	N	
MPA-B-57	B-57 DHR CAPABILITY			07/80C	06/81C	06/81C		M		M	N	
MPA-B-59	B-59 MASONRY WALL DESIGN			05/80C	09/86C	00/83C		H	M	M		
MPA-B-61	B-61 LOSS OF NON CLASS IE I&C POWER			11/79C	07/82C	05/80C		M	M	M		
MPA-B-62	B-62 ESF RESET CONTROL DESIGN DEFICIENCY			03/80C	08/81C	00/80C		L	H	L		
MPA-B-63	B-63 INTERIM PROCEDURES FOR SHORT TERM BLACKO			05/81C	12/81C	00/85C		M	H	H		
MPA-B-66	B-66 NATURAL CIRCULATION COOLDOWN			05/81C	08/83C	00/85C		M	H	M		
MPA-B-69	B-69 IEB 80-4 MAINSTEAM LINE BREAK WITH CONTI			08/81C	01/83C	00/81C		M	M	M		
MPA-B-70	B-70 FATIGUE TRANSIENT LIMIT TS			07/81C	05/82C	N/A		L		L	N	
MPA-B-72	B-72 NUREG 0737 TECH SPECS (GENERIC LETTER 82			03/83C	11/83C	00/87	88				N	
MPA-B-83	B-83 TECH SPECIFICATIONS COVERED BY GENERIC L			03/84C	10/85C	00/87	88	H			N	

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	10/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
MPA-C-01	C-01	PWR SECONDARY WATER CHEMISTRY MONITORING		08/76C	04/80C	N/A		M		M	N	
MPA-C-04	C-04	FILTER TECH SPECS		11/74C	08/80C	N/A		L		L	N	
MPA-C-06	C-06	PUMP SUPPORT-LAMELLAR TEARING		08/78C	01/81C	N/A		M		M	N	
MPA-C-07	C-07	FUEL HANDLING ACCIDENT INSIDE CONTAINMEN		01/77C	03/79C	00/82C		M		M	N	
MPA-C-09	C-09	PWR AUX FW PUMPS		08/78C	10/80C	N/A		H		H	N	
MPA-C-14	C-14	AUXILIARY FEEDWATER SEISMIC QUALIFICATIO		02/81C	08/83C	00/83C		H	M	H		
MPA-C-16	C-16	UTILITY RESPONSES TO STAFF RECOMMENDATIO		06/85C	02/86C	00/85C					N	
MPA-D-02	D-02	ECCS ZIRC CLAD MODEL ERROR-COMPLIANCE WI		04/78C	02/79C	00/79C		M		M	N	
MPA-D-03	D-03	PRESSURIZER HEATUP RATE ERROR		12/77C	01/79C	04/81C		M		M	N	
MPA-D-11	D-11	FISSION GAS RELEASE		11/76C	02/80C	02/80C					N	
MPA-D-14	D-14	REACTOR VESSEL WELD - WIRE DEFICIENCY		08/78C	04/80C	01/86C					N	
MPA-D-15	D-15	HIGH ENERGY LINE BREAK & CONSEQUENTIAL S		09/79C	01/84C	00/87		L		L	N	
MPA-D-17	D-17	DEFINITION OF OPERABLE		10/80C	06/81C	03/86C		M		M	N	
MPA-E-01	E-01	SPENT FUEL POOL EXPANSIONS		05/78C	03/79C	00/80C		H	L	H		
MPA-E-02	E-02	FUEL CASK DROP		09/75C	04/80C	00/80C		L		L	N	
MPA-F-08	F-08	I.D.1.1 DETAILED CONTROL ROOM DESIGN REV		04/83C	12/87	00/87	90					
MPA-F-63	F-63	III.A.1.2 TECHNICAL SUPPORT CENTER		04/81C	12/87	00/87	C			H		
MPA-F-64	F-64	III.A.1.2 OPERATIONAL SUPPORT CENTER		04/81C	12/87	00/00C	C			H		
MPA-F-65	F-65	III.A.1.2 EMERGENCY OPERATIONS FACILITY		04/81C	12/87	00/87	C			H		

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
ZION 1	05000295	PWR	WEST	3250 MWT	COMMONWEALTH EDISON	IL	3	10/73C	12/08			
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
MPA-F-66	F-66 III.A.1.2	NUCLEAR DATA LINK			04/81C	07/82C	00/82C					
MPA-F-71	F 1 I.D.1.2	DETAILED CONTROL ROOM REVIEW (FO			10/84C	12/87	00/87					
NMSS-2	ACCESS AUTHORIZATION				02/87	12/87	04/88	/89	H			
NMSS-3	MISC AMEND CONCERN PHYSICAL PROTECTION O				07/86	10/86	/87	/87	H			
NMSS-4	SEARCHES OF INDIVIDUALS AT POWER REACTOR				07/86	10/86	/87	/87	H			
NMSS-5	REPORTING REQUIREMENTS FOR SAFEGUARDS EV				/86	/86	/87	/87	H			
NMSS-7	REQUIREMENTS FOR CRIMINAL HISTORY CHECKS				/87	/87	/88	/88	H			
NRR-3	SEVERE ACCIDENT POLICY IMPLEMENTATION ON				09/87	/89.		/89	H			

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M65488	ZION 2 - LOW TEMPERATURE OVERPRESSURE PR			05/87C						H		
50	REACTOR VESSEL LEVEL INSTRUMENTATION IN			N/A	N/A	N/A	N/A					
67.3.3	A-17 IMPROVED ACCIDENT MONITORING			04/83C	12/87	00/87	89		H			
67.4.1	G-01 RCP TRIP			02/83C	12/87	00/85C						
75 (B-76)	B-76 ITEM 1.1 - POST TRIP REVIEW; PROGRAM DES			11/83C	07/85C	00/87					N	
75 (B-77)	B-77 ITEM 2.1 - EQUIPMENT CLASSIFICATION & VE			11/83C	09/87	00/90					N	
75 (B-78)	B-78 ITEMS 3.1.1 & 3.1.2 -POST MAINTENANCE TE			11/83C	07/85C	00/87					N	
75 (B-79)	B-79 ITEM 3.1.3 - POST MAINTENANCE TESTING -			11/83C	12/87	00/89					N	
75 (B-80)	B-80 ITEM 4.1 - REACTOR TRIP SYSTEM RELIABILI			11/83C	07/85C	00/88			H			
75 (B-81)	B-81 ITEMS 4.2.1 & 4.2.2 -PREVENTATIVE MAINT			11/83C	06/85C	00/89					N	
75 (B-82)	B-82 ITEM 4.3 - AUTOMATIC ACTUATION OF SHUNT			11/83C	01/85C	00/89			M			
75 (B-85)	B-85 SALEM ATWS 1.2 DATA CAPABILITY			11/84C	12/87	00/87					N	
75 (B-86)	B-86 SALEM ATWS 2.2 S-R COMPONENTS			11/84C	09/87	00/85C					N	
75 (B-87)	B-87 SALEM ATWS 3.2.1 & 3.2.2 S-R COMPONENTS			11/84C	07/85C	00/89					N	
75 (B-88)	B-88 SALEM ATWS 3.2.3 T.S. S-R COMPONENTS			11/84C	12/87	00/87					N	
75 (B-89)	B-89 SALEM ATWS 4 2.3 & 4.2.4 LIFE COMPONENTS			11/84C	12/87	00/89					N	
75 (B-90)	B-90 SALEM ATWS 4.3 W AND B&W T.S.			07/84C	12/87	10/86					N	
75 (B-92)	B-92 SALEM ATWS 4.5.1 DIVERSE TRIP FEATURES			11/84C	07/85C	00/89					N	
75 (B-93)	B-93 SALEM ATWS 4.5.2 & 4.5.3 TEST ALTERNATIV			11/84C	12/87	00/90					N	

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
A-2	D-10	ASYMMETRIC BLOWDOWN LOADS ON REACTOR PRI		03/79C	02/84C	02/84C				M	N
A-24	B-60	QUALIFICATION OF CLASS IE SAFETY-RELATED		08/80C	11/84C	00/85C			H	H	
A-26	B-04	REACTOR VESSEL PRESSURE TRANSIENT PROTEC		08/76C	04/80C	00/80C			H	M	
A-36 (C-10)	C-10	CONTROL OF HEAVY LOADS OVER SPENT FUEL P		08/77C	03/84C	09/85C			M	M	
A-36 (C-15)	C-15	CONTROL OF HEAVY LOADS - PHASE II (FOLLO		05/83C	06/85C	09/85C					
B-56	D-19	DIESEL GENERATOR RELIABILITY		09/84C	02/86C	00/87		H			N
B-59 (E-05)	E-05	W N-1 LOOP OPERATION		12/76C	11/84C	00/80C N/A				L	N
HF 1.1		SHIFT STAFFING		10/83C	01/84C	10/85C		H			
I.A.1.1.1		SHIFT TECHNICAL ADVISOR - ON DUTY		C	11/80C	11/80C	05/81C				
I.A.1.1.3	F-01	SHIFT TECHNICAL ADVISOR - TRAINED PER LL		10/80C	01/82C	09/86					
I.A.1.1.4		SHIFT TECHNICAL ADVISOR - DESCRIBE LONG		C	/81C	/81C					
I.A.1.2		SHIFT SUPERVISOR RESPONSIBILITIES		C	11/80C	11/80C	05/81C				
I.A.1.3.1	F-02	SHIFT MANNING - LIMIT OVERTIME		04/81C	06/83C	00/83C					
I.A.1.3.2	F-02	SHIFT MANNING - MIN SHIFT CREW		04/81C	06/83C	00/83C					
I.A.1.4		LONG-TERM UPGRADE OF OPERATIONS PERSONNE			04/83	04/83		M			
I.A.2.1.1		IMMEDIATE UPGRADING OF RO & SRO TRAINING		C	11/80C	11/80C					
I.A.2.1.2		IMMEDIATE UPGRADING OF RO & SRO TRAINING			11/80C	11/80C					
I.A.2.1.3		IMMEDIATE UPGRADING OF RO & SRO TRAINING			11/80C	11/80C					
I.A.2.1.4	F-03	IMMEDIATE UPGRADING OF RO & SRO TRAINING		04/81C	03/82C	00/82C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
I.A.2.1.5	IMMEDIATE UPGRADING OF RO & SRO TRAINING				11/80C	11/80C						
I.A.2.3	ADMINISTRATION OF TRAINING PROGRAMS				11/80C	11/80C						
I.A.2.7	ACCREDITATION OF TRAINING INSTITUTIONS			03/85	12/86	03/85	03/87	M				
I.A.3.1.1	REVISE SCOPE & CRITERIA FOR LICENSING EX				11/80C	11/80C						
I.A.3.1.2	REVISE SCOPE & CRITERIA FOR LICENSING EX				11/80C	11/80C						
I.C.1.1	SHORT-TERM ACCIDENT & PROCEDURES REVIEW			C	11/80C	11/80C	04/80C					
I.C.1.2.A	F-04 SHORT-TERM ACCID. & PROCEDURES REV. - IN			04/81C	02/85C	12/85C				H		
I.C.1.2.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - IN			04/81C	01/88	00/87	C			H		
I.C.1.3.A	F-04 SHORT-TERM ACCID. & PROCEDURES REV - TRA			04/81C	02/85C	12/85C				H		
I.C.1.3.B	F-05 SHORT-TERM ACCID. & PROCEDURES REV. - TR			04/81C	01/88	00/87	C			H		
I.C.2	SHIFT & RELIEF TURNOVER PROCEDURES			C	11/80C	11/80C	05/81C					
I.C.3	SHIFT-SUPERVISOR RESPONSIBILITY			C	11/80C	11/80C	05/81C					
I.C.4	CONTROL-ROOM ACCESS			C	11/80C	11/80C	05/81C					
I.C.5	F-06 FEEDBACK OF OPERATING EXPERIENCE			11/81C	01/82C	00/82C						
I.C.6	F-07 VERIFY CORRECT PERFORMANCE OF OPERATING			11/81C	01/82C	00/82C						
I.D.2.1	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	06/84C	00/82C						
I.D.2.2	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	06/84C	00/82C						
I.D.2.3	F-09 PLANT-SAFETY PARAMETER DISPLAY CONSOLE -			04/83C	06/84C	00/82C						
II.B.1.1	REACTOR-COOLANT SYSTEM VENTS - DESIGN VE			C	11/80C	11/80C	N/A					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
II.B.1.2	F-10 REACTOR-COOLANT SYSTEM VENTS - INSTALL V			04/81C	09/83C	00/83C				H		
II.B.1.3	F-10 REACTOR-COOLANT SYSTEM VENTS - PROCEDURE			04/81C	09/83C	00/83C				H		
II.B.2.1	PLANT SHIELDING - REVIEW DESIGNS			C	11/80C	11/80C	N/A					
II.B.2.3	F-11 PLANT SHIELDING - PLANT MODIFICATIONS (L			02/82C	04/83C	00/83C						
II.B.3.1	POSTACCIDENT SAMPLING - INTERIM SYSTEM			C	11/80C	11/80C	05/81C					
II.B.3.4	F-12 POSTACCIDENT SAMPLING - PLANT MODIFICATI			04/81C	06/84C	09/85C				H		
II.B.4.1	F-13 TRAINING FOR MITIGATING CORE DAMAGE - DE			04/81C	05/82C	00/82C				H		
II.B.4.2.A	F-13 TRAINING FOR MITIGATING CORE DAMAGE - IN			04/81C	05/82C	00/82C				H		
II.B.4.2.B	F-13 TRAINING FOR MITIGATING CORE DAMAGE - CO			04/81C	05/82C	00/82C				H		
II.D.1.1	RELIEF & SAFETY VALVE TEST REQUIREMENTS			C	11/80C	11/80C	N/A					
II.D.1.2.A	RELIEF & SAFETY VALVE TEST REQUIREMENTS			C	12/83C	12/83C	N/A					
II.D.1.2.B	F-14 RELIEF & SAFETY VALVE TEST REQUIREMENTS			04/81C	12/87	01/86C				H		
II.D.1.3	RELIEF & SAFETY VALVE TEST REQUIREMENTS			C	12/83C	12/83C	N/A					
II.D.3.1	VALVE POSITION INDICATION - INSTALL DIRE			C	11/80C	11/80C	05/81C					
II.E.1.1.1	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATION -			06/81C	01/83C	00/84C				H		
II.E.1.1.2	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATION -			06/81C	01/83C	00/84C				H		
II.E.1.1.3	F-15 AUXILIARY FEEDWATER SYSTEM EVALUATIONS -			06/81C	01/83C	00/84C				H		
II.E.1.2.1.A	AUXILIARY FEEDWATER SYSTEM INITIATION &			C	11/80C	11/80C						
II.E.1.2.1.B	F-16 AUXILIARY FEEDWATER SYSTEM INITIATION &			04/81C	04/81C	00/82C						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE					STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON					IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY		
II.E.1.2.2.A	AUXILIARY FEEDWATER SYSTEM INITIATION &			C	11/80C	11/80C							
II.E.1.2.2.B	AUXILIARY FEEDWATER SYSTEM INITIATION &			C	N/A	N/A	N/A						
II.E.1.2.2.C	F-17	AUXILIARY FEEDWATER SYSTEM INITIATION &		04/81C	04/81C	00/82C							
II.E.3.1.1	EMERGENCY POWER FOR PRESSURIZER HEATERS			C	11/80C	11/80C	05/81C						
II.E.4.1.1	DEDICATED HYDROGEN PENETRATIONS - DESIGN			C	11/80C	11/80C	05/81C						
II.E.4.1.3	F-18	DEDICATED HYDROGEN PENETRATION - INSTALL		04/81C	09/81C	02/85C							
II.E.4.2.1-4	CONTAINMENT ISOLATION DEPENDABILITY - IMP			C	11/80C	11/80C	05/81C						
II.E.4.2.5.A	CONTAINMENT ISOLAT. DEPENDABILITY - CNM			C	09/82C	00/82C	N/A						
II.E.4.2.5.B	CONTAINMENT ISOLATION DEPENDABILITY - CN			C	09/82C	00/82C							
II.E.4.2.6	F-19	CONTAINMENT ISOLATION DEPENDABILITY - CN		04/81C	09/82C	00/82C				H			
II.E.4.2.7	F-19	CONTAINMENT ISOLATION DEPENDABILITY - RA		04/81C	09/82C	00/82C				H			
II.F.1.2.A	F-20	ACCIDENT-MONITORING - NOBLE GAS MONITOR		04/81C	09/81C	00/87	C						
II.F.1.2.B	F-21	ACCIDENT-MONITORING - IODINE/PARTICULATE		04/81C	09/81C	00/87	C						
II.F.1.2.C	F-22	ACCIDENT-MONITORING - CONTAINMENT HIGH-R		04/81C	01/82C	00/85C							
II.F.1.2.D	F-23	ACCIDENT-MONITORING - CONTAINMENT PRESSU		01/82C	09/83C	00/87	C			H			
II.F.1.2.E	F-24	ACCIDENT-MONITORING - CONTAINMENT WATER		01/82C	09/83C	00/85C				H			
II.F.1.2.F	F-25	ACCIDENT-MONITORING - CONTAINMENT HYDROG		01/82C	09/83C	00/85C				H			
II.F.2.1	INSTRUMENTATION FOR DETECT. OF INADEQUAT				11/80C	11/80C							
II.F.2.2	INSTRUMENTATION FOR DETECT. OF INADEQUAT			C	N/A	N/A	05/81C						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.F.2.4	F-26	INSTRUMENTATION FOR DETECT. OF INADEQUAT		04/81C	08/86C	00/88				H	
II.G.1.1	POWER SUPP.	FOR PRESSURIZER RELIEF, BLOCK		C	11/80C	11/80C	05/81C				
III.A.1.1	EMERGENCY PREPAREDNESS, SHORT TERM				11/80C	11/80C					
III.A.1.2.1	UPGRADE EMERGENCY SUPPORT FACILITIES - I			C	11/80C	11/80C	10/81C				
III.A.2.1	F-67	UPGRADE PREPAREDNESS - UPGRADE EMERGENCY		04/81C	05/83C	00/83C				H	
III.A.2.2	F-68	UPGRADE PREPAREDNESS - METEROROLOGICAL D		04/81C	12/87	00/87				H	
III.C.1.1.1	PRIMARY COOLANT OUTSIDE CONTAIMENT - LEA			C	11/80C	11/80C	05/81C				
III.D.3.3.1	INPLANT RAD. MONIT. - PROVIDE MEANS TO D			C	11/80C	11/80C	05/81C				
III.D.3.3.2	F-69	INPLANT RADIATION MONIT. - MODIFICATIONS		04/81C	02/82C	00/82C				H	
III.D.3.4.1	F-70	CONTROL ROOM HABITABILITY - REVIEW		06/81C	06/82C	00/87	C			H	
III.D.3.4.2	F-70	CONTROL ROOM HABITABILITY - SCHEDULE MOD		06/81C	06/82C	00/87	C			H	
II.K.1.3	IE BULLETINS - 79-06, 79-06A, 79-06A REV			C	C	C	06/79C				
II.K.2.13	F-30	ORDERS ON B&W PLANTS - THERMAL MECHANICA		12/81C	10/83C	00/84C				H	
II.K.2.17	F-33	ORDERS ON B&W PLANTS - VOIDING IN RCS (C		01/82C	01/84C	00/84C				H	
II.K.2.19	BENCHMARK ANALYSIS OF SEQUENTIAL AFW FLO.				12/82C	12/82C					
II.K.3.1.A	F-36	FINAL RECOMMENDATIONS, B&O TASK FORCE - A		04/81C	09/83C	00/83C				H	
II.K.3.1.B	FINAL RECOMMENDATIONS, B&O TASK FORCE - A			C							
II.K.3.10	F-41	FINAL RECOMMENDATIONS, B&O TASK FORCE - P		04/81C	09/81C	00/81C					
II.K.3.12.A	FINAL RECOM., B&O TASK FORCE - ANTICIP. T				/81C	/81C					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION			
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON	IL	3	11/73C	12/08			
APPLICABLE ISSUES					IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
II.K.3.12.B	F-42 FINAL RECOM.	B&O TASK FORCE - ANTICIPATO			04/81C	09/81C	00/81C					
II.K.3.17	F-47 FINAL RECOMMENDATIONS	B&O TASK FORCE - E			04/81C	08/83C	00/83C				H	
II.K.3.2	F-37 FINAL RECOMMENDATIONS	B&O TASK FORCE - R			04/81C	09/83C	00/83C				H	
II.K.3.25.A	FINAL RECOMMENDATIONS	B&O TASK FORCE - P					C	C				
II.K.3.25.B	F-53 FINAL RECOMMENDATIONS	B&O TASK FORCE - P			11/80C	05/82C	00/82C					
II.K.3.3	F-38 FINAL RECOMMENDATIONS	B&O TASK FORCE - R			04/81C	09/82C	00/82C				H	
II.K.3.30.A	FINAL RECOMMENDATIONS	B&O TASK FORCE - S			C	06/85C	06/85C	N/A				
II.K.3.30.B	F-57 FINAL RECOMMENDATIONS	B&O TASK FORCE - S			04/81C	06/85C	06/85C				H	
II.K.3.31	F-58 FINAL RECOMMENDATIONS	B&O TASK FORCE - C			04/82C	04/83C	07/86C				H	
II.K.3.5.A	F-39 FINAL RECOMMENDATIONS	B&O TASK FORCE - A			04/81C	02/83C	08/84C				H	
II.K.3.5.B	F-39 FINAL RECOMMENDATIONS	B&O TASK FORCE - A			04/81C	02/83C	08/84C				H	
II.K.3.9	F-40 FINAL RECOMMENDATIONS	B&O TASK FORCE - P			04/81C	09/81C	00/81C					
M13022	ZION 2 - STANDARD TECH SPEC	LCO'S FOR TA			03/80C	8/82C	N/A			H	H	
M41045	ZION 2 - RESIDUAL RISKS				02/80C	08/85C	N/A			H	H	
M42147	ZION 2 - ATWS INSTRUMENTATION MODIFICATI				02/80C	12/85C	00/89			H	H	
M42307	ZION 2 - CONTROL ROOM - HUMAN FACTORS EN				02/80C	11/83C	00/90			H	H	
M42837	ZION 2 - FAILURE MODE EFFECTS ANALYSIS (				08/80C	12/85C	C			H	H	
M48104	ZION 2 - BORATION FLOW PATHS HEAT TRACIN				07/81C	12/85C	N/A			L	L	
M48693	ZION 2 - LICENSE CONDITION FOR TECH SPEC				08/82C	02/85C	N/A					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO INIT.	IMPO COMP.	IMPL COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M49602	ZION 2 - MOD TO 1980 ORDER - AFWS			12/82C	12/85C	C					
M51307	ZION 2 - OPERABILITY OF VENT/PURGE VALVE			02/83C	04/84C	00/88					
M51902	ZION 2 - 6/27/83 ISI REQUEST			06/83C	12/84C	C					
M52101	ZION 2 - ISI AND ISI PROGRAM, SECOND INT			06/83C	02/86C	C					
M52117	ZION 2 - REVIEW AND APPROVE OR DISAPPROV			07/83C	12/83C	N/A					
M52119	ZION 2 - T.S. CHANGE TO CONT. LEAKAGE TE			08/83C	04/84C	C					
M52186	ZION 2 - T.S. CHANGE RE AUXILIARY ELECTR			08/83C	12/85C						
M52289	ZION 2 - T.S. CHANGE FOR OPTIMIZED FUEL			08/83C	12/83C						
M52381	ZION 2 - TS CHANGE RE COOLANT CHEMISTRY			09/83C	04/84C						
M52526	ZION 2 - T.S. CHANGE RE PREVENTIVE MAINT			10/83C	03/84C						
M52621	ZION 2 ROD SWAP ANALYSIS METHOD			10/83C	12/83C						
M53465	ZION 2 - TS CHANGE RE PREVENTIVE MAINTEN			01/84C	03/84C						
M54161	ZION 2 - ITEM B.6 OF 1980 ORDER			01/84C	12/85C	N/A					
M54163	ZION 2 - REVIEW OF REVISED LICENSED OPER			08/83C	01/86C	N/A					
M54177	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	06/85C	N/A					
M54204	ZION 2 - SCHEDULAR EXEMPTION FROM 10CFR			11/83C	12/87	00/87					
M54307	ZION 2 - CONTROL RAD. CONT. MATERIALS -			03/84C	04/84C	N/A					
M54366	ZION-2 - ONE TIME EXEMPTION FROM STATE A			01/84C	04/84C	N/A					
M54427	ZION 2- RCS VENTS TECHNICAL SPECIFICATIO			03/84C	02/85C	00/88					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M54902	ZION 1 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C	N/A					
M54904	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54906	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54908	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54910	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54912	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54914	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54916	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54918	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54920	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54922	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54924	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54926	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54928	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54930	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54932	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54934	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C	04/87C					
M54936	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C						
M54938	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C	N/A					

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M54940	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C	N/A						
M54942	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C	1						
M54944	ZION 2 - RECONSIDERATION OF FEB. 29, 198			01/84C	10/84C	N/A						
M55025	ZION 2 - SCHEDULAR EXEMPTION FROM 10 CFR			05/84C	06/84C							
M55418	ZION 2 - TECH. SPECS. FOR PURGE/VENT OPE			07/84C	12/87	00/87						
M55583	ZION 2 - MODS TO MEET 10CFR50 APPENDIX R			07/84C	12/87	C						
M55675	ZION 2 - AFW CHECK VALVES - PRA			08/84C	12/84C	C						
M55927	ZION 2 - ASME CODE CASE N-401			09/84C	11/84C	00/87						
M55941	ZION 2 - CORE DAMAGE ASSESSMENT			08/84C	12/84C	C						
M56623	ZION 2 - REVISION 1 TO FIRST 10-YR ISI P			11/84C	06/85C							
M56839	ZION 2 - ROD URGENT FAILURE			02/85C	05/85C							
M56855	ZION 2 - CONTAINMENT INTEPRITY			01/85C	08/85C							
M56857	ZION 1 - ASSISTANCE ON APPENDIX R INSPEC			01/85C	03/85C	N/A						
M56969	ZION 2 - D.G. TESTING			02/85C	12/85C	C						
M57027	ZION 2 - HYDROGEN MONITORS (II.F.1.6)			10/84C	03/85C	C						
M57048	ZION 2 - ECCS ANALYSIS			10/84C	05/85C	C						
M57092	ZION 2 - SPDS EVALUATION			09/84C	12/87	C						
M57660	ZION 2 - REV. 4 TO FIRST 10-YR ISI-IST P			05/85C	07/85C	C						
M59036	ZION 2 - ITEMS A.1 AND A.2 OF 1980 ORDER			06/85C	12/85C	C						

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
M59298	ZION 2 - TECH. SPEC. CHANGE FUEL ENRICH.			07/85C	02/86C	C					
M59486	ZION 2 - DEGRADED GRID VOLTAGE PROTECTIO			08/85C	03/86C	C					
M59493	ZION 2 - MATERIALS IRRADIATION SPECIMEN			08/85C	01/86C	C					
M60042	ZION 2 - REV. 5 1ST 10-YR ISI PROGRAM			10/85C	07/86C	C					
M60312	ZION 2 - RESCINDING 1980 ORDER			11/85C	06/87	00/87					
M60795	ZION 2 - NIS FLUX RATE SET POINTS			02/86C	02/86C	C					
M61367	ZION 2 - STEAM GENERATOR TUBE SLEEVING			04/86C	09/86C	C					
M61546	ZION 2 - NUREG 0737, I.A.1.1 - SHIFT TEC			04/86C	09/86C	C					
M61748	ZION 2 - S. G. TUBE SLEEVING METHODOLOGY			06/86C	11/86C	C					
M61856	ZION 2 - REV. 2 ISI AND 1ST SECOND INTER			06/86C	12/87	00/88					
M62835	ZION 2 - BATTERY CHARGER			09/86C	12/86C	C					
M62987	ZION 2 - 40-YEAR OPERATING LICENSE			09/86C		00/88					
M63170	ZION 2 - BASE LINE INSERVICE INSP. AND A			10/86C	12/87	C				H	
M63172	ZION 2 - NUMBER OF RCP'S IN MODE 3			10/86C	03/87C	C				H	
M63174	ZION 2 - TECH. SPEC. CHANGES - G.L.85-19			10/86C		C				H	
M63307	ZION 2 - HOT CHANNEL FACTOR			10/86C	02/87C	C				H	
M63346	ZION 2 - 1986 SALP			11/86C	01/87C	N/A					
M63990	ZION 2 - ESF RESET CONTROLS			11/86C	07/87	N/A				H	
M64186	ZION 2 - CONTAINMENT FAN COOLERS			12/86C	08/87	C				H	

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
PLANT DATA

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
M64188	ZION 2 - HEATUPS & COOLDOWN CURVES			12/86C	03/87C	C				H		
M64216	ZION 2 - MODS TO RETS			12/86C		C				H		
M64363	ZION 2 - RE-EVALUATE ISI PROGRAM			01/87C	08/87	00/87				H		
M64652	ZION 2 "0" DIESEL GENERATOR OUTAGE TIM			02/87C	05/87C	05/87C	OK C			H		
M65095	ZION 2 - REVISED CAPSULE WITHDRAWAL SCHE			04/87C	03/87C	03/87C	C			H		
M65097	ZION 2 - CONTAINMENT ISOLATION SYSTEM			04/87C	00/87C	00/87C	C			H		
MPA-A-01	A-01 10 CFR 50.55 A(J) - ISI			07/77C	08/80C	00/00C		H		H	N	
MPA-A-02	A-02 APPENDIX I - ALARA			07/78C	03/86C	N/A		H		L	N	
MPA-A-03	A-03 SECURITY REVIEWS-MODIFIED AMENDMENT PLAN			08/77C	02/79C	01/80C					N	
MPA-A-04	A-04 APPENDIX J - CONTAINMENT LEAK TESTING			08/75C	09/81C	08/85C		M		M	N	
MPA-A-07	A-07 APPENDIX G - FRACTURE TOUGHNESS			03/76C	06/79C	12/85C		L			N	
MPA-A-09	A-09 PRESSURE VESSEL BELTLINE MATERIAL SURVEI			02/78C	04/80C	01/86C		L		L	N	
MPA-A-10	A-10 CONTINGENCY PLANNING			03/79C	11/80C	00/86C		H		H	N	
MPA-A-11	A-11 GUARD TRAINING PLANS			08/79C	01/81C	00/86C		H		H	N	
MPA-A-12	A-12 VITAL AREA ANALYSIS			02/78C	04/82C	N/A		H		H	N	
MPA-A-18	A-18 TECH SPECS AFFECTED BY 50.72 AND 50.73 (			09/84C	12/87	03/86C		H			N	
MPA-A-20	A-20 10 CFR 50.62 OPERATING REACTOR REVIEWS			06/84C	01/88	00/88			H			
MPA-A-21	A-21 10 CFR 50.61, PRESSURIZED THERMAL SHOCK			01/86C	08/86C	01/86C	00/88				N	
MPA-B-01	B-01 DIESEL GENERATOR LOCKOUT			08/78C	09/78C	00/80C		L	M	L		

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
MPA-B-02	B-02 FIRE PROTECTION			05/76C	03/78C	00/87		H		H	N	
MPA-B-03	B-03 PWR MODERATOR DILUTION			09/77C	02/79C	00/79C		L	M	L		
MPA-B-07	B-07 STEAM GENERATOR FEEDWATER FLOW INSTABILI			09/77C	10/79C	10/79C		M	M	M		
MPA-B-08	B-08 PWR HPSI-LPSI FLOW RESISTANCE			07/77C	01/79C	04/81C		L		L	N	
MPA-B-09	B-09 CHARGING SYSTEMS PIPE VIBRATIONS			08/78C	02/80C	N/A		L	M	L		
MPA-B-14	B-14 CEA GUIDE TUBE WEAR			12/77C	10/80C			L		L	N	
MPA-B-16	B-16 EMERGENCY PLANNING AND REVISIONS			09/79C	05/81C	12/84C		H		H	N	
MPA-B-17	B-17 TECH SPEC SURVEILLANCE FOR HYDRAULIC SNU			08/78C	01/86C	01/86C		L		L	N	
MPA-B-20	B-20 CONTAINMENT LEAKAGE DUE TO SEAL DETERIOR			12/78C	08/80C	08/80C		L		L	N	
MPA-B-21	B-21 LOSS OF 125-V DC BUS VOLTAGE WITH LOSS O			12/78C	07/77C	N/A		L		L	N	
MPA-B-22	B-22 TECH SPEC SURVEILLANCE REQUIREMENTS FOR			08/78C	01/86C	01/86C		M		M	N	
MPA-B-23	B-23 DEGRADED GRID VOLTAGE			08/76C	06/82C	03/86C		M	M	M		
MPA-B-24	B-24 VENTING AND PURGING CONTAINMENTS WHILE A			11/78C	09/83C	00/87		H	M	H		
MPA-B-26	B-26 INADVERTANT SAFETY INJECTION DURING COOL			12/78C	12/79C	N/A		M		M	N	
MPA-B-32	B-32 BLOCKED SI SIGNAL DURING COOLDOWN			01/83C	04/83C	04/83C		M			N	
MPA-B-39	B-39 PWR PRESSURE - TEMPERATURE LIMIT TECH SP			08/78C	04/80C	N/A		H		H	N	
MPA-B-41	B-41 FIRE PROTECTION - FINAL TECH SPECS (INCL			03/78C	03/83C	00/81C		H	H	H		
MPA-B-42	B-42 TMI FOLLOW UP - ALL PLANTS			05/79C	03/81C	N/A		H		H	N	
MPA-B-43	B-43 PWR FEEDWATER LINE CRACKS			10/80C	05/82C	05/82C		M		M	N	

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE			STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON			IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
MPA-B-44	B-44	LESSONS LEARNED IMPLEMENTATION		09/79C	03/80C	02/80C		H		H	N
MPA-B-45	B-45	WASH 1400 EVENT V, "PRIMARY COOLANT SYST		02/80C	04/81C	02/80C		H	H	H	
MPA-B-46	B-46	ANALYSIS OF TURBINE DISC CRACKS		12/79C	08/81C	00/87	C	M		M	N
MPA-B-47	B-47	ECCS; CLAD SWELLING AND RUPTURE		11/79C	09/80C	00/81C		M		M	N
MPA-B-48	B-48	ADEQUACY OF STATION ELECTRIC DISTRIBUTIO		08/79C	04/81C	00/81C		M	M	M	
MPA-B-52	B-52	REVIEW OF SAFETY ASPECT OF INADVERTENT S		06/79C	10/80C	01/80C		M		M	N
MPA-B-57	B-57	DHR CAPABILITY		07/80C	06/81C	06/81C		V		M	N
MPA-B-59	B-59	MASONRY WALL DESIGN		05/80C	09/86C	00/83C		H	M	M	
MPA-B-61	B-61	LOSS OF NON CLASS IE I&C POWER		11/79C	07/82C	05/80C		M	M	M	
MPA-B-62	B-62	ESF RESET CONTROL DESIGN DEFICIENCY		03/80C	08/81C	00/80C		L	H	L	
MPA-B-63	B-63	INTERIM PROCEDURES FOR SHORT TERM BLACKO		05/81C	12/81C	00/85C		M	H	H	
MPA-B-66	B-66	NATURAL CIRCULATION COOLDOWN		05/81C	08/83C	00/85C		M	H	M	
MPA-B-69	B-69	IEB 80-4 MAINSTEAM LINE BREAK WITH CONTI		08/81C	01/83C	00/81C		M	M	M	
MPA-B-70	B-70	FATIGUE TRANSIENT LIMIT TS		07/81C	05/82C	N/A		L		L	N
MPA-B-72	B-72	NUREG 0737 TECH SPECS (GENERIC LETTER 82		09/82C	11/83C	00/87	88				N
MPA-B-83	B-83	TECH SPECIFICATIONS COVERED BY GENERIC L		03/84C	10/85C	00/87	88	H			N
MPA-C-01	C-01	PWR SECONDARY WATER CHEMISTRY MONITORING		08/76C	04/80C	N/A		M		M	N
MPA-C-04	C-04	FILTER TECH SPECS		01/75C	08/80C	N/A		L		L	N
MPA-C-06	C-06	PUMP SUPPORT-LAMELLAR TEARING		08/78C	01/81C	N/A		M		M	N

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE				STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON				IL	3	11/73C	12/08
APPLICABLE ISSUES				IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY	
MPA-C-07	C-07 FUEL HANDLING ACCIDENT INSIDE CONTAINMEN			01/77C	03/79C	00/82C		M		M	N	
MPA-C-09	C-09 PWR AUX FW PUMPS			08/78C	10/80C	N/A		H		H	N	
MPA-C-14	C-14 AUXILIARY FEEDWATER SEISMIC QUALIFICATIO			02/81C	08/83C	00/83C		H	M	H		
MPA-C-16	C-16 UTILITY RESPONSES TO STAFF RECOMMENDATIO			06/85C	02/86C	00/85C					N	
MPA-D-02	D-02 ECCS ZIRC CLAD MODEL ERROR-COMPLIANCE WI			04/78C	02/79C	00/79C		M		M	N	
MPA-D-03	D-03 PRESSURIZER HEATUP RATE ERROR			08/78C	01/79C	04/81C		M		M	N	
MPA-D-11	D-11 FISSION GAS RELEASE			11/76C	02/80C	02/80C					N	
MPA-D-14	D-14 REACTOR VESSEL WELD - WIRE DEFICIENCY			08/78C	04/80C	01/86C					N	
MPA-D-15	D-15 HIGH ENERGY LINE BREAK & CONSEQUENTIAL S			09/79C	01/84C	00/87		L		L	N	
MPA-D-17	D-17 DEFINITION OF OPERABLE			10/80C	06/81C	03/86C		M		M	N	
MPA-E-01	E-01 SPENT FUEL POOL EXPANSIONS			05/78C	03/79C	00/80C		H	L	H		
MPA-E-02	E-02 FUEL CASK DROP			09/75C	04/80C	00/80C		L		L	N	
MPA-F-08	F-08 I.D.1.1 DETAILED CONTROL ROOM DESIGN REV			04/83C	12/87	00/80	90					
MPA-F-63	F-63 III.A.1.2 TECHNICAL SUPPORT CENTER			04/81C	12/87	00/87	C			H		
MPA-F-64	F-64 III.A.1.2 OPERATIONAL SUPPORT CENTER			04/81C	12/87	00/00C	C			H		
MPA-F-65	F-65 III.A.1.2 EMERGENCY OPERATIONS FACILITY			04/81C	12/87	00/87	C			H		
MPA-F-66	F-66 III.A.1.2 NUCLEAR DATA LINK			04/81C	07/82C	00/82C				H		
MPA-F-71	F-71 I.D.1.2 DETAILED CONTROL ROOM REVIEW (FO			10/84C	12/87	00/87	90					
NMSS-2	ACCESS AUTHORIZATION			02/87	12/87	04/88	/89	H				

R-1216320-SPC

08/03/87

S A F E T Y I S S U E S M A N A G E M E N T S Y S T E M
P L A N T D A T A

PLANT	DOCKET	TYPE	NSSS SUPPLIER	THERMAL CAPACITY	LICENSEE	STATE	REGION	OL ISSUE	OL EXPIRATION
ZION 2	05000304	PWR	WEST	3250 MWT	COMMONWEALTH EDISON	JL	3	11/73C	12/08

APPLICABLE ISSUES	IMPO. INIT.	IMPO. COMP.	IMPL. COMP.	VERIFY COMPLET	ISSUE PRIORITY	MPA VER PRIORITY	DOCKET PRIORITY	VERIFY PRIORITY
NMSS-3 MISC AMEND CONCERN PHYSICAL PROTECTION	0 07/86	10/86	/87	/87	H			
NMSS-4 SEARCHES OF INDIVIDUALS AT POWER REACTOR	07/86	10/86	/87	/87	H			
NMSS-5 REPORTING REQUIREMENTS FOR SAFEGUARDS EV	/86	/86	/87	/87	H			
NMSS-7 REQUIREMENTS FOR CRIMINAL HISTORY CHECKS	/87	/87	/88	/88	H			
NPR-3 SEVERE ACCIDENT POLICY IMPLEMENTATION ON	09/87	/89		/89	H			